

**CapX2020
Hampton – Rochester – La Crosse
345 kV Transmission Project
Docket 5-CE-136
Completeness Response: Item 01-76**

Date of PSCW Request: February 1, 2011
Date of Response: March 2011

Item 01-76 / Appendix U / AFR Section 2.7.1.4.1

Amperage reported on EMF tables for proposed structures report only one current value for each double-circuit configuration. Include amperage for both circuits on each table (e.g. Tables 11 and 11c, the amperage reported for these two tables is identical but the magnetic fields suggest that at least one circuit has a much different amperage value).

Response:


The EMF tables included in Appendix U have been revised to include amperage for both circuits. This revised Appendix U replaces the original Appendix U.


THIS PAGE INTENTIONALLY LEFT BLANK.

REVISED March 2011

Appendix U: Electric and Magnetic Fields (EMF) Information

THIS PAGE INTENTIONALLY LEFT BLANK.





LOOKING TOWARDS NORTH La CROSSE

FIGURE 2

PROPOSED

SEGMENTS: B,D,G,K - OPERATES 345/161kV

SEGMENTS: H,I,J - OPERATES 345/69kV

Table 2 - Calculated Electric Fields Table	
Calculated Electric Field Data ³	
Transmission Line Segments: B2, D2, G2, K2	
Facility Description: ⁴ Proposed Single Pole, 1 String Tangent ⁵	
Double Circuit 345kV/161kV	
Applies to all proposed 345/161 kV 1 String type segments	
Distance from Centerline (feet)	Electric Field (kV/m)
Centerline	2.95
25	4.63
50	1.74
100	0.14
150	0.13
200	0.09
300	0.05
Assumptions: Typical Midspan Sag = 35 to 50 feet Amperage = 304.6 A ³ Provide a measured diagram of structures showing the height of conductors from the ground at the structure. ⁴ Describe facility - Structure type, configuration, location ⁵ Figure 2	

Table 2a - Calculated Electric Fields Table	
Calculated Electric Field Data ³	
Transmission Line Segments: H2, I2, J2	
Facility Description: ⁴ Proposed Single Pole, 1 String Tangent ⁵	
Double Circuit 345kV/161kV Operated at 345kV/69kV	
Applies to all proposed segments energized as 345/69 kV with 1 string insulators	
Distance from Centerline (feet)	Electric Field (kV/m)
Centerline	3.39
25	4.72
50	1.73
100	0.16
150	0.15
200	0.11
300	0.06
Assumptions: Typical Midspan Sag = 35 to 50 feet Amperage = 304.6 A ³ Provide a measured diagram of structures showing the height of conductors from the ground at the structure. ⁴ Describe facility - Structure type, configuration, location ⁵ Figure 2	

Table 9 - Calculated Magnetic Fields Table							
Calculated Magnetic Field Data ³							
Transmission Line Segments: B2							
Facility Description: ⁴ Proposed Single Pole, 1 String Tangent ⁵							
Double Circuit 345kV/161kV							
Circuit 1: Capx North Rochester -- Briggs Road 345 kV							
Circuit 2: Dairyland Alma -- Marshland 161 kV							
(2015) ¹ Normal Load	(2015) ² Normal Peak	(2015) ² Normal Load	(2015) ² Normal Peak	(2015) ² Normal Load	(2015) ² Normal Peak	(2015) ² Normal Load	(2015) ² Normal Peak
Distance from Centerline (feet)	Magnetic Field (mG)	Distance from Centerline (feet)	Magnetic Field (mG)	Distance from Centerline (feet)	Magnetic Field (mG)	Distance from Centerline (feet)	Magnetic Field (mG)
Centerline	38.84	Centerline	48.54	Centerline	45.45	Centerline	56.81
25	25.58	25	31.97	25	29.83	25	37.29
50	11.93	50	14.92	50	13.88	50	17.35
100	3.76	100	4.7	100	7.23	100	5.47
150	1.8	150	2.25	150	2.1	150	2.62
200	1.06	200	1.32	200	1.23	200	1.54
300	0.5	300	0.62	300	0.58	300	0.73
Assumptions: Typical Midspan Sag = 35 to 50 feet Amperage = 304.6A (345kV), 351.4A (161kV) for 2015 and 354.8A (345kV), 412.4A (161kV) for 2025 345 kV Circuit Phase Angle: A phase = 0 Deg, B phase = 240 Deg, C phase = 120 Deg 161 kV Circuit Phase Angle: A phase = 240 Deg, B phase = 120 Deg, C phase = 0 Deg ¹ Expected in-service date of new facility ² Calculated MF based on expected loads 10 years in the future after in-service date ³ Provide a measured diagram of structures showing the height of conductors from the ground at the structure. ⁴ Describe facility - Structure type, configuration, location ⁵ Figure 2							

Table 10 - Calculated Magnetic Fields Table							
Calculated Magnetic Field Data ³							
Transmission Line Segments: D2							
Facility Description: ⁴ Proposed Single Pole, 1 String Tangent ⁵							
Double Circuit 345kV/161kV							
Circuit 1: Capx North Rochester -- Briggs Road 345 kV							
Circuit 2: Dairyland Marshland -- La Crosse Tap 161 kV							
(2015) ¹ Normal Load	(2015) ² Normal Peak	(2015) ² Normal Load	(2015) ² Normal Peak	(2015) ² Normal Load	(2015) ² Normal Peak	(2015) ² Normal Load	(2015) ² Normal Peak
Distance from Centerline (feet)	Magnetic Field (mG)	Distance from Centerline (feet)	Magnetic Field (mG)	Distance from Centerline (feet)	Magnetic Field (mG)	Distance from Centerline (feet)	Magnetic Field (mG)
Centerline	26.17	Centerline	32.71	Centerline	30.13	Centerline	37.62
25	25.76	25	32.2	25	30.21	25	37.79
50	15.51	50	19.38	50	18.36	50	22.99
100	5.5	100	6.87	100	6.56	100	8.21
150	2.54	150	3.17	150	3.04	150	3.81
200	1.41	200	1.76	200	1.69	200	2.12
300	0.6	300	0.75	300	0.72	300	0.9
Assumptions: Typical Midspan Sag = 35 to 50 feet Amperage = 304.6A (345kV), 111.2A (161kV) for 2015 and 354.8A (345kV), 114.8A (161kV) for 2025 345 kV Circuit Phase Angle: A phase = 0 Deg, B phase = 240 Deg, C phase = 120 Deg 161 kV Circuit Phase Angle: A phase = 240 Deg, B phase = 120 Deg, C phase = 0 Deg ¹ Expected in-service date of new facility ² Calculated MF based on expected loads 10 years in the future after in-service date ³ Provide a measured diagram of structures showing the height of conductors from the ground at the structure. ⁴ Describe facility - Structure type, configuration, location ⁵ Figure 2							

Table 11 - Calculated Magnetic Fields Table							
Calculated Magnetic Field Data ³							
Transmission Line Segments: K2							
Facility Description: ⁴ Proposed Single Pole, 1 String Tangent ⁵							
Double Circuit 345kV/161kV							
Circuit 1: Capx North Rochester -- Briggs Road 345 kV							
Circuit 2: Xcel Energy Tremol -- Mayfair 161 kV							
Distance from Centerline (feet)	Magnetic Field (mG)	Distance from Centerline (feet)	Magnetic Field (mG)	Distance from Centerline (feet)	Magnetic Field (mG)	Distance from Centerline (feet)	Magnetic Field (mG)
Centerline	29.16	Centerline	36.46	Centerline	30.67	Centerline	38.35
25	24.93	25	31.16	25	29.9	25	37.38
50	13.92	50	17.39	50	17.91	50	22.39
100	4.69	100	5.86	100	6.33	100	7.91
150	2.12	150	2.65	150	2.92	150	3.65
200	1.16	200	1.46	200	1.62	200	2.02
300	0.49	300	0.61	300	0.68	300	0.86
Assumptions: Typical Midspan Sag = 35 to 50 feet Amperage = 304.6A (345kV), 190.1A (161kV) for 2015 and 354.8A (345kV), 136.3A (161kV) for 2025 345 and 161 kV Circuit Phase Angles: A phase = 0 Deg, B phase = 240 Deg, C phase = 120 Deg ¹ Expected in-service date of new facility ² Calculated MF based on expected loads 10 years in the future after in-service date ³ Provide a measured diagram of structures showing the height of conductors from the ground at the structure. ⁴ Describe facility - Structure type, configuration, location ⁵ Figure 2							

Table 11a - Calculated Magnetic Fields Table							
Calculated Magnetic Field Data ³							
Transmission Line Segments: H2, I2 ⁶							
Facility Description: ⁴ Proposed Single Pole, 1 String Tangent ⁵							
Double Circuit 345kV/161kV; Operated at 345kV/69kV							
Circuit 1: Capx North Rochester -- Briggs Road 345 kV							
Circuit 2: North Creek -- Arcadia 69 kV or Arcadia -- Frenchville Tap 69 kV							
(2015) ¹ Normal Load	(2015) ² Normal Peak	(2015) ² Normal Load	(2015) ² Normal Peak	(2015) ² Normal Load	(2015) ² Normal Peak	(2015) ² Normal Load	(2015) ² Normal Peak
Distance from Centerline (feet)	Magnetic Field (mG)	Distance from Centerline (feet)	Magnetic Field (mG)	Distance from Centerline (feet)	Magnetic Field (mG)	Distance from Centerline (feet)	Magnetic Field (mG)
Centerline	25.69	Centerline	32.11	Centerline	30.24	Centerline	37.8
25	26.07	25	32.58	25	30.14	25	37.68
50	15.94	50	19.92	50	18.26	50	22.83
100	5.72	100	7.15	100	6.51	100	8.13
150	2.65	150	3.32	150	3.01	150	3.76
200	1.48	200	1.85	200	1.67	200	2.09
300	0.63	300	0.79	300	0.71	300	0.89
Assumptions: Typical Midspan Sag = 35 to 50 feet Amperage = 304.6A (345kV), 92A (69kV) for 2015 and 354.8A (345kV), 120.49A (69kV) for 2025 345 kV Circuit Phase Angle: A phase = 0 Deg, B phase = 240 Deg, C phase = 120 Deg 69 kV Circuit Phase Angle: A phase = 240 Deg, B phase = 120 Deg, C phase = 0 Deg ¹ Expected in-service date of new facility ² Calculated MF based on expected loads 10 years in the future after in-service date ³ Provide a measured diagram of structures showing the height of conductors from the ground at the structure. ⁴ Describe facility - Structure type, configuration, location ⁵ Figure 2 ⁶ Because of the very small load at Arcadia substation, current flows at each side of the substation are very similar in value. Therefore, calculations for H and I were made using the higher of the two values (Segment H).							

Table 11b - Calculated Magnetic Fields Table							
Calculated Magnetic Field Data ³							
Transmission Line Segments: J2							
Facility Description: ⁴ Proposed Single Pole, 1 String Tangent ⁵							
Double Circuit 345kV/161kV; Operated at 345kV/69kV							
Circuit 1: Capx North Rochester -- Briggs Road 345 kV							
Circuit 2: Frenchville Tap -- Galesville 69 kV							
(2015) ¹ Normal Load	(2015) ² Normal Peak	(2015) ² Normal Load	(2015) ² Normal Peak	(2015) ² Normal Load	(2015) ² Normal Peak	(2015) ² Normal Load	(2015) ² Normal Peak
Distance from Centerline (feet)	Magnetic Field (mG)	Distance from Centerline (feet)	Magnetic Field (mG)	Distance from Centerline (feet)	Magnetic Field (mG)	Distance from Centerline (feet)	Magnetic Field (mG)
Centerline	29.69	Centerline	37.1	Centerline	34.59	Centerline	43.24
25	24.88	25	31.09	25	28.97	25	36.21
50	13.73	50	17.15	50	15.98	50	19.97
100	4.59	100	5.74	100	5.34	100	6.68
150	2.07	150	2.59	150	2.41	150	3.02
200	1.14	200	1.42	200	1.32	200	1.66
300	0.48	300	0.6	300	0.56	300	0.7
Assumptions: Typical Midspan Sag = 35 to 50 feet Amperage = 304.6A (345kV), 200.82A (69kV) for 2015 and 354.8A (345kV), 234.29A (69kV) for 2025 345 kV Circuit Phase Angle: A phase = 0 Deg, B phase = 240 Deg, C phase = 120 Deg 69 kV Circuit Phase Angle: A phase = 240 Deg, B phase = 120 Deg, C phase = 0 Deg ¹ Expected in-service date of new facility ² Calculated MF based on expected loads 10 years in the future after in-service date ³ Provide a measured diagram of structures showing the height of conductors from the ground at the structure. ⁴ Describe facility - Structure type, configuration, location ⁵ Figure 2							

Table 11c - Calculated Magnetic Fields Table							
Calculated Magnetic Field Data ³							
Transmission Line Segments: G2							
Facility Description: ⁴ Proposed Single Pole, 1 String Tangent ⁵							
Double Circuit 345kV/161kV							
Circuit 1: Capx North Rochester -- Briggs Road 345 kV							
Circuit 2: Alma -- Tremol 161 kV							
(2015) ¹ Normal Load	(2015) ² Normal Peak	(2015) ² Normal Load	(2015) ² Normal Peak	(2015) ² Normal Load	(2015) ² Normal Peak	(2015) ² Normal Load	(2015) ² Normal Peak
Distance from Centerline (feet)	Magnetic Field (mG)	Distance from Centerline (feet)	Magnetic Field (mG)	Distance from Centerline (feet)	Magnetic Field (mG)	Distance from Centerline (feet)	Magnetic Field (mG)
Centerline	80.03	Centerline	100.03	Centerline	98.29	Centerline	122.87
25	42.5	25	53.13	25	52.18	25	65.23
50	19.36	50	24.2	50	24.17	50	30.21
100	8.34	100	10.42	100	10.52	100	13.15
150	4.81	150	6.02	150	6.07	150	7.58
200	3.09	200	3.87	200	3.89	200	4.87
300	1.56	300	1.95	300	1.96	300	2.45
Assumptions: Typical Midspan Sag = 35 to 50 feet Amperage = 304.6A (345kV), 861.84A (161kV) for 2015 and 354.8A (345kV), 1062.66A (161kV) for 2025 345 kV Circuit Phase Angle: A phase = 0 Deg, B phase = 240 Deg, C phase = 120 Deg 161 kV Circuit Phase Angle: A phase = 240 Deg, B phase = 120 Deg, C phase = 0 Deg ¹ Expected in-service date of new facility ² Calculated MF based on expected loads 10 years in the future after in-service date ³ Provide a measured diagram of structures showing the height of conductors from the ground at the structure. ⁴ Describe facility - Structure type, configuration, location ⁵ Figure 2							


THIS DRAWING WAS PREPARED BY POWER ENGINEERS, INC. FOR A SPECIFIC PROJECT, TAKING INTO CONSIDERATION THE SPECIFIC AND UNIQUE REQUIREMENTS OF THE PROJECT. REUSE OF THIS DRAWING OR ANY INFORMATION CONTAINED IN THIS DRAWING FOR ANY PURPOSE IS PROHIBITED UNLESS WRITTEN PERMISSION FROM BOTH POWER AND POWER'S CLIENT IS GRANTED.

REVISED March 2011

		</

Table 4 - Calculated Electric Fields Table	
Calculated Electric Field Data ³	
Transmission Line Segments: C4	
Facility Description: ⁴ Proposed Single Pole, 1 String Tangent with underbuild ⁵	
Double Circuit 345kV/161kV with 69kV underbuild	
Applies to proposed 345/161/69 kV triple circuit south of Cochrane, WI	
Distance from Centerline (feet)	Electric Field (kV/m)
Centerline	1.35
25	1.28
50	0.95
100	0.22
150	0.02
200	0.06
300	0.04
Assumptions: Typical Midspan Sag = 35 to 50 feet Amperage = 304.6 A ³ Provide a measured diagram of structures showing the height of conductors from the ground at the structure. ⁴ Describe facility - Structure type, configuration, location ⁵ Figure 4	

Table 15 - Calculated Magnetic Fields Table							
Calculated Magnetic Field Data ³							
Transmission Line Segments: C4							
Facility Description: ⁴ Proposed Single Pole, 1 String Tangent with underbuild ⁵							
Double Circuit 345kV/161kV with 69kV underbuild							
Circuit 1: Capx North Rochester – Briggs Road 345 kV				Circuit 2: Alma – Marshland 161 kV			
Circuit 3: Dairyland's Xcel Cochrane – DPC Cochrane 69 kV							
(2015) ¹ Normal Load		(2015) ¹ Normal Peak		(2025) ² Normal Load		(2025) ² Normal Peak	
Distance from Centerline (feet)	Magnetic Field (mG)	Distance from Centerline (feet)	Magnetic Field (mG)	Distance from Centerline (feet)	Magnetic Field (mG)	Distance from Centerline (feet)	Magnetic Field (mG)
Centerline	14.48	Centerline	18.09	Centerline	16.56	Centerline	20.7
25	10.23	25	12.79	25	11.88	25	14.85
50	7.71	50	9.63	50	8.98	50	11.23
100	4.36	100	5.45	100	5.08	100	6.35
150	2.56	150	3.2	150	2.98	150	3.73
200	1.62	200	2.03	200	1.89	200	2.36
300	0.79	300	0.98	300	0.92	300	1.15
Assumptions: Typical Midspan Sag = 35 to 50 feet Amperage = 304.6A (345kV), 351.4A (161kV), 58.6A (69kV) for 2015 and 354.8A (345kV), 412.4A (161kV), 62.8A (69kV) for 2025 345 and 69 kV Circuit Phase Angles: A phase = 0 Deg, B phase = 240 Deg, C phase = 120 Deg 161 kV Circuit Phase Angle: A phase = 240 Deg, B Phase = 120 Deg, C phase = 0 Deg ¹ Expected in-service date of new facility ² Calculated MF based on expected loads 10 years in the future after in-service date ³ Provide a measured diagram of structures showing the height of conductors from the ground at the structure. ⁴ Describe facility - Structure type, configuration, location ⁵ Figure 4							



LOOKING TOWARDS NORTH La CROSSE

FIGURE 4

PROPOSED
SEGMENT: C



PROPOSED
SEGMENTS: C,D

Table 16a - Calculated Magnetic Fields Table							
Calculated Magnetic Field Data ³							
Transmission Line Segments: B5							
Facility Description: ⁵ Proposed H Frame Tangent ⁵							
Double Circuit 345kV/161kV							
Circuit 1: Capex North Rochester -- Briggs Road 345 kV				Circuit 2: Alma -- Marshland 161 kV			
(2015) ¹ Normal Load		(2015) Normal Peak		(2025) ² Normal Load		(2025) Normal Peak	
Distance from Centerline (feet)	Magnetic Field (mG)	Distance from Centerline (feet)	Magnetic Field (mG)	Distance from Centerline (feet)	Magnetic Field (mG)	Distance from Centerline (feet)	Magnetic Field (mG)
Centerline	63.66	Centerline	79.56	Centerline	74.43	Centerline	93.05
25	74.28	25	92.84	25	58.22	25	108.26
50	68.76	50	85.94	50	80.11	50	100.15
100	14.41	100	18.02	100	12.85	100	20.97
150	4.19	150	5.23	150	2.17	150	6.09
200	1.92	200	2.4	200	0.69	200	2.8
300	0.71	300	0.89	300	0.16	300	1.04

Assumptions:

Typical Midspan Sag = 35 to 50 feet

Amperage = 304.6A (345kV), 351.4A (161kV) for 2015 and 354.8A (345kV), 412.4A (161kV) for 2025

345 kV Circuit Phase Angle: A phase = 0 Deg, B phase = 240 Deg, C phase = 120 Deg

161 kV Circuit Phase Angle: A phase = 240 Deg, B phase = 120 Deg, C phase = 0 Deg

¹Expected in-service date of new facility

²Calculated MF based on expected loads 10 years in the future after in-service date

³Provide a measured diagram of structures showing the height of conductors from the ground at the structure.

⁵Describe facility - Structure type, configuration, location

Figure 5

Calculated Magnetic Field Data ³							
Transmission Line Segments: D5							
Facility Description: ⁵ Proposed H Frame Tangent ⁵							
Double Circuit 345kV/161kV							
Circuit 1: Capx North Rochester -- Briggs Road 345 kV				Circuit 2: Marshland -- La Crosse tap 161 kV			
(2015) ⁵ Normal Load		(2015) Normal Peak		(2025) ² Normal Load		(2025) Normal Peak	
Distance from Centerline (feet)	Magnetic Field (mG)	Distance from Centerline (feet)	Magnetic Field (mG)	Distance from Centerline (feet)	Magnetic Field (mG)	Distance from Centerline (feet)	Magnetic Field (mG)
Centerline	43.12	Centerline	53.91	Centerline	49.21	Centerline	61.52
25	67.18	25	83.97	25	77.83	25	97.31
50	65.81	50	82.26	50	76.47	50	95.6
100	15.57	100	19.47	100	18.21	100	22.77
150	4.78	150	5.97	150	5.6	150	7
200	2.25	200	2.81	200	2.64	200	3.3
300	0.84	300	1.05	300	0.99	300	1.24

Assumptions:
 Typical Midspan Sag = 35 to 50 feet
 Amperage = 304.6A (345kV), 111.2A (161kV) for 2015 and 354.8A (345kV), 114.8A (161kV) for 2025
 345 kV Circuit Phase Angle: A phase = 0 Deg, B phase = 240 Deg, C phase = 120 Deg
 161 kV Circuit Phase Angle: A phase = 240 Deg, B Phase = 120 Deg, C phase = 0 Deg

¹Expected in-service date of new facility

²Calculated MF based on expected loads 10 years in the future after in-service date

³Provide a measured diagram of structures showing the height of conductors from the ground at the structure.

⁴Describe facility - Structure type, configuration, location


⁵Figure 5

REVISED March 2011

		DSGN	PEI	7/14/10
		DRN	PEI	7/14/10
		CKD	PEI	7/14/10
		SCALE: NTS		
REFERENCE DRAWINGS		FOR 11x17 DWG ONLY		



CAPX2020	JOB NUMBER	REV
EMF FIGURES	118645	
GENERAL DRAWING	DRAWING NUMBER	
345/161-kV H-FRAME TANGENT	S5-5	



LOOKING TOWARDS NORTH La CROSSE

FIGURE 7

Table 7 - Calculated Electric Fields Table	
Calculated Electric Field Data ³	
Transmission Line Segments: F7	
Facility Description: ⁴ Proposed Single Pole, 1 String Vertical Tangent ⁵	
Single Circuit 345kV	
Applies to proposed single circuit 345 kV vertical segments along WI Hwy 93 near Galesville.	
Distance from Centerline (feet)	Electric Field (kV/m)
Centerline	3.85
25	1.07
50	0.1
100	0.21
150	0.17
200	0.12
300	0.06
Assumptions: Typical Midspan Sag = 35 to 50 feet Amperage = 304.6 A ³ Provide a measured diagram of structures showing the height of conductors from the ground at the structure. ⁴ Describe facility - Structure type, configuration, location ⁵ Figure 7	

Table 18 - Calculated Magnetic Fields Table							
Calculated Magnetic Field Data ³							
Transmission Line Segments: F7							
Facility Description: ⁴ Proposed Single Pole, 1 String Vertical Tangent ⁵							
Single Circuit 345kV							
Circuit: Capx North Rochester -- Briggs Road 345 kV							
(2015) ¹ Normal Load		(2015) ¹ Normal Peak		(2025) ² Normal Load		(2025) ² Normal Peak	
Distance from Centerline (feet)	Magnetic Field (mG)	Distance from Centerline (feet)	Magnetic Field (mG)	Distance from Centerline (feet)	Magnetic Field (mG)	Distance from Centerline (feet)	Magnetic Field (mG)
Centerline	24.93	Centerline	31.16	Centerline	29.04	Centerline	36.3
25	15.07	25	18.83	25	17.55	25	21.94
50	9.13	50	11.41	50	10.63	50	13.29
100	4.06	100	5.07	100	4.73	100	5.91
150	2.2	150	2.75	150	2.56	150	3.21
200	1.36	200	1.7	200	1.58	200	1.98
300	0.65	300	0.82	300	0.76	300	0.95
Assumptions: Typical Midspan Sag = 35 to 50 feet Amperage = 304.6 A for 2015 and 354.8 A for 2025 345 kV Circuit Phase Angle: A phase = 0 Deg, B phase = 240 Deg, C phase = 120 Deg ¹ Expected in-service date of new facility ² Calculated MF based on expected loads 10 years in the future after in-service date ³ Provide a measured diagram of structures showing the height of conductors from the ground at the structure. ⁴ Describe facility - Structure type, configuration, location ⁵ Figure 7							

PROPOSED
SEGMENT: F

THIS DRAWING WAS PREPARED BY POWER ENGINEERS, INC. FOR A SPECIFIC PROJECT, TAKING INTO CONSIDERATION THE SPECIFIC AND UNIQUE REQUIREMENTS OF THE PROJECT. REUSE OF THIS DRAWING OR ANY INFORMATION CONTAINED IN THIS DRAWING FOR ANY PURPOSE IS PROHIBITED UNLESS WRITTEN PERMISSION FROM BOTH POWER AND POWER'S CLIENT IS GRANTED.

REVISED March 2011

		DSGN	PEI	7/14/10
		DRN	PEI	7/14/10
		CKD	PEI	7/14/10
		SCALE: NTS		
		FOR 11x17 DWG ONLY		
		REFERENCE DRAWINGS		



CAPX2020	JOB NUMBER	REV
EMF FIGURES GENERAL DRAWING	118645	B
345-kV I-STRING VERTICAL TANGENT	DRAWING NUMBER	S5-7

Table 19 - Calculated Electric Fields Table

Calculated Electric Field Data ³	
Transmission Line Segments: N8, Q8, L8	
Facility Description: ⁴ Existing Single Pole, H-Frame Single Circuit 161kV	
Applies to all existing 161 kV H-	
Distance from Centerline (feet)	Electric Field (kV/m)
Centerline	0.68
25	1.72
50	0.82
100	0.15
150	0.05
200	0.02
300	0.01

Table 22 - Calculated Magnetic Fields Table

Calculated Magnetic Field Data ³			
Transmission Line Segments: U8			
Facility Description: ⁵ Existing H-Frame			
Single Circuit 161kV			
Circuit: Dairyland Marshland – La Crosse tap 161 kV and Xcel Energy's Tremwal – Mayfair 161 kV			
Existing Normal Load		Existing Normal Peak	
Distance from Centerline (feet)	Magnetic Field (mG)	Distance from Centerline (feet)	Magnetic Field (mG)
Centerline	14.46	Centerline	18.06
25	10.1	25	12.61
50	4.5	50	5.62
100	1.32	100	1.66
150	0.61	150	0.76
200	0.35	200	0.44
300	0.16	300	0.2

Assumptions:
 Typical Midspan Sag = 26 to 30 feet
 Amperage = 89.6 A
 Amperage on these two lines were essentially the same, so the highest of the two values was used for magnetic field calculations.
 The calculation used Xcel Energy's phase angles of A = 0, B = 240 and C = 120. Using Dairyland's phase angles changes the values by about 0.1%.


³ Provide a measured diagram of structures showing the height of conductors from the ground at the structure.

⁴ Describe facility - Structure type, configuration, location

⁵ Figure 8

Table 22a - Calculated Magnetic Fields Table

Calculated Magnetic Field Data ³			
Transmission Line Segments: N8_Q8			
Facility Description: ¹ Existing H-Frame ³			
Single Circuit 161kV			
Circuit 1: Alma - Marshland 161 kV or Alma - Tremva 161 kV ²			
Existing Normal Load		Existing Normal Peak	
Distance from Centerline (feet)	Magnetic Field (mG)	Distance from Centerline (feet)	Magnetic Field (mG)
Centerline	68.74	Centerline	86.07
25	48	25	60.11
50	21.39	50	26.78
100	6.3	100	7.89
150	2.91	150	3.64
200	1.67	200	2.09
300	0.77	300	0.96



LOOKING TOWARDS NORTH La CROSSE

FIGURE 8

EXISTING

SEGMENTS: N,P,Q,U


THIS DRAWING WAS PREPARED BY POWER ENGINEERS, INC. FOR A SPECIFIC PROJECT, TAKING INTO CONSIDERATION THE SPECIFIC AND UNIQUE REQUIREMENTS OF THE PROJECT. REUSE OF THIS DRAWING OR ANY INFORMATION CONTAINED IN THIS DRAWING FOR ANY PURPOSE IS PROHIBITED UNLESS WRITTEN PERMISSION FROM BOTH POWER AND POWER'S CLIENT IS GRANTED.

REVISED March 2011

DSGN	PEI	9/27/10
DRN	PEI	9/27/10
CKD	PEI	9/27/10
SCALE:		
NTS		
FOR 11x17 DWG ONLY		

CapX2020

CAPX2020
EMF FIGURES GENERAL DRAWING
161-kV H-FRAME

JOB NUMBER 118645	REV 
DRAWING NUMBER S5-8	




Table 20 - Calculated Electric Fields Table	
Calculated Electric Field Data ³	
Transmission Line Segments: R9, S9, T9 (majority of existing poles); ⁶ O9 (all poles)	
Facility Description: ⁴ Existing Single Pole, Horizontal Post ⁵	
Single Circuit 69kV	
Applies to all existing 69 kV	
Distance from Centerline (feet)	Electric Field (kV/m)
Centerline	0.69
25	0.28
50	0.08
100	0.03
150	0.01
200	0.01
300	0
Assumptions:	
Typical Midspan Sag = 23 to 25 feet	
Amperage = 200.8 A	
³ Provide a measured diagram of structures showing the height of conductors from the ground at the structure.	
⁴ Describe facility - Structure type, configuration, location	
⁵ Figure 9	
⁶ Segments R, S, and T: The majority of the poles on these segments are horizontal post. Although a few wishbone and vertical configured structures exist they were modeled as horizontal post because 1) there are very few of them and 2) horizontal posts h	

Table 23 - Calculated Magnetic Fields Table			
Calculated Magnetic Field Data ³			
Transmission Line Segments: R9, S9 (majority of spans) ⁶			
Facility Description: ⁴ Existing Single Pole, Horizontal Post ⁵			
Single Circuit 69kV			
Circuit: Dairyland North Creek -- Arcadia 69 kV and Dairyland Arcadia -- Frenchville tap 69 kV			
Existing Normal Load		Existing Normal Peak	
Distance from Centerline (feet)	Magnetic Field (mG)	Distance from Centerline (feet)	Magnetic Field (mG)
Centerline	13.05	Centerline	16.32
25	6.59	25	8.23
50	2.53	50	3.16
100	0.71	100	0.89
150	0.31	150	0.39
200	0.17	200	0.22
300	0.07	300	0.09
Assumptions:			
Typical Midspan Sag = 23 to 25 feet			
Amperage = 138.9 A			
69 kV Circuit Phase Angle: A phase = 240 Deg, B Phase = 120 Deg, C phase = 0 Deg			
³ Provide a measured diagram of structures showing the height of conductors from the ground at the structure.			
⁴ Describe facility - Structure type, configuration, location			
⁵ Figure 9			
⁶ Because of the very small load at Arcadia substation, current flows at each side of the substation are very similar in value. Therefore, calculations for H and I were made using the higher of the two values (Segment H).			

Table 23a - Calculated Magnetic Fields Table			
Calculated Magnetic Field Data ³			
Transmission Line Segments: T9 (majority of spans)			
Facility Description: ⁴ Existing Single Pole, Horizontal Post			
Single Circuit 69kV			
Circuit: Dairyland Frenchville tap -- Galesville 69 kV			
Existing Normal Load		Existing Normal Peak	
Distance from Centerline (feet)	Magnetic Field (mG)	Distance from Centerline (feet)	Magnetic Field (mG)
Centerline	18.88	Centerline	23.59
25	9.53	25	11.9
50	3.66	50	4.57
100	1.02	100	1.28
150	0.45	150	0.57
200	0.25	200	0.31
300	0.11	300	0.13
Assumptions:			
Typical Midspan Sag = 23 to 25 feet			
Amperage = 200.8 A			
69 kV Circuit Phase Angle: A phase = 240 Deg, B Phase = 120 Deg, C phase = 0 Deg			
³ Provide a measured diagram of structures showing the height of conductors from the ground at the structure.			
⁴ Describe facility - Structure type, configuration, location			
⁵ Figure 9			

Table 23b - Calculated Magnetic Fields Table			
Calculated Magnetic Field Data ³			
Transmission Line Segments: O9			
Facility Description: ⁴ Existing Single Pole, Horizontal Post ⁵			
Single Circuit 69kV			
Circuit: Xcel Cochrane -- Dairyland Cochrane 69 kV			
Existing Normal Load		Existing Normal Peak	
Distance from Centerline (feet)	Magnetic Field (mG)	Distance from Centerline (feet)	Magnetic Field (mG)
Centerline	3.77	Centerline	4.72
25	1.9	25	2.38
50	0.73	50	0.92
100	0.2	100	0.26
150	0.09	150	0.11
200	0.05	200	0.06
300	0.02	300	0.03
Assumptions:			
Typical Midspan Sag = 23 to 25 feet			
Amperage = 40.2 A			
69 kV Circuit Phase Angle: A phase = 0 Deg, B phase = 240 Deg, C phase = 120 Deg			
³ Provide a measured diagram of structures showing the height of conductors from the ground at the structure.			
⁴ Describe facility - Structure type, configuration, location			
⁵ Figure 9			

EXISTING
SEGMENTS: R,S,T,O

* SEE NOTE ON TABLE 20.

THIS DRAWING WAS PREPARED BY POWER ENGINEERS, INC. FOR A SPECIFIC PROJECT, TAKING INTO CONSIDERATION THE SPECIFIC AND UNIQUE REQUIREMENTS OF THE PROJECT. REUSE OF THIS DRAWING OR ANY INFORMATION CONTAINED IN THIS DRAWING FOR ANY PURPOSE IS PROHIBITED UNLESS WRITTEN PERMISSION FROM BOTH POWER AND POWER'S CLIENT IS GRANTED.

REVISED March 2011

	REFERENCE DRAWINGS

DSGN	PEI	9/27/10
DRN	PEI	9/27/10
CKD	PEI	9/27/10
SCALE:		NTS
FOR 11x17 DWG ONLY		



CAPX2020
EMF FIGURES GENERAL DRAWING
69-kV MONO-POLE


JOB NUMBER	REV
118645	B
DRAWING NUMBER	
S5-9	

Table 21 - Calculated Electric Fields Table

Calculated Electric Field Data ³	
Transmission Line Segments: R10, S10, T10	
Facility Description: ² Existing Single Pole, H Frame (used on large angles and long spans) ⁵	
Single Circuit 69kV	
Applies to all existing 69 kV H-	
Distance from Centerline (feet)	Electric Field (kV/m)
Centerline	0.3
25	0.72
50	0.22
100	0.04
150	0.01
200	0.01
300	0

Table 24 - Calculated Magnetic Fields Table

Calculated Magnetic Field Data ³			
Transmission Line Segments: S10 (certain long spans)			
Facility Description: ⁴ Existing Single Pole, H Frame			
Single Circuit 69kV			
Circuit: Dairyland North Creek -- Arcadia 69 kV and Dairyland Arcadia -- Frenchville tap 69 kV			
<i>Existing Normal Load</i>		<i>Existing Normal Peak</i>	
Distance from Centerline (feet)	Magnetic Field (mG)	Distance from Centerline (feet)	Magnetic Field (mG)
Centerline	27.79	Centerline	34.74
25	13.56	25	16.96
50	4.74	50	5.92
100	1.28	100	1.6
150	0.58	150	0.72
200	0.32	200	0.41
300	0.14	300	0.18



LOOKING TOWARDS NORTH L_a CROSSE

FIGURE 10

EXISTING
SEGMENTS: R,S,T

THIS DRAWING WAS PREPARED BY POWER ENGINEERS, INC. FOR A SPECIFIC PROJECT, TAKING INTO CONSIDERATION THE SPECIFIC AND UNIQUE REQUIREMENTS OF THE PROJECT. REUSE OF THIS DRAWING OR ANY INFORMATION CONTAINED IN THIS DRAWING FOR ANY PURPOSE IS PROHIBITED UNLESS WRITTEN PERMISSION FROM BOTH POWER AND POWER'S CLIENT IS GRANTED.

REVISÉD March 2011

		DSGN	PEI	9/27/10
		DRN	PEI	9/27/10
		CKD	PEI	9/27/10
		SCALE: NTS		
REFERENCE DRAWINGS		FOR 11x17 DWG ONLY		

CapX2020

CAPX2020	JOB NUMBER	REV
EMF FIGURES GENERAL DRAWING	118645	B
69-kV H-FRAME	DRAWING NUMBER	
	S5-10	

