

Before the Minnesota Public Utilities Commission
State of Minnesota

**In the Matter of Requests for Certificates of Need for Three 345 kV Transmission
Line Projects with Associated System Interconnections**

PUC Docket No. E-002/CN-06-1115,

OAH No. 15-2500-19350-2

**DIRECT TESTIMONY
OF
MICHAEL MICHAUD
MATRIX ENERGY SOLUTIONS**

**ON BEHALF OF
THE NORTH AMERICAN WATER OFFICE
AND
INSTITUTE FOR LOCAL SELF RELIANCE**

May 23, 2008

Table of Contents

I.	INTRODUCTION & QUALIFICATIONS.....	1
II.	FORECASTING ISSUES & CONCERNS	2
III.	CONSERVATION AND LOAD MANAGEMENT	7
IV.	RENEWABLES GENERATION SUPPORT	11
V.	NEED FOR COMMUNITY RELIABILITY SUPPORT	17
A.	Rochester Area.....	17
B.	La Crosse Area	21
C.	Fargo Area	24
D.	Alexandria Area.....	25
E.	St. Cloud Area	26
VI.	GREENHOUSE GAS EMISSION IMPACTS.....	29
A.	Climate Change Statute Requirements.....	29
B.	Impacts from Power Line Construction	31
C.	Impacts from Enabled Coal Generation.....	32
VII.	ALTERNATIVES ANALYSIS	33
A.	System Wide Needs.....	34
	<i>Power System Design Strategies</i>	35
	<i>Dispersed Generation Studies</i>	37
B.	Community Reliability.....	39
	<i>The Smart Grid</i>	39
C.	Renewables Support.....	43
	<i>Focus on Delivered Cost of Energy</i>	44
D.	Ratepayer Economic Impact.....	44

<i>Community Based Energy Development</i>	46
<i>Cost allocation and Ownership</i>	46
VIII. SUMMARY AND RECOMMENDATIONS	48

LIST OF EXHIBITS

Exhibit # 1: Resume of Michael Michaud

Exhibit # 2: Supplement to NAWO & ILSR IR #7

Exhibit # 3: Supplemental Response to NAWO & ILSR IR #12, Spreadsheet

Exhibit # 4: Response to NAWO & ILSR IR #18

Exhibit # 5: Response to NAWO & ILSR IR #13

Exhibit # 6: Supplemental Response to NAWO & ILSR IR #16

Exhibit # 7: Xcel Energy Smart Grid White Paper

Exhibit # 8: Supplemental Response to NAWO & ILSR IR #15

Exhibit # 9: PNL Fast Facts Paper

1 **I INTRODUCTION & QUALIFICATIONS**

2 **Q. Please state your name, occupation, and business address.**

3 A. My name is Michael Michaud. I am an independent energy consultant specializing in
4 renewable community based energy development, transmission and interconnection
5 issues, and renewable energy policy development. My business address is 802 North
6 Pine Creek Road, Maiden Rock, WI. 54750.

7 **Q. What is your educational and professional background?**

8 A. I have experience and education in electrical engineering, wind energy project
9 development, and energy policy analysis. I have a Bachelors Degree in Electrical
10 engineering from the University of Minnesota, Institute of Technology and a Master of
11 Science Degree from the University Of Minnesota Hubert Humphrey Institute Of Public
12 Affairs in Science and Technology Policy. I have 13 years of policy analysis and
13 Certificate of Need process experience working on staff of the Minnesota Public Utilities
14 Commission, the Minnesota Department of Commerce, and the Minnesota
15 Environmental Quality Board. I have been involved in transmission planning activities
16 since the mid 1990's as a regulatory participant and as an independent consultant. I have
17 attached a resume as Exhibit 1 to my testimony.

18 **Q. What is the purpose of your testimony in this proceeding?**

19 A. I will provide technical comments on behalf of the North American Water Office and
20 the Institute for Local Self Reliance (NAWO & ILSR) to show that the Applicants have
21 not met their burden of proof on specific statutory requirements necessary before a
22 Certificate of Need can be issued for these lines under Minn. Stat. §216B.243,

1 specifically subd 3 and 3a. I will address separately each of the three claimed categories
2 of need as defined in the Application.

3 **Q. Which particular items in the statutes will you address?**

4 I will discuss problems with the Applicants 1) forecasting: 2) conservation and load
5 management analysis, 3) inadequate planning for regional renewable energy
6 development, 4) their legal requirement to consider the greenhouse gas emission impacts
7 from the proposed project, 5) their inadequate analysis of renewable generation
8 alternatives, and 6) an inadequate examination of the alternatives for the specific
9 community service reliability issues as identified in the Application.
10

11 **II. FORECASTING ISSUES & CONCERNS**

12 **Q. Why is the accuracy of the Applicants' forecast an issue?**

13 A. The Application shows that their statement of need for these facilities is based on the
14 projected system wide growth in energy consumption expected in the 2020 time frame.
15 (App. P. 1.4). The core of the analysis they offer in support of this need is based on a
16 forecast of future growth of energy consumption. Under Minn. Stat. § 216B.243, subd 3
17 item (1) the Applicants have the burden of showing that their forecast of long range
18 energy demand is accurate.

19 **Q. Where is the forecast of system wide growth found in the Application?**

20 A. The technical analysis supporting the system wide growth claim regarding the need for
21 these facilities is found in the Application in the CAPX 2020 Technical Update

1 document, Appendix A-1, Table 1. It shows a load growth forecast for the CAPX
2 utilities systems of 6300 MW by the year 2020.

3 **Q. What are your concerns about the accuracy of this forecast?**

4 A. This Technical Update study work is shown on page one of Appendix A-1 to have
5 been completed in October 2005. That means that the forecast assumptions used in the
6 analysis would have to have been made in 2004. Those forecasts are now four years old,
7 and numerous economic and legislative forces have been at work since that time that
8 affect the future forecast of energy. More recent Integrated Resource Plans have been
9 filed by the CAPX utilities with updated forecasts for the year 2020. Significant changes
10 made during the 2007 legislative session in Minnesota regarding an increased
11 requirement for conservation and substantial renewable energy requirements have created
12 a new paradigm that renders the forecasts used by the Applicants obsolete and inaccurate.

13 **Q. What are the specific requirements of the 2007 legislation regarding increased
14 conservation?**

15 A. Minnesota Session Laws 2007, Ch 136 established a policy goal of conserving 1.5%
16 of annual retail electric energy sales beginning in 2010. Prior to the passage of this new
17 law, Minnesota did not have a specific performance-based conservation requirement. All
18 of the forecasts used in the studies in Appendix A-1, and the data provided in Appendix
19 C, were made without consideration of this new requirement.

20 **Q. How can you be sure these new law changes are of significant magnitude to
21 impact the accuracy of the Applicants' forecasts?**

22 On July 20, 2007, Xcel Energy filed a "Notice of Changed Circumstances" in Docket E-

1 002/RP-04-752 indicating that “our preliminary analyses of the impacts of the 2007
2 legislation indicates substantial changes to system operations and suggest changed needs
3 with respect to resource size, type, and timing.” Transmission resource size, type, and
4 timing, is the focus of this proceeding. Also, on September 17, 2007, Great River Energy
5 issued a press release indicating it is withdrawing from an ownership position in the Big
6 Stone II power plant. GRE cited one reason for their withdrawal being recent Minnesota
7 legislation regarding renewables and conservation, stating, “the implications of the
8 aggressive new state requirements on the Great River Energy’s resource needs will be
9 significant.” These developments show that even the Applicants now recognize the
10 magnitude and impact that new changes in the laws have on forecasting and future
11 resource needs.

12 **Q. What other information is available to support a different forecast scenario from**
13 **the one used by the Applicants?**

14 A. In response to an information request regarding updating forecasts submitted to the
15 Applicants by NAWO & ILSR, the Applicants have provided new forecast information in
16 a supplement to IR #7 dated May 1, 2008. That information is attached as Exhibit 2 to
17 this testimony.

18 **Q. What does this new forecast data show?**

19 A. The supplemental data provide updated median and high Integrated Resource Plan
20 forecasts that result in a median forecast load growth scenario for the CAPX utilities of
21 3919 MW and a high growth scenario of 4789 MW. The new median forecast is about
22 600 MW below the lower boundary forecast range used in the CAPX 2020 Technical
23 Update Study provided in Appendix A-1. Even the new high-end forecast barely meets

1 the lower boundary growth range of 4500 MW that was presented in the Applicants
2 analysis. The magnitude of the error in their forecast assumptions can be seen by
3 noticing that the 6300 MW of load growth assumed in the Application is 1510 MW, or
4 about 31.5 % above the high-end Integrated Resource Plan forecast, and 60% above the
5 median forecast of 3919 MW.

6 **Q. Do you have any concerns about the accuracy of this new data?**

7 A. Yes, the new data shows that Northern States Power (Xcel Energy) only assumed a
8 1.1 % conservation component in their forecast. This is contrary to what the law now
9 directs them to achieve. The impact of understating the legal requirement for
10 conservation is to overstate the MW of future energy demand. Thus the total MW that
11 should be expected to occur in the area of concern by 2020 will be even less than stated
12 in this new data.

13 **Q. Can you explain in more detail the legal requirement to use a 1.5% conservation**
14 **value in the forecast?**

15 A. The 1.5% conservation policy goal was codified in statute as Minn. Stat. §
16 216B.2401. The legislature directed how this policy would be implemented by also
17 modifying Minn. Stat. § 216B.241, subd 1c, clause (b). The new language in § 216B.241
18 states that each individual utility and association shall have an annual energy savings goal
19 equivalent to 1.5 percent of gross annual retail energy sales unless modified by the
20 Commissioner of the Department of Commerce in a specific petition requesting a
21 variance. No variances have been granted as of yet, so all the CAPX utilities with
22 Minnesota load now have a conservation goal of 1.5 % per year and this proceeding
23 should be assuming they will comply with their legal requirement. This perspective was

1 recently affirmed by the Administrative Law Judge in a Certificate of Need proceeding
2 regarding the proposed Big Stone II power plant. In a supplemental order the ALJ stated:

3 “The Applicants should not be excused from the 1.5 percent goal in this
4 Certificate of Need proceeding. It provides an appropriate planning goal
5 for energy conservation. It would be contrary to the statute to plan to not
6 meet the goal established by the Legislature, particularly where, as here,
7 new facilities are being built, and particularly where this is one of the very
8 first cases to arise under the new goal. If any of the Applicants need relief
9 from the goal in future years, that can be provided by the Commissioner of
10 Commerce under the new statute. At the beginning of a trip, you plan to
11 stay on the main road and to use “off ramps” only when necessary.”¹
12

13 **Q. Why is this new data significant?**

14 The high growth Integrated Resource Plan forecast represents the upper edge of the
15 reasonable planning scenario range of growth. The lower limit of the forecast range used
16 in the CAPX 2020 Technical Update Study barely coincides with the upper boundary of
17 the range of scenarios used in resource planning proceedings. This indicates that all the
18 forecast scenarios used in the Technical Update Study do not constitute a reasonable
19 basis for determining the size, type, or timing of future resource acquisitions, including
20 for transmission resources subject of this proceeding.

21 **Q. Can you explain how this applies to transmission facilities?**

22 A. The computer models of future years used in transmission analysis are created by
23 building in assumptions of future load growth as a first step. The potential to reach
24 operating limits on the grid system generally increases as you increase load. By
25 overstating the amount of load growth in the input modeling assumptions, you are
26 overstating the likelihood that new facilities will be needed to fix operational constraints.

¹ See OAH Docket. No. 12-2500-17037-2, MPUC Docket. No. ET-6131, ET-2, ET-6130, ET-10, ET-6444, E-017, ET-9/CN-05-619. ALJ Order dated May 9, 2008, page 7, finding #17.

1 The number and locations of constraints will be different depending on load growth
2 assumptions, and therefore the size type and timing of necessary upgrades will be
3 exaggerated.

4 **Q. What do you conclude from this new forecast data?**

5 A. The Applicants have not met their burden under Minn. Stat. § 216B.243 subd 3(1) to
6 provide an accurate long range energy demand forecast of the projected system wide
7 growth in energy consumption expected in the 2020 time frame on which the necessity
8 for these facilities is based.

9
10 **III. CONSERVATION AND LOAD MANAGEMENT**

11 **Q. Why is conservation and load management important to this proceeding?**

12 A. One of the burdens placed on the Applicants by Minn. Stat. § 216B.243 is the burden
13 to show that the demand for electricity cannot be met more cost effectively through
14 energy conservation and load-management measures. The statute requires the
15 Commission to consider “the effect of existing or possible energy conservation
16 programs under sections 216C.05 to 216C.30 and this section or other federal or state
17 legislation on long-term energy demand.”

18 **Q. How should this requirement be interpreted in this proceeding?**

19 A. The Applicants have declared a three-part argument for the need for these
20 facilities: a generalized system wide load growth need, a local load serving based
21 need and a renewables development need. The application of the Certificate of Need

1 criteria identified in statute must be applied separately to each of the three
2 components of their argument.

3 **Q. Can you explain how conservation and load management applies to the**
4 **system wide load growth portion of the stated need?**

5 A. In my previous discussion of forecasting issues I have pointed out how the
6 Applicants' Technical Update Study has failed to incorporate in their analysis the
7 new requirement in state law to achieve 1.5 % annual energy savings beginning in
8 2010. This is a failure to properly consider conservation measures applied uniformly
9 across the defined geographic need area. In addition, the Applicants have failed to
10 study how targeted application of load management programs could relieve
11 congestion points on the transmission grid, thus relieving the peak demand
12 constraints that drive the alleged need for the specific transmission infrastructure
13 enhancements they propose.

14 **Q. Please explain what you mean by relieving peak demand constraints?**

15 A. For most of the year the transmission system is relatively underutilized. During
16 certain hours of the year, usually in July or August in Minnesota, the demand for
17 electricity peaks and the utilization of the transmission system reaches its maximum
18 usage state. Flows on all the transmission lines do not increase equally, so some
19 lines reach their maximum rated capacity before others. These system constraints on
20 power flow are on specific lines and totally definable. Targeted peak demand
21 management programs focused on geographic areas "downstream" from the
22 congestion point can relieve the power flow at the congestion point. Utilizing load
23 management to relieve transmission constraints instead of building new transmission

1 capacity is like encouraging drivers to shift their driving habits rather than building
2 additional lanes on the highway.

3 **Q. How should the Applicants have used the targeted application of load**
4 **management analysis for system wide load growth?**

5 A. Once the Applicants developed a reasonable forecast for the year 2020, the type
6 of transmission system analysis used in the technical study of Appendix A-1 would
7 identify constrained areas on the grid. At that point, the models could be tested for
8 sensitivity to targeted load management efforts in relevant geographic areas. Even
9 under the exaggerated forecast used in the study in Appendix A-1, they failed to
10 investigate this requirement of the law.

11 **Q. How would the legal requirement for the Applicant's consideration of**
12 **conservation and load management be applied to local load serving needs?**

13 A. The Application in section 4.1 lists several alleged specific local community
14 service reliability areas. Minn. Stat. § 216B.243, subd 3(8) requires consideration
15 of "any feasible combination of energy conservation improvements, required under
16 section 216B.241, that can (i) replace part or all of the energy to be provided by the
17 proposed facility, and (ii) compete with it economically." The Applicants should
18 have examined how targeted conservation and load management programs could
19 have partially or completely resolved each of the 2020 year local reliability issues
20 they have identified. These types of programs are readily available and are deployed
21 routinely by utilities. Load management strategies coupled with distributed
22 generation resources is also a scenario they should have examined.

1 **Q. What is your assessment of the Applicant’s analysis of conservation and load**
2 **management as applied to local community reliability issues?**

3 A. They have failed to comply with their statutory burden. The Applicants have not
4 analyzed the potential for targeted load management or conservation strategies to
5 replace all or part of the energy to be provided by these facilities to the communities
6 alleged to have reliability needs. The Application consideration of Alternatives,
7 provided in Chapter Seven, does not include any discussion of conservation or load
8 management. None of the local area technical studies provided in Appendix A-2
9 through A-4 considered the potential for conservation or load management to impact
10 the community reliability need component for the proposed facilities. In addition, all
11 of the technical transmission studies were completed prior to the passage of the new
12 conservation requirements to achieve 1.5% energy savings outlined in Minnesota
13 Session Laws 2007, Ch 136, and so each of the local area peak demand forecasts used in
14 the transmission studies fails to consider this important legal requirement in the local
15 reliability analysis. These transmission needs analyses cannot be relied upon since these
16 older forecasts used by the Applicants overstate the load growth and therefore predict the
17 need for additional reliability support in a timeframe earlier than the most likely scenario.

18 **Q. Does the Environmental Report prepared by the Department of Commerce**
19 **adequately address this load management and conservation issue?**

20 A. No. The Environmental Report limits its discussion of conservation and load
21 management issues to only three short paragraphs, (see page 90) and does not consider
22 the role of conservation or load management as a partial solution to be used in
23 combination with other alternatives.

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22

IV. RENEWABLES GENERATION SUPPORT

Q. What are your concerns regarding the Applicants claim that these facilities are needed for renewables generation support?

A. In their need summary on this issue, page 1.14 and 1.15 of the Application, the Applicants assert that these three lines are a “necessary step” toward meeting Minnesota’s renewable energy policy goals and that “it is important to provide transmission support so that renewable development can continue.” I concur with the general statement that transmission lines are necessary to support our electricity system and Minnesota's renewable energy policy goals, but the Applicants have not demonstrated that any of these three new 345 kV lines are a “necessary” precondition to being able to meet these goals.

Q. Can you explain your statement in relation to each of the three proposed lines in more detail?

A. The only specific renewables targeted transmission study evidence offered to by the Applicants is the analysis in Appendix A-4 related to the Twin Cities - Brookings 345 kV line. That analysis shows that this proposed segment will raise the generation outlet capability from the Buffalo Ridge area from 1200 MW to approximately 1900 MW. The generation in the interconnection queues, that are waiting to be connected in the Buffalo Ridge area, are almost exclusively wind. One can presume that if built, this line would perform as the study indicates. The problem is that the Applicants have not demonstrated in this record that unless we develop more outlet capability from the

1 Buffalo Ridge area, Minnesota utilities cannot meet their renewable energy mandates. In
2 other words, the option of meeting our goals by developing renewable generation in other
3 geographic areas and targeting existing transmission and distribution lines has not been
4 analyzed in the Application. We cannot know whether providing 700 MW of outlet
5 capability from this geographic area with this particular line is the best option towards
6 meeting the state’s renewable energy policy goals considering economic goals, power
7 system, and community reliability needs. Ongoing transmission study work regarding
8 Dispersed Generation siting strategies will likely help inform this issue.

9 Regarding the Twin Cities – Fargo 345 kV line the Applicants offer in their
10 renewables support discussion on page 4.48, that this line by itself “will enable an
11 additional 350 MW of generation to be transmitted on the electrical system to
12 customers.” The Analysis provided in Appendix A-3, Table 5.1.A, in support of this line
13 shows that this 350 MW is actually an increase in transfer capability across the North
14 Dakota export boundary that limits power transfer from North Dakota to Minnesota and
15 points east. There is no guarantee that this increase in transfer capability will be utilized
16 by wind. On the contrary there are entities trying to develop additional coal resources
17 that could take up this additional transfer capability. So this claim that the Fargo line will
18 enable renewables cannot be substantiated by this statement. Nothing in the supporting
19 transmission study for this line, Appendix A-3, demonstrates any specific renewable
20 development support.

21 The Twin Cities – La Crosse line is alleged to support renewables development,
22 on page 4.47 of the Application, because “the ability of the electrical system to transfer
23 power is currently constrained” and the new line relieves a 161 kV constraint on the grid

1 during an outage when flow on the Byron - Adams 345 kV line exceeds 766 MW north to
2 south. It is useful to know that the new proposed 345 kV line will enable increased flows
3 out of the Twin Cities southward toward Iowa. This fact by itself does not demonstrate
4 that the 779 MW, presumably wind, the Applicants have identified is in the queue in
5 Mower County, will be able to move power northward to serve Twin Cities load if the
6 line is built. Nothing in the supporting transmission study, Appendix A-2, for the Twin
7 Cities - Lacrosse 345 kV line demonstrates any specific renewable generation
8 development support.

9 **Q. What are the ramifications of the Applicants not demonstrating all the lines will**
10 **be used to transmit renewable generation?**

11 A. For at least the Fargo 345 kV line and the La Crosse 345 kV line, it must be presumed
12 that they will transmit electric power generated by non-renewable energy sources. This
13 fact triggers a need for the Applicants to comply with Minn. Stat. § 216B.243, subd 3a,
14 that prohibits the Commission from issuing a Certificate of need for a facility “that
15 transmits electric power generated by means of a nonrenewable energy source, unless the
16 applicant for the certificate has demonstrated to the commission's satisfaction that it has
17 explored the possibility of generating power by means of renewable energy sources and
18 has demonstrated that the alternative selected is less expensive (including environmental
19 costs) than power generated by a renewable energy source.” The Applicants have made
20 no attempt to comply with their burden of proof under this decision criterion. Arguments
21 that you cannot substitute renewable generation sources for these transmission lines do
22 not hold up if one assumes that the renewable generation is developed as dispersed
23 facilities located reasonably close to the load to be served. Since bio-fueled base load

1 and peaking plants are renewable resources, the argument that the intermittent nature of
2 renewable resources requires transmission to reach base load coal plants does not apply
3 here.

4 **Q. What other observations do you have about the need to provide transmission to**
5 **support our renewable energy policy goals?**

6 A. I have two main concerns about the approach taken by the CAPX utilities leading up
7 to this proceeding. The first is that all the analysis provided in Appendix A-1 was done
8 almost four years ago, when the state only had a policy objective of obtaining 10%
9 renewable energy as a long term goal. The decision to proceed with this application,
10 utilizing obsolete assumptions for the level of renewables required by 2020, now a 20 %
11 mandate, flies in the face of the requirement now in state statute to create a long term
12 transmission plan to support the recently enacted Renewable Energy Standards (RES).

13 The second major concern is that the planning paradigm used in the Appendix A-
14 1 analysis is based only on the obsolete assumption that new generation will be installed
15 in large scale projects located remote from where the power is needed. This planning
16 presumption virtually guarantees that you will come up with a need for additional high
17 voltage transmission resources and runs contrary to state policy that desires an efficient
18 use of existing transmission resources and corridors. Minnesota Stat. §216E.03 calls for
19 the transmission determinations to be guided by the "state's goals to conserve resources,
20 minimize environmental impacts, minimize human settlement and other land use
21 conflicts, and ensure the state's electric energy security through efficient, cost-effective
22 power supply and electric transmission infrastructure."

1 The high voltage transmission resources that are identified under these generation
2 assumptions may be more expensive than necessary to meet customer requirements and
3 renewable energy policy objectives. The transmission resources identified using the
4 Applicants' obsolete generation assumptions are biased in a manner that virtually ensures
5 that state Community-Based Energy Development (C-BED) policy objectives will be
6 stunted. In enacting Minnesota Statutes §216B.1612 lawmakers established a preferential
7 C-BED tariff to "optimize local, regional, and state benefits from renewable energy
8 development and to facilitate widespread development of community-based renewable
9 energy projects throughout Minnesota."

10 **Q. What is the transmission planning requirement for renewables now in statute?**

11 A. Minnesota Session Laws 2007 Ch. 3, sec 2, requires a comprehensive effort to study
12 and develop plans for the transmission network enhancements necessary to support the
13 renewable energy standards and milestones established in Minnesota Statutes. The
14 Minnesota utilities were required to submit a report to the Minnesota Public Utilities
15 Commission by November 1, 2007, describing the activities undertaken pursuant to this
16 section. The filing contained a five year action plan that identifies with specificity the
17 actions necessary to implement the specific proposals and to refine and further develop
18 the transmission plans needed to support those standards and milestones.

19 **Q. What are your concerns about that plan?**

20 A. Rather than approach the question of what transmission do we need to support
21 renewables at a level twice the previous standard with a fresh unbiased effort, the utilities
22 simply assumed that the CAPX Phase I facilities, subject of this proceeding, were a done
23 deal. They did not examine whether these proposed facilities were the appropriate match

1 for a system designed to optimize delivery of that new renewable energy to Minnesota
2 retail customers while maintaining system reliability.

3 **Q. Please explain your concerns about the assumption that new generation will be**
4 **installed in large scale projects located remote from where the power is needed?**

5 A. For many decades the standard way to generate electricity was by utilizing large-scale
6 central station plants. This assumption no longer holds true. Even small MW scale wind
7 plants can compete on price of energy with large scale gas plants today. The
8 “distributed” or “dispersed” construction of multiple small MW utility scale generation
9 resources is now possible given present day technological development and economics.
10 The problem is that utility planners are only now beginning to realize that this alternative
11 paradigm has value, and they failed to consider that value when proposing these facilities
12 as a solution to the alleged problem.

13 The CAPX utilities have asserted that the proposed facilities fit all likely
14 generation development scenarios (see Application page 1.14.) However, in response to
15 NAWO & ILSR's information request #12, provided as Exhibit 3, it is now known that
16 generation alternative scenarios examined by the Applicants were biased overwhelmingly
17 to large-scale generation facilities. The legislative directive to plan transmission to meet
18 the RES goals requires the utilities to “incorporate and build upon the analyses that have
19 previously been done or that are in progress, including, but not limited to, the 2006
20 Minnesota Wind Integration Study and ongoing work to address geographically dispersed
21 development patterns.” The legislature specifically required examination of dispersed
22 generation development scenarios, building on the work started in the West Central
23 CBED Study, as part of trying to find the optimal transmission network to deliver

1 renewables to Minnesota customers but the transmission study provided by the
2 Applicants in Appendix A-1 has not done so.

4 **V. NEED FOR COMMUNITY RELIABILITY SUPPORT**

5 **Q. The Applicants have stated that a major part of the need for these lines is for**
6 **community reliability support. What are your concerns about their examination of**
7 **these issues?**

8 A. The Application, in Chapter 4, identifies a future need for additional reliability
9 support for the communities around and including Fargo, North Dakota, Alexandria, St.
10 Cloud, Rochester, and the Winona and La Crosse, Wisconsin area. Each of those
11 locations has unique circumstances that require an individual analysis of the validity of
12 the claimed need and the range of alternatives available to mitigate any concerns. It is
13 my opinion that the Applicants have generally overstated the urgency of the need for
14 reliability enhancements, have ignored or undervalued various strategies for meeting the
15 actual need for system enhancements in these areas, and as a consequence have not
16 selected more cost effective and timely alternatives to resolve the problems while
17 complying with Minnesota's renewable and energy efficiency public policy objectives.

18 ***A. Rochester Area***

19 **Q. Please outline your concerns about the stated need for reliability support for the**
20 **Rochester Area.**

1 A. There is little to dispute about the existing conditions regarding load serving
2 resources available in the Rochester area. Some type of system reinforcement or
3 dramatic reduction in energy usage is needed soon to mitigate the situation. However,
4 the system reinforcements proposed by Applicants as a solution are substantively flawed.
5 First, I'll note that there are deficiencies in the forecasted load growth that overstate the
6 likely level of peak load to be expected in the 2020 timeframe. Second, even using the
7 Applicant's erroneous forecast, there are more cost effective solutions to serving
8 Rochester area load growth than the one proposed. Third, the Applicants have very
9 recently revealed that they plan new 161 kV transmission facilities to connect to the
10 Rochester system in the next few years, that further diminish the argument that a facility
11 the size of the 345 kV line proposed here is the most cost effective way to enhance load
12 service to the Rochester area.

13 **Q. How do forecast deficiencies impact the need for system enhancements?**

14 A. Transmission engineers examine projected peak load levels to determine at what level
15 of Megawatts of demand the system reaches a reliability standard violation event.
16 Differences in the rate of growth of load shift the point in time when the reliability event
17 would be predicted to occur. Overstating the load growth forecast makes the reliability
18 problem appear to occur sooner. A lower forecasted rate of growth would add additional
19 time before a reliability problem would occur. In the case of Rochester, since there is an
20 existing need for system enhancements, the question before us is what option most cost
21 effectively relieves the problems, and for how long. The forecast assumptions impact the
22 calculation of how long any option would reliably serve Rochester load.

1 **Q. What leads you to conclude that the Applicants forecast overstates likely load**
2 **growth?**

3 A. As discussed above the requirements in Minnesota's new energy conservation laws
4 affect likely forecasts of energy and demand growth. Even in the latest forecast data
5 provided to NAWO & ILSR in Exhibit 2 to my testimony, the forecast for Rochester
6 Public Utilities remains based on the MAPP 2006 Load and Capability report. These
7 figures were developed prior to the passage of the 2007 Session Law and so the local
8 Rochester area forecast used in the transmission studies is out of date and the changed
9 public policy will change the load forecast for Rochester.

10 **Q. What impact does this have on the analysis of solutions to the Rochester**
11 **problem?**

12 A. An overstated forecast results in understating the useful life of the various alternatives
13 considered.

14 **Q. What are the implications of the very recently revealed new 161 kV transmission**
15 **facilities the Applicants plan to connect to the Rochester system in the next few**
16 **years?**

17 A. In Direct Testimony provided by Applicants witness Amanda King, (p.21) it has been
18 disclosed that Xcel Energy plans to build three new 161 kV facilities in the Rochester
19 area, and that Dairyland Power plans to upgrade a fourth 161 kV facility in the Rochester
20 area. These are massive changes to the Rochester area transmission system that will
21 provide additional load support out to at least 2018, according to Ms. Kings' testimony.
22 Since this information was just recently made available, I have been unable as yet to
23 discover the details of the assumptions behind her projection of 2018 as a date when the

1 reliability issues are now projected to occur. Since the Applicants forecast data provided
2 so far over states likely local load growth rates, the 2018 date offered by Ms. King may
3 very well understate the time horizon when problems will begin to occur in the Rochester
4 area after these new 161 kV reinforcements are operational.

5 **Q. What do you conclude from these new planned reinforcements of the Rochester**
6 **transmission system?**

7 A. The Applicants have declared that the time frame of concern regarding the need for
8 the 345 kV lines is the year 2020. Rochester will likely have a reliable transmission
9 system until at least 2018 and likely longer than that if load management and
10 conservation programs are aggressively pursued in the Rochester area. There is now no
11 need for the new 345 kV line as proposed here for Rochester community reliability
12 support purposes.

13 **Q. What if the 2018 year forecast of reliability benefit to the scheduled 161 kV**
14 **system upgrades turns out to be correct?**

15 A. Even if this forecast of reliability support benefits is assumed to be true there are
16 other system reinforcements available that would be more cost effective than the
17 proposed 345 kV line.

18 **Q. Can you be more specific?**

19 A. Given that rapid technological advances are now occurring in the area of optimizing
20 control of distributed generation and demand side resources, these types of system
21 efficiency enhancement and peak load management tools will likely be well developed
22 within the ten year time frame before the problems occur.

1 Also, in response to NAWO & ILSR information request #18, the option of just
2 building the new North Rochester 345/161 kV substation and the two proposed new 161
3 kV lines also provides increased additional load support to the Rochester area.
4 According to the response to NAWO & ILSR IR #18, the addition of just these facilities
5 by themselves raises the critical load level in the Rochester area to 620 MW. See Exhibit
6 #4 attached. The cost of this option as described in Appendix A-2 is \$10.8 million for the
7 161 kV lines (p. 143) and \$6.8 Million (p.148) for the 345 kV substation. This \$17.6
8 million investment buys additional reliable load service, well beyond the 2020 time
9 frame.

10 ***B. La Crosse Area***

11 **Q. Please outline your concerns about the stated need for reliability support for the**
12 **La Crosse area.**

13 A. For the need assessment transmission studies that analyzed the La Crosse/Winona
14 region, Applicants have here again used forecasts for load growth for the La
15 Crosse/Winona area that predate the passage of the 2007 Minnesota conservation law.
16 While load in La Crosse is not a target for application of Minnesota law, Winona load
17 forecasts will be impacted. The original La Crosse 161 kV Load Serving Study, found on
18 page 64 of Appendix A-2, was completed in 2005, about three years ago. The study
19 work was performed on a 2003 MISO Model issued in January 2003 that simulated a
20 2009 model year. (See page 67 of App. A-2). In responses to the supplemental response
21 to information request #16 from NAWO & ILSR (See Exhibit #6 attached) it became
22 obvious that numerous system upgrades have been implemented in the La Crosse area

1 that were not in the initial modeling work. The Applicants responded to the request
2 using a different updated model, the 2011 Summer Peak from the 2006 MAPP Series.
3 The response to the information request contains a list of seven major system and La
4 Crosse area upgrades that were not in the original study model. (See Exhibit #5
5 attached). The supplemental response shows revised critical load levels under worst case
6 planning criteria conditions, a NERC Category C contingency. The impact of these
7 seven new upgrades significantly changes the need for local reliability support in the La
8 Crosse area from that determined in the initial study work.

9 **Q. What are your concerns about the results of the analysis provided in the**
10 **response using the newer system models?**

11 A. Part of my concern about the proposed 345 kV solution to the alleged La Crosse area
12 problems is that the 345 kV line stops in Lacrosse. The Applicants have made it clear in
13 their response that they do not intend to build any of the eastbound 345 kV lines out of La
14 Crosse that were a part of the regional analysis done in Appendix A-2. When a radial
15 345 kV line is proposed to terminate in a lower voltage 230 kV system for load support, a
16 natural engineering concern is how the La Crosse load will be served when the 345 kV
17 line is out of service. The response to IR #16 provides critical load level information in a
18 scenario where the proposed 345 kV line is out of service and a second system element
19 outage also takes place. This N-2 contingency is roughly analogous to a scenario where
20 the line is not built and an N-1 contingency occurs. The only difference is there are some
21 lower voltage facilities added to support the 345 kV line that would otherwise not be in
22 the model.

1 The IR response shows that in the event of a combined outage of the John P.
2 Madgett (“JPM”) generator and an outage of the North-Rochester – North La Crosse 345
3 kV line, the capability of the electrical system was 800 MW.

4 Also, in the event of a combined outage of the Genoa 3 generator and the North
5 Rochester – North La Crosse 345 kV line, the capability of the electrical system was 700
6 MW. If a new transformer were added, the critical load level in this scenario reached 750
7 MW.

8 These scenarios, roughly equivalent to N-1 contingencies without the proposed
9 line, can be compared to the N-1 critical load level of 470 MW shown in Figure 4-8 of
10 the Application. Both of these new modeling N-1 critical load levels are significantly
11 above the 602 MW of expected load growth in 2020 for the La Crosse/Winona area.

12 **Q. What do you conclude from this observation?**

13 A. It appears as if the actively occurring system upgrades contained in the modeling, and
14 the underlying facilities added as part of the proposed project, by themselves, have
15 provided enough additional local support to provide reliable service to the area through
16 the 2020 time frame. Additional detailed modeling work would answer this conclusion
17 more fully. They have not shown that the proposed 345 kV line to La Crosse is needed
18 for community reliability load serving purposes. Instead, the alternative of adding just
19 the 161 kV system upgrades, which appear to be those shown on p. 144 of Appendix A-2
20 for a cost of \$32 million, may be a cost effective solution to the 2020 time frame load
21 serving issues.

1 ***C. Fargo Area***

2 **Q. Please outline your concerns about the stated need for reliability support for the**
3 **Fargo area.**

4 A. The reliability analysis supporting the claimed need for reliability enhancements to
5 the Fargo North Dakota area are contained in Appendix A-3. Like the Rochester Study
6 the load growth forecasts used in the analysis were developed prior to the passage of the
7 2007 conservation laws, so the local area forecasts used in the study overstate load
8 growth compared to compliance with the new law. The analysis in this Red River
9 Valley/Northwest Minnesota Load Serving Transmission Study is divided into a
10 discussion of reliability issues in the northern portion and the southern portions of the
11 Red River Valley region. The analysis of the value of alternatives considered is different
12 for the two regions and also depends on the alternative considered. The two major
13 transmission alternatives examined include the 65 mile Boswell to Bemidji 230 kV line
14 and the 250 mile Fargo to St. Cloud 345 kV line. If you unbundle these two regions in
15 terms of analyzing the benefits of the two options you find that the Bemidji to Boswell
16 230 kV line essentially fixes the problems identified for the northern region. If you
17 assume that the 230 kV line is built and then look at the residual reliability needs in the
18 southern region different alternatives, other than the 345 kV line become evident.

19 **Q. Explain how you conclude that the Bemidji – Boswell 230 kV line solves the**
20 **northern region reliability issues.**

21 A. Appendix A-3, section 5.0.4, identifies two important north zone needs, the need for
22 another source into the Bemidji sub zone of the northern area and the need for another
23 source into the north zone as a whole. Regarding this 230 kV alternative, this section

1 concludes “The Bemidji-Boswell 230 kV line is the most effective transmission option
2 studied with respect to satisfying these two needs.” Section 5.0.3 states that, for the
3 combined north and south study zones, the 230 kV option provides 300 MW of load
4 growth improvements considering N-2 conditions. The 345 kV option only provides an
5 incremental 100 MW more performance in this regard, for a lot more money. Lastly, the
6 conclusions section (7.0) states that “the Fargo-St. Cloud 345 kV transmission option is
7 not particularly effective at providing load serving support to the northern RRV sub area
8 because the Maple River-Winger 230 kV outage isolates this new transmission source
9 from the northern RV load center.” So only the 230 kV Bemidji - Boswell option, of
10 those presented in the report effectively resolves these northern region issues.

11 **Q. What problems remain to be analyzed if one assumes the 230 kV line is built?**

12 A. Figure 5.3A in appendix A-3 identifies the load benefit area from the 230 kV line,
13 primarily the northern area. The Application, Chapter 4, specifically identifies
14 Alexandria as a southern zone reliability concern load center. Additionally, the St. Cloud
15 area is identified.

16 ***D. Alexandria Area***

17 **Q. Please outline your concerns about the stated need for reliability support for the**
18 **Alexandria area.**

19 A. The application indicates a critical load level for the Alexandria area at 171 MW of
20 load without local generation support (See Fig 4-16). In response to NAWO & ILSR
21 information request #13 (See Exhibit #5 attached) the Applicants have stated that if the
22 Bemidji to Boswell 230 kV line is constructed the critical load level in the Alexandria

1 area rises to 190 MW. Using the Applicants forecast they conclude in their response that
2 this would occur in about 2017 for the Alexandria area. The incremental load growth
3 between 190 MW and the year 2020 shown in Figure 4-16 is about 8 MW. This
4 corresponds to an additional growth above the 190 MW critical load level of only 4.2 %.
5 Given that the Applicants have not applied the conservation requirements of the 2007
6 conservation laws to the local area forecast used in the Appendix A-3 analysis, this
7 additional 8 MW is likely in the error range of their load growth forecast. Since the
8 Alexandria area is a winter peaking locality, peak demand load management programs
9 such as dual fuel heating systems targeted to the area beginning now should eliminate 8
10 MW of peak load by 2017.

11 **Q. What are your conclusions about the Alexandria area need for reliability**
12 **support?**

13 A. If the Bemidji to Boswell 230 kV line is built to enhance the northern Red River
14 Valley region reliability issues, there likely will not be a reliability problem to solve in
15 the Alexandria area in the 2020 timeframe of concern as outlined in the Application. The
16 Applicants have not shown that the Fargo to Twin Cities 345 kV line is the most cost
17 effective way to manage 2020 year load growth issues for the Alexandria area.

18 ***E. St. Cloud Area***

19 **Q. Please outline your concerns about stated need for reliability support for the St.**
20 **Cloud area.**

21 A. St. Cloud, like Rochester has a fairly well defined existing system deficiency
22 requiring system reinforcements or a substantial reduction in local load. The discussion

1 in the Application, Ch 4.1.6 identifies reliability issues related to the outage of the Benton
2 County 115 kV double circuit line, and the outage of the Crossroads – Granite City 115
3 kV line. The Applicants propose to tap the Fargo to Monticello 345 kV line at a point at
4 or near the Sauk River substation or the West St. Cloud substation to reinforce the local
5 St. Cloud power system. My concern is that the complete story regarding the solution to
6 the St. Cloud reliability is not easily gathered from the discussion in section 4.1.6 or the
7 Appendix A-3 transmission Study.

8 **Q. What part of the story needs clarification?**

9 A. The discussion in section 4.1.6 regarding the outage of the Benton County double
10 circuit 115 kV line includes a discussion of the operating procedure that trips the 115 kV
11 line going to the St. Regis substation at the same time the double circuit line is tripped.
12 The reason for this is because of the physical arrangement of the St. Regis line “between
13 the line terminals for the Benton County – Granite City double circuit 115 kV line.” The
14 point that needs clarifying is that the Applicants’ proposed solution likely will not solve
15 the problem of the need to trip the St. Regis substation when the double circuit 115 kV
16 line is tripped.

17 **Q. What other issues need to be clarified?**

18 A. The discussion of the schedule for the line contained in section 4.1.7 indicates that the
19 Applicants would construct the Monticello to St. Cloud portion of the proposed 345 kV
20 line as soon as possible to bring “additional transmission capacity to the area where the
21 need is most immediate.” The point that needs clarification is how long this short
22 extension of a 345 kV line would serve as a solution by itself to the local load serving
23 problems in the St. Cloud region.

1 **Q. How can you clarify the value in building just this segment as a solution to**
2 **reliability issues in the area?**

3 A. The transmission study contained in Appendix A-3 did not directly examine this
4 option. However there is some information in the report that sheds light on the question.
5 One way to examine the value of this 345 kV radial option is to look for information
6 about the performance of the longer proposed 345 kV line to Fargo under scenarios
7 where the portion of the proposed line from St. Cloud to Alexandria would be out of
8 service. The examination of the termination point options for the Fargo line in the St.
9 Cloud 345 kV Sensitivity found in Appendix A of the Red River Valley/Northwest
10 Minnesota Study offered in Application section A-3 contains some information in this
11 regard.

12 **Q. How is this discussion helpful?**

13 A. The discussion in this section shows that by adding double transformers in various
14 locations the amount of support to the local area provided by the Applicants' proposed
15 project can be up to 343 MW of incremental St. Cloud load serving capability.

16 Since the need for additional support to St. Cloud even in the year 2020 is identified to be
17 an incremental 230 MW as shown in Figure 4-19 of the Application, the Applicants'
18 solution provides significant margin above 230 MW. What can be gleaned from the data
19 in this analysis regarding the radial 345 kV option I described above is contained in the
20 discussion of the specific double contingency limitation that results in the 343 MW limit.

21 On page 3 of Appendix A to Section A-3 it states "The Monticello option is limited to
22 343 MW by the outage of the Sherco-Monticello 345 kV line in conjunction with outage
23 of one Benton Co 345/230 kV transformer." What is significant about this is that the

1 outage of the section of the proposed 345 kV line between St Cloud and Alexandria is not
2 part of this system limiting double contingency. This means that in the radial scenario,
3 for an N-1 outage analysis, equivalent to simulating the outage of the Alexandria to St.
4 Cloud section of the 345 kV line and any other contingency event will have incremental
5 load serving limit higher than 343 MW. This is significantly above the existing system's
6 N-1 critical load level of 228 MW as identified in the Application in Figure 4-19.

7 **Q. What do you conclude from this observation?**

8 A. It appears that the St. Cloud area N-1 reliability issues can be resolved beyond the year
9 2020 with the radial 345 kV option from Monticello and the portion of the 345 kV line
10 west of St Cloud is not needed to resolve this level of reliability of service to the St Cloud
11 area.

12 **Q. Are there other options for resolving the St. Cloud reliability issues?**

13 A. Yes, even though the existing MW at risk level is stated to be 140-175 MW, a
14 combination of peak demand management and strategic distributed generation
15 deployment could be targeted to the St. Cloud area and probably Rochester as well, using
16 "Smart Grid" technologies. I will speak to this opportunity later in my testimony.

17
18 **VI GREENHOUSE GAS EMISSION IMPACTS**

19 ***A. Climate Change Statute Requirements***

20 **Q. Why is the issue of greenhouse gas emissions relevant to this proceeding?**

21 A. There is a reference in Minn. Stat. § 216B.243, subd 3 (5) that requires consideration
22 of the benefits of this facility, including its uses to protect or enhance environmental

1 quality. It follows that, to the extent a project degrades environmental quality, that
2 should also be a factor in the decision to be made here.

3 The Minnesota Environmental Policy Act, found in Minn. Stat. § 116D.02,
4 Subd. 2(16), places a responsibility on state agencies to “reduce the deleterious
5 impact on air and water quality from all sources.” Minnesota Environmental Law, as
6 stated in Minn. Stat. § 116D.04, Subd. 6, provides that no state action which is likely
7 to cause impairment of the environment shall be allowed if there is a feasible and
8 prudent alternative.

9 There is also statute language in the newly created Minn. Stat. § 216H
10 regarding greenhouse gas reduction policy that also must be considered in this
11 proceeding.

12 **Q. How does the 216B.243 requirement regarding enhancing environmental**
13 **quality apply here?**

14 A. As I have demonstrated above, the Applicants have failed to show that there is
15 any specific renewable energy transport benefit for at least two of the three 345 kV
16 lines they propose. Since the power that would flow on these lines is quite likely to
17 be non-renewable sourced energy, in fact the location and size of the generators on
18 the list of generation sources modeled in the Analysis in Appendix A-1, used to
19 justify the need for these projects, likely shows fossil fueled sources now in
20 interconnection queues. To the extent that these lines enable those proposed
21 generation sources there would be an adverse effect on environmental quality, thus
22 an environmental cost, rather than a benefit is associated with operation of these
23 proposed facilities.

1 **Q. In what ways are the new Chapter 216H laws applicable here?**

2 A. First, per Minn. Stat. 216H.02, subd 1, it is the goal of the state to reduce statewide
3 greenhouse gas emissions across all sectors producing those emissions to a level at least
4 15 percent below 2005 levels by 2015, to a level at least 30 percent below 2005 levels by
5 2025, and to a level at least 80 percent below 2005 levels by 2050.

6 Second, there is a specific directive in Minn. Stat. 216H.03 subd 3, that on and
7 after August 1, 2009, no person shall “construct within the state a new large energy
8 facility that would contribute to statewide power sector carbon dioxide emissions” and no
9 person shall “import or commit to import from outside the state power from a new large
10 energy facility that would contribute to statewide power sector carbon dioxide emissions;
11 or enter into a new long-term power purchase agreement that would increase statewide
12 power sector carbon dioxide emissions.”

13 **Q. How do these requirements apply here?**

14 A. Enabling the importation of fossil fueled power from outside the state by construction
15 of the proposed facilities would contribute to statewide power sector carbon dioxide
16 emissions. There is also evidence available in this record that the carbon dioxide
17 contribution from the mere construction of these transmission lines would significantly
18 contribute to an increase in statewide power sector emissions.

19 ***B. Impacts from Power Line Construction***

20 **Q. What kind of evidence is available regarding construction impacts?**

21 A. There is evidence in this record already, in the form of Environmental Report Scoping
22 comments from the Sierra Club, that indicate that transmission line construction CO2
23 impacts can be greater than any operational CO2 benefits that may accrue over time. The

1 Sierra Club cites an Environmental Review document developed by California Public
2 Utilities Commission and U.S. Bureau of Land Management in a proceeding regarding
3 the Sunrise Powerlink transmission project. This project consists of 91 miles of 500 kV
4 single circuit overhead line, a new substation, and a 59 mile segment at 230 kV line
5 intended to help deliver power from a solar, a geothermal, and a wind facility. The
6 California PUC Draft Environmental Impact Report concluded:

7 “Assuming long-term avoided GHG emissions of 1,650 tons of CO2
8 annually, based on the CAISO forecast for 2015, during every year of
9 transmission line operation would provide 66,000 tons over 40 years. This
10 quantity of avoided GHG emissions would not fully offset the two years of
11 GHG emission increases caused by construction (approximately 109,000
12 tons). Because total construction GHG emissions exceed the GHG
13 reductions achieved due to avoided power plant emissions over 40 years
14 of transmission line operation, the Proposed Project would cause an
15 overall net increase in GHG emissions and a significant climate change
16 impact.”²
17

18 Since these lines similar in class to the lines proposed here, utilizing similar right of way
19 requirements and construction techniques the construction CO2 impacts on a per mile
20 basis should be similar.

21 ***C. Impacts from Enabled Coal Generation***

22 **Q. How will these lines enable import of fossil fuel from other states?**

23 A. At a minimum the Fargo line could enable importation of at least 350 MW of fossil
24 fueled, likely coal fired energy from North Dakota. The transmission line Certificate of
25 Need proceeding regarding Big Stone II transmission lines contains voluminous data on
26 CO2 emission levels from coal plants. This environmental impact and the CO2 impact

² See Sunrise Powerlink DEIR, January 2008:
<http://www.cpuc.ca.gov/Environment/info/aspn/sunrise/deir/D11%20Air%20Quality.pdf>, page D.11-55.

1 from construction should be a part of the Environmental Report developed for this
2 proceeding.

3 4 **VII. ALTERNATIVES ANALYSIS**

5 **Q. What is your assessment of alternatives provided in the Application and in the**
6 **Environmental Report?**

7 A. Both efforts have failed in the first instance to make any showing in this regard
8 because they have failed to offer any comprehensive alternative that would meet the
9 combined needs that the proposed project is intended to satisfy. Nowhere in Chapter 7 of
10 the application, the Alternatives Chapter, do the Applicants develop any of the
11 information required by Minn. Rule 7849.0260(C) that would enable a reasoned
12 comparison of cost and performance data of any alternative to the project's cost and
13 performance. Similarly the Environmental Report fails to develop any comprehensive
14 alternative, not even one based on considering the possibility of a combination of various
15 strategies.

16 **Q. What is your assessment of the need for the analysis of Alternatives at this time?**

17 A. As I just mentioned, a complete and comprehensive alternative would address all of
18 the three categories of need identified by the Applicants, 1) Minnesota area system wide
19 needs for future load growth, 2) Community reliability needs for the specific
20 communities identified in the Application, and 3) Renewables development support.
21 Additionally, since there are three major 345 kV lines being proposed for three different
22 geographic regions of the state, the alternatives should be focused on satisfying the needs
23 on a line by line basis. The Applicants have predominantly examined finding only a set

1 of transmission solutions to the individual problems they have alleged. A one size fits all
2 transmission only approach to alternatives isn't a realistic way of solving problems that
3 occur 20 years out.

4 However, as I have just shown in my testimony the three categories of need as
5 stated in the Application to do not hold up to the evidence available given the new state
6 renewable energy standard and conservation law requirements. The actual need for
7 system enhancements is substantially different for all three categories of need from those
8 alleged in the Application. Since the assumptions in the Application on which the need
9 for the proposed project are based are shown to be in error, the Applicants have failed in
10 the first instance to demonstrate the need for their projects. It is technically not necessary
11 to reach the examination of alternatives in this proceeding unless there is a verifiable
12 demonstration of need around which alternatives can be constructed and examined.

13 ***A. System Wide Needs***

14 **Q. Please explain your position regarding the evidence for or against the claimed**
15 **need to Support Minnesota area load growth.**

16 A. In the case of the claimed need for Minnesota area system wide load growth support,
17 the projections of future load growth used by the Applicants for the year 2020, between
18 4500 and 6300 MW of load growth has been shown to be obsolete and exaggerated given
19 the latest forecasts being used in Integrated Resource plans. The actual projections of
20 future Minnesota area load growth now offered by the Applicants fall into the median to
21 high forecast range of 3,919- 4,789 MW. A new low load growth forecast, which is just
22 as probable as the high growth scenario, was not even offered by the Applicants. The
23 transmission study offered in support of the proposed lines didn't even examine the

1 forecast range that is used by Minnesota regulators to determine resource acquisition
2 requirements. The claimed need for these facilities for Minnesota area system wide load
3 growth fails to pass the burden of proof hurdle since the applicability of the proposed
4 transmission project has not been studied for suitability to the load growth projections
5 now offered by the Applicants.

6 **Q. Couldn't we just assume we would "grow into" these new facilities over time?**

7 A. The Applicants have claimed a need that needs to be satisfied in a 2020 time frame.
8 The question of what is the least cost option to meet the 2020 year system load growth
9 need has not been adequately analyzed by the Applicants. Beyond this 15 year time
10 frame the industry cannot create believable system models to even test various options to
11 meet any claimed need. It is important to recognize that the Applicants have created this
12 set of proposed lines using an "old paradigm strategy" set of study assumptions that is no
13 longer a likely set of assumptions about the future to plan around. A realistic approach
14 would acknowledge Minnesota's GHG reduction goals and how that policy will drive the
15 state towards dramatic absolute reductions in electricity consumption or towards an even
16 more dramatic switch to renewable energy technologies. The applicants have not
17 demonstrated that their proposed lines fit well in to meeting these future requirements.

18 ***Power System Design Strategies***

19 **Q. What do you mean by an old paradigm strategy?**

20 A. Earlier in my testimony I referenced the fact that the Vision Study offered in
21 Appendix A-1 of the Application had presumed a set of generation that would be
22 developed that was almost exclusively of the large scale variety, sized in the hundreds of
23 megawatt range. The locations selected to be analyzed included many locations in the

1 Dakotas, Manitoba, Iowa, and Wisconsin. Even the wind plants were modeled as single
2 injections of plants with 100 – 400 MW units. This bias in the assumptions used in
3 planning, reflective of the way power plants were sized and located in the past, no longer
4 is indicative of where the technologic innovation in generation technology economics,
5 and public policy are driving generation patterns now and on into the future.

6 **Q. What would be a new paradigm then?**

7 Power generation technologies are evolving into smaller plant sizes, and new technology
8 types that can be located close to the point of end use of the energy. Open Access
9 policies at the federal level and the passage of Community Based Energy Development
10 laws in Minnesota have enabled local communities to capture the economic development
11 benefits associated with owning these types of generation resources. The Minnesota
12 legislature in 2007, recognizing this trend, required utilities to study how to integrate
13 1200 MW of Dispersed Generation into Minnesota's power grid. The report on the first
14 phase of that study, integrating 600 MW, is due to be released in just a few weeks on
15 June 16th. The results of that study will further inform the value of these types of
16 resources. At this time, I am limited in what I can say about the study results because of
17 signed confidentiality agreements for those advising the process.

18 Additionally, new technology options utilizing Internet based communication
19 strategies, and new legal requirements to implement these technologies to control demand
20 on the power system will significantly affect the need to plan for what historically been
21 uncontrollable customer system peak demands. This is especially relevant to
22 transmission planning since the transmission system generally must be sized to service
23 the maximum peak power flow event. Since transmission planners have to plan out to a

1 fifteen year time frame, the scenarios they create of the power system as they expect it to
2 be in the future must consider these important trends in technology innovation in their
3 planning assumptions. The study work presented by the Applicants in this proceeding
4 has not done so. The future trend in tools that are and will be available to transmission
5 planner's impact both what assumptions should go into the future models and what
6 options can be used for mitigation strategies.

7 ***Dispersed Generation Studies***

8 **Q. How has the concept of Dispersed Generation been integrated into transmission**
9 **planning to date?**

10 A. Except for responding to Interconnection Queue requests, modeling for integration of
11 dispersed technologies has generally not been a part of transmission planning
12 assumptions. One exception has been right here in Minnesota when, the Minnesota
13 utilities, as a result of negotiations with NAWO, undertook a study of integrating
14 Dispersed Generation into the West Central transmission planning zone in the state. This
15 West Central CBED Study has been made part of this record as part of direct testimony
16 of Tim Rogelstad. That study showed that it is possible to integrate 1400 MW of
17 dispersed resources into the existing grid for less than \$100 million in system
18 improvements. The improvements were upgrades of existing facilities that would not
19 require Certificate of Need process to implement.

20 **Q. What did that study show in regard to transmission planning?**

21 A. The conclusion section of the CBED Study Report states "this study has pointed out
22 that future generation scenarios based on dispersed resources can have an impact on the
23 type of system reinforcements that may be necessary to accommodate these smaller

1 dispersed resources.” This statement verifies that if you include dispersed generation as
2 part of your transmission planning assumptions, you will discover they will impact the
3 type of system reinforcements that may be necessary. If smaller dispersed generators
4 become the predominant generation type in the ten to fifteen year planning horizon the
5 nature of transmission reinforcements that are necessary will likely be significantly
6 different than the ones that the Visioning Study offered in Appendix A-1 produced that
7 used an old paradigm future of large scale facilities located far from load.

8 **Q. What happened as a result of the West Central CBED Study?**

9 A. The showing in the study that during summer on peak time that up to 1400 MW of
10 dispersed generation could be used to offset expensive gas peaking generation in
11 Minnesota for the relatively small investment of about \$100 million in transmission
12 enhancements led to passage of the legislation in the Next Generation Energy Act of
13 2007 requiring further exploration of Dispersed Generation strategies applied throughout
14 the state.

15 **Q. Are there other attributes of Dispersed Generation resources that need to be**
16 **recognized?**

17 A. Since smaller generators generally can be installed on lower voltage facilities they
18 offer the potential for their interconnection to be managed under state authority rather
19 than having to enter the FERC jurisdiction MISO Queue. The MISO Queue is a well
20 known barrier to interconnection because of the long lead times to get through the
21 process. The recent Minnesota State legislature CBED Advisory Taskforce committee
22 investigated this interconnection jurisdiction process and recommended that “The work
23 group noted the MISO queue process is overwhelmed with a backlog of generator

1 interconnection requests and recommended the state should exercise its authority to
2 implement state interconnections as a tool to facilitate C-BED project installation.”³
3 These smaller resources could be integrated into the system through an expedited state
4 review process.

5 ***B. Community Reliability***

6 **Q. Please explain your position regarding the evidence for or against the claimed**
7 **need for Community Reliability Support.**

8 A. For the claimed need category of community reliability support, I have examined
9 each of the local communities identified in the Application intended to be served by
10 either the Fargo to Twin Cities 345 kV line or the Twin Cities to La Crosse 345 kV line
11 and found that given that the CAPX utilities are applying for a permit to build the
12 Bemidji to Boswell 230 kV line, and because significant system reinforcements are either
13 in service or committed to be built for Rochester and La Crosse, and because a radial 345
14 kV option is available for St. Cloud, the need for these two 345 kV lines for community
15 reliability support does not hold up under scrutiny. In addition to these transmission
16 related problem mitigation strategies there are other options such as the “Smart Grid” that
17 could be applied to the identified issues.

18 ***The Smart Grid***

19 **Q. What do you mean by the term Smart Grid?**

³ See: Legislative Electric Energy Task Force Legislative Coordinating Commission Minnesota Legislature
Community-Based Energy Development (C-BED) Advisory Task Force Report, March 28, 2008.

1 A. The Smart Grid term is one of several labels that are used to refer to using
2 communication and control technology to add intelligence and efficiency to the power
3 transmission and distribution system. The technology is used in a real time mode to
4 monitor and manage power flow on the grid through interactions with storage systems,
5 and both demand and supply side distributed resources. Technology is also provided to
6 electricity customers that allow them to actively participate in lowering their energy
7 consumption and lessening of their impact the rest of the grid system.

8 **Q. Are utilities using this technology now?**

9 A. The concept is being implemented across the country in various degrees and
10 manifestations. One of the Applicants, Xcel Energy has committed to install a
11 comprehensive Smart Grid system in the City of Boulder Colorado. They have published
12 a Smart Grid White Paper to explain the technology. I have attached a copy to my
13 testimony as Exhibit #7.

14 **Q. Do you have more detail on the Xcel Energy Boulder Project?**

15 A. The Smart Grid White Paper indicates that the Boulder Smart Grid project is phase II
16 of a three phase project that would lead in the third phase to an Xcel wide deployment of
17 proven technologies after the results of the “Smart Grid City” Boulder project results are
18 available.

19 **Q. What system benefits are available using this technology that are relevant to**
20 **this proceeding?**

21 A. One of the benefits of the Smart Grid listed in the White Paper are expected deferral
22 of capital expenditures for transmission projects based on improved load estimates and
23 reduction in peak load from enhanced demand management. The Community Reliability

1 support need identified by the Applicant is caused by peak demands on the system. This
2 new tool can therefore be utilized as a peak demand management device to mitigate these
3 transmission bottlenecks.

4 **Q. What are the cost and timing parameters of the Boulder project?**

5 A. Xcel indicates in the White paper that total investment among the project partners will
6 be about \$100 Million. In a supplemental response to NAWO & ILSR information
7 request #15, copy attached as Exhibit #8, Xcel indicates that the system is being built this
8 year and will be fully operational by the end of 2009. This is an extremely short lead
9 time to install a system that has so much potential for a wide variety of system and
10 customer benefits. One can easily expect that costs will come down dramatically as Xcel
11 Energy and other utilities gain experience in implementing Boulder's Smart Grid.

12 **Q. In their response to your IR # 15, Xcel indicates that this Smart Grid concept is**
13 **just developing, and very little exists in the way of quantifiable results or judgments**
14 **about the project. Why do you think this Smart Grid concept has value to this**
15 **proceeding?**

16 A. First, this technology is more than a concept; previous applications of this strategy
17 have shown significant positive results. In particular I will point to a test of the
18 technology performed through Pacific Northwest National Laboratories (PNL). Their
19 "GridWise" Demonstration Project has a number of reports available. A "Fast Facts"
20 paper on the project from PNL is attached as Exhibit #9. PNL has come to some more
21 definitive conclusions about the usefulness of this concept than offered by Xcel in their
22 IR response. In particular in the paper I mentioned, PNL concludes "The project
23 demonstrated that utility-dispatched demand response can alleviate the need to build

1 expensive new infrastructure to address constraints on the distribution or transmission
2 system during times of peak demand.” Not only do they offer this general statement, but
3 their study demonstrated that “an Internet-based network coordinating demand response
4 can save consumers money on power, and reduce peak load on the grid by 15 percent
5 over the course of one year.” When the technology is used in combination with
6 distributed generation they found “A combination of demand response and distributed
7 generation reduced peak distribution loads by 50 percent for days.” The power of this
8 technology has been demonstrated already, the investment of \$100 million being made by
9 Xcel energy and its partners in Boulder is an investment whose magnitude is such that the
10 parties making such an investment won’t do it unless they are relatively certain of its
11 outcome.

12 **Q. What do you see as the long term potential impact of this technology for**
13 **transmission planners?**

14 A. The demonstration of a 50 % reduction in peak load demand for days at a time by
15 PNL when supply and demand side resources are simultaneously managed collectively
16 could dramatically change the shape of load duration curves for the grid system as a
17 whole. This would increase overall utilization of the existing grid system, getting more
18 energy delivered from our sunken investment in infrastructure, and greatly impacting the
19 timing and nature of new infrastructure enhancements. Xcel Energy’s CEO Dick Kelly
20 seems to concur with the potential of the Smart Grid. He has stated that the Boulder

1 Smart Grid technology "is a forward-thinking project that will transform the way we do
2 business."⁴

3 ***C. Renewables Support***

4 **Q. Please explain your position regarding the evidence for or against the claimed**
5 **need for Renewables Support.**

6 A. The third category of claimed need, regarding providing renewables support, also has
7 problems. The Applicants have not tried to make any showing that the Twin Cities –
8 Rochester – La Crosse 345 kV line will help Minnesota meet its renewable energy goals.
9 Regarding the Fargo – Twin Cities 345 kV line the Applicants have offered that 350 MW
10 of increased generation outlet is evidence of this line having renewables support
11 attributes. They offer no guarantee that the 350 MW made available will not be scooped
12 up by fossil fueled generation resources. Regarding the Brookings – Twin Cities 345 kV
13 line the Applicants have made a showing that 700 MW of outlet capacity from the
14 Buffalo Ridge area will be created by this system addition, evidence offered that it will be
15 utilized by renewables is the magnitude of wind generation now in the MISO queue for
16 this area. However, they have made no showing that building this \$600 + million dollar
17 line is either the least cost next step to reduce the MW of need for renewables calculated
18 in the Gap analysis by 700 MW or a necessary prerequisite to achieving the Minnesota
19 RES goals.

⁴ See Press Release provided to NAWO & ILSR as part of response to IR # 15.

1 ***Focus on Delivered Cost of Energy***

2 **Q. Isn't it obvious that the high wind resource region in southwest Minnesota and**
3 **eastern North and South Dakota would be the least cost next step to achieving the**
4 **Minnesota RES goal?**

5 A. No. From a societal policy perspective what is the determinant of what would be the
6 least cost way to get 700 MW of renewables for Minnesota goals would be to look at the
7 total cost of delivering the energy to Minnesota load, not the cost of power out where it is
8 injected into the grid should be the proper comparison between alternatives. A
9 comparison between the cost of energy from 700 MW on the Buffalo Ridge, including
10 the \$600 million cost of building the Brookings – Twin Cities 345 kV line, with the
11 delivered cost of energy from another area including the infrastructure necessary to
12 deliver energy from that location would be the way to examine alternative strategies to
13 meet the RES Goals.

14 **Q. Are the Applicants doing this kind of analysis?**

15 A. The utilities responsible for doing RES related transmission planning have initiated a
16 “G & T Study” to examine this issue. Information about results is not yet available from
17 this effort. Proper decisions about the nature of least cost new transmission infrastructure
18 investments for renewables cannot be made without this type of data.

19 ***D. Ratepayer Economic Impact***

20 **Q. Why are socio-economic issues relevant to this proceeding?**

21 A. There are provisions in both the Certificate of Need statutes and in Minnesota
22 Environmental Policy Act that requires an evaluation of the direct and indirect
23 economics of the proposed project and the alternatives.

1 **Q. What do the Certificate of Need Laws require?**

2 A. Under Minn. Stat. § 216B.243, subd 3, “the applicant must show that demand for
3 electricity cannot be met more cost effectively through energy conservation and
4 load-management measures and unless the applicant has otherwise justified its need.”
5 Even more detail regarding this issue is developed in Minn. Rules Ch. 7849.120 subp
6 B(3), which states “a certificate cannot be granted unless a more reasonable and
7 prudent alternative to the proposed facility has not been demonstrated by a
8 preponderance of the evidence on the record, considering: the effects of the
9 proposed facility upon the natural and socioeconomic environments compared to
10 the effects of reasonable alternatives.” Both of these legal requirements force an
11 examination of cost issues related to the project and its alternatives.

12 **Q. What does the Minnesota Environmental Policy Act require?**

13 A. In Minn. Stat. § 116D.04, subd 6, it requires that:

14 “No state action significantly affecting the quality of the environment
15 shall be allowed, nor shall any permit for natural resources
16 management and development be granted, where such action or permit
17 has caused or is likely to cause pollution, impairment, or destruction of
18 the air, water, land or other natural resources located within the state,
19 so long as there is a feasible and prudent alternative consistent with the
20 reasonable requirements of the public health, safety, and welfare and
21 the state's paramount concern for the protection of its air, water, land
22 and other natural resources from pollution, impairment, or destruction.
23 Economic considerations alone shall not justify such conduct.”

24 That statement bounds the value of consideration of economic parameters and shows
25 that environmental concerns override economic considerations.

26 **Q. What other socioeconomic factors are relevant here?**

1 A. The state has a policy that encourages local economic development through the
2 deployment of Community Based Energy Development projects as outlined in Minn.
3 Stat. § 216B. 1612. These renewable energy project ownership structures are to be
4 given priority consideration for contracts by utilities that have an obligation under
5 the Renewable Energy Standard law.

6 ***Community Based Energy Development***

7 **Q. How do these CBED socioeconomics fit into the decision to be made here?**

8 A. Since part of the claimed need is for renewables development, a comparison of the
9 Applicants' proposed project's renewable attributes with other renewable development
10 alternatives, such as Dispersed CBED Generation development throughout the state
11 should be considered when evaluating whether a Certificate of Need should be granted.

12 ***Cost allocation and Ownership***

13 **Q. How do ratepayers fit into this analysis?**

14 A. Rate payers are part of the socioeconomic environment required to be evaluated
15 under Minn. Rules Ch. 7849.

16 **Q. How will the proposed projects costs be allocated to Minnesota ratepayers?**

17 A. The Applicants, after being ordered to do so by the commission, provided information
18 in Appendix D-5 of the Application. This section provides part of the picture regarding
19 ratepayer impacts.

20 **Q. Why is this only a part of the picture?**

21 A. The data in Appendix D-5 show how much money MISO will collect from the
22 various Minnesota loads using the lines (Table 5) to get the money needed to pay for the
23 lines. The money that MISO collects to pay for the lines will be distributed to the

1 eventual owners of the proposed facilities if they are built. The Applicants have failed to
2 make any demonstration regarding who will actually own what part of these lines so we
3 cannot know for sure who will get this money. The Applicants have provided a surrogate
4 example of how much money each of them would receive from owning these lines in
5 Table 2 of Appendix D-5. This Table is built upon a premise that they all commit to
6 invest at their maximum agreed upon percentages.

7 **Q. Why is the ownership question so important here?**

8 A. For the investor owned utilities, the investments these utilities make in owning these
9 lines are capital expenditures that would typically become part of a rate case proceeding.
10 The investment would become part of the rate base consideration of appropriate charges
11 to Minnesota ratepayers. For Municipal and Cooperative utilities, rate cases are not
12 before the Commission, but the costs or profits from the investment in these lines will be
13 borne 100% by the ratepayers of each entity. Any net revenues from ownership would
14 presumably help offset the costs that are charged to them by MISO under Table 5.

15 **Q. Are there other reasons why ownership is important here?**

16 A. The CAPX utilities have openly admitted that they would consider other as yet
17 unidentified third party entities to become owners of these lines. When Interstate Power
18 & Light sold its transmission assets to Interstate Transmission Company, the Minnesota
19 Commission transferred jurisdiction on a number of transmission related items to FERC.
20 If a Certificate of Need is granted in this proceeding with no proof of ownership
21 requirement attached to the Certificate as a condition, it is not clear that the Commission
22 would have any say in who ends up owning these lines. The Commission may have
23 given up future jurisdiction over these facilities without knowing it.

1 **VIII. SUMMARY AND RECOMMENDATIONS**

2 **Q. What is your overall assessment of the alleged need for these facilities?**

3 A. The Applicants claimed three categories of need do not stand up to the evidence
4 available. The need for system wide load growth support need has been grossly
5 overstated by the Applicants, to the point that recent projections of load growth
6 developed by the Applicants themselves fall outside and below the range of forecast
7 scenarios examined in the CAPX Vision Study offered in support of this claimed need.

8 The need for community reliability support has been shown to be based on
9 overstated forecasts for the local area of concerns. Even if these forecasts were accurate
10 there are other more cost effective options available for resolving all of the community
11 reliability issues identified in the Application.

12 The need for renewables support that each of the three lines is purported to offer
13 does not hold up under scrutiny. No specific identified renewable benefit is offered for
14 the Twin Cities to La Crosse 345 kV line, the Fargo to Twin Cities line’s alleged 350
15 MW of North Dakota export capacity has not been shown to be guaranteed to be used by
16 renewables, and the Brookings to Twin Cities line, while likely shown to provide
17 renewable generation outlet capability, has not been shown to be the least cost way of
18 adding 700 MW of renewables to the system to reduce the gap in achieving Minnesota’s
19 RES Goals.

20 **Q. What is your recommendation regarding what action the Commission should**
21 **take regarding the Certificate of Need permit Application?**

22 A. The Commission should determine that based on the needs identified in the
23 Application, the Applicants have not met there burden of proof to show that this proposal

- 1 is the least cost way to meet the actual need for system enhancements in each of the three
- 2 categories of claimed need. The Commission should deny the permit request.