


November 2011

**PUBLIC SERVICE COMMISSION OF WISCONSIN
WISCONSIN DEPARTMENT OF NATURAL RESOURCES**



**Alma—La Crosse
345 kV Transmission
Project Volume 1
Draft Environmental Impact Statement**

**PSCW Docket 5-CE-136
Date Issued: November 2011**

PUBLIC SERVICE COMMISSION OF WISCONSIN
WISCONSIN DEPARTMENT OF NATURAL RESOURCES

CapX2020
Alma-La Crosse
345 kV Transmission Project

Public Service Commission of Wisconsin
610 North Whitney Way
P.O. Box 7854
Madison, Wisconsin 53707-7854
Phone 608.266.5481 • Fax 608.266.3957 • TTY 608.267.1479
E-mail: pcsrcs@wisconsin.gov
Home Page: <http://www.psc.wi.gov>

Wisconsin Department of Natural Resources
101 South Webster Street
P.O. Box 7921
Madison, Wisconsin 53707-7921
Phone 608.266.0426 • Fax 608.266.5226 • TTY 608.267.6897
E-mail: cheryl.laatsch@wisconsin.gov
Home Page: <http://www.dnr.wi.gov>


This draft Environmental Impact Statement for the proposed CapX2020 Alma-La Crosse 345 kilovolt transmission line project is progress towards compliance with the Public Service Commission's requirement under Wis. Stat. § 1.11 and Wis. Admin. Code § PSC 4.30. It also is progress toward compliance with the Department of Natural Resources requirements under Wis. Admin. Code § NR 150.22.

By:



Kathleen J. Zuelsdorff
WEPA Coordinator
Public Service Commission of Wisconsin

Date:



Questions about information provided in this draft Environmental Impact Statement should be directed to:

Kenneth Rineer
(environmental)
Public Service Commission
(608) 267-1201
kenneth.rineer@wisconsin.gov

or

Udaivir Singh Sirohi
(engineering)
Public Service Commission
(608) 266-2806
udaivirsingh.sirohi@wisconsin.gov

Cheryl Laatsch
Department of Natural Resources
(608) 264-8943
cheryl.laatsch@wisconsin.gov

To the Reader

This draft environmental impact statement (EIS) fulfills part of the requirements of the Wisconsin Environmental Policy Act (WEPA), Wis. Stat. § 1.11. WEPA requires state agencies to consider environmental factors when making major decisions. The purpose of this draft EIS is to provide the decision makers, the public, and other stakeholders with an analysis of the economic, social, cultural, and environmental impacts that could result from the construction of the new power line and its associated facilities. This document has been prepared jointly by the Public Service Commission of Wisconsin (Commission or PSCW) and the Wisconsin Department of Natural Resources (WDNR).

You are encouraged to comment on this draft EIS. The state agency comment period on this draft EIS ends on December 23, 2011. Please use the PSCW docket number 5-CE-136 on all e-mail and correspondence. Written comments should be addressed to:

William Fannucchi
Docket Coordinator
Public Service Commission
P.O. Box 7854
Madison, WI 53707-7854
(608) 267-3594
[william.fannucchi@wisconsin.gov](mailto:wiliam.fannucchi@wisconsin.gov)

Specific questions on the draft EIS should be addressed to:

Kenneth Rineer
Public Service Commission
(608) 267-1201
kenneth.rineer@wisconsin.gov

Cheryl Laatsch
Department of Natural Resources
(608) 264-8943
cheryl.laatsch@wisconsin.gov

Comments received during the comment period will be used to prepare the final EIS, which will become part of the record used by the Commission to make its final decisions on this project. At this time, the Commission decision on the proposed project is expected in June 2012.

The Commission decision on the merits of this project will be based on the record of a public hearing that will be held about 30 days after the final EIS is issued. When the final EIS is prepared, the Commission will issue a Notice of Hearing. The hearing will satisfy the WEPA requirements of the Commission and WDNR. The final EIS and testimony from the public hearing will be included in the hearing record.

If necessary, WDNR will hold separate hearings on its water permits or other WDNR regulatory actions discussed in this draft EIS.

Table of Contents

TO THE READER	I
TABLE OF CONTENTS	I
LIST OF TABLES	IX
LIST OF FIGURES	XI
CONTRIBUTORS AND REVIEWERS	XIII
Contributors.....	xiii
Public Service Commission	xiii
Department of Natural Resources.....	xiii
Reviewers	xiii
Public Service Commission	xiii
Department of Natural Resources.....	xiii
EXECUTIVE SUMMARY	XV
Application.....	XV
CapX2020	XV
Alma-La Crosse 345 kV Project	XV
Need for the Proposed Project.....	xvi
Existing transmission and generation.....	xvii
System Alternatives	xvii
Proposed Project and Routes.....	XX
Potential Environmental and Social Impacts	xxi
1. PROJECT OVERVIEW AND REGULATORY RESPONSIBILITY.....	1
1.1. Project Overview	1
1.1.1. Application under review	1
1.1.2. CapX2020 utilities and projects	2
1.1.3. Alma-La Crosse project	3
1.2. Role of the Public Service Commission of Wisconsin	6
1.2.1. Approval, denial, or modification of this proposed project	6
1.2.2. What the Commission must consider	6
1.2.3. Interagency relationships in the PSCW process.....	7
1.2.4. Intervenors in the PSCW process.....	7
1.2.5. Public involvement opportunities in the PSCW process.....	8
1.3. Related Wisconsin Agencies' Responsibilities.....	9
1.3.1. Wisconsin Department of Natural Resources	10
1.3.2. Wisconsin Department of Agriculture and Trade and Consumer Protection.....	10
1.3.3. Wisconsin Department of Transportation.....	10
1.3.4. Wisconsin Historical Society	11
1.4. Federal Agencies' Responsibilities	11
1.5. Minnesota Agency Related Responsibilities	12
1.6. County and Local Government Responsibilities	12

2. ASSESSMENT OF NEED FOR ELECTRIC SYSTEM IMPROVEMENTS	14
2.1. Transmission Planning Criteria	14
2.2. Area of Interest	15
2.3. Existing La Crosse/Winona Area Electric Transmission System	15
2.4. Existing Electric Generation.....	15
2.5. Area Load Forecast.....	15
2.6. Assessment of Area Transmission Reliability	18
2.6.1. N-1 contingency.....	18
2.6.2. N-2 contingency.....	19
3. POTENTIAL SYSTEM SOLUTIONS	20
3.1. No Build Option	20
3.2. Non-Transmission Options	20
3.2.1. Request for more options	20
3.2.2. Load reduction as an option	21
3.2.3. Generation options with renewable resources or natural gas	21
3.3. Transmission Alternatives—Descriptions	24
3.3.1. Alma-La Crosse 345 kV transmission line option (proposed project)	24
3.3.2. Reconductor option	25
3.3.3. 161 kV Red Wing-La Crosse transmission line option	25
3.3.4. Single-circuit 161 kV North Rochester-La Crosse transmission line option	26
3.3.5. Double-circuit 161 kV North Rochester-La Crosse transmission line option	26
3.3.6. Single-circuit 230 kV North Rochester-La Crosse transmission line option.....	26
3.4. Transmission Alternatives—Cost and Performance Comparison	27
3.5. Scenarios for the Existing Dairyland Power Cooperative 161 kV Line	27
4. MISSISSIPPI RIVER AT ALMA TO HOLMEN—DETAILED PROJECT DESCRIPTION	29
4.1. Proposed 345 kV Transmission Line Route Alternatives	29
4.1.1. Q1-Highway 35 Route and Q1-Galesville Route	29
4.1.2. WisDOT's STH 88 Alternative for the Q1 Routes.....	30
4.1.3. Arcadia Route	30
4.1.4. Ettrick Alternative for the Arcadia Route	30
4.1.5. Applicants' original Q1 Route	30
4.2. Electric Transmission Facilities.....	31
4.2.1. Transmission line facilities	31
4.2.2. Rights-of-way	33
4.3. Project Endpoint—Mississippi River Crossing	35
4.3.1. Alternative crossings and interconnections	35
4.3.2. Winnowing of crossing alternatives	35
4.3.3. Crossing at Alma	36
4.4. Project Endpoint—Briggs Road Substation	37
4.4.1. Proposed facilities description	37
4.4.2. Location	38

4.4.3. Existing environment.....	38
4.4.4. Acreages and heights of existing and new construction.....	38
4.5. Costs	40
4.5.1. New substation.....	40
4.5.2. Utility-proposed routes	40
4.5.3. Routes using segments suggested by WisDOT or WDNR.....	41
4.5.4. Environmental impact assessment fees	43
4.5.5. MISO's transmission tariff benefit	44
4.5.6. Costs for replacement trees within WisDOT ROW	44
4.6. Construction Schedule	44
5. ENVIRONMENTAL IMPACTS AND MITIGATION STRATEGIES FOR TRANSMISSION LINE PROJECTS	45
5.1. Assessing Transmission Line Impacts	45
5.1.1. Quantifying potential impacts.....	45
5.1.2. Determining the degree of potential impacts	46
5.1.3. Identifying the duration of potential impacts	46
5.2. Mitigating Potential Impacts.....	46
5.2.1. General	46
5.2.2. Corridor sharing	47
5.2.3. Structure design.....	49
5.2.4. Construction timing	49
5.3. Landowners' Statutory Rights	49
5.3.1. Rights specified in Wisconsin statutes.....	49
5.3.2. Waiving landowner rights during easement negotiations	50
5.4. Construction Phases	50
5.4.1. Pre-construction activities	51
5.4.2. ROW marking and clearing	51
5.4.3. Augering and blasting	52
5.4.4. Foundation installation	53
5.4.5. Tower erection and wire stringing.....	53
5.4.6. Site restoration	53
5.4.7. Vegetative maintenance of ROW.....	54
5.5. Impacts Associated with Transmission Lines.....	54
5.5.1. Aesthetics.....	54
5.5.2. Agricultural lands.....	55
5.5.3. Airports and airstrips	59
5.5.4. Archeological and historic resources	59
5.5.5. Cultural concerns	60
5.5.6. Electric and magnetic fields	60
5.5.7. Endangered/threatened and protected species.....	61
5.5.8. Highway impacts	63
5.5.9. Invasive species.....	64
5.5.10. Noise and light impacts	66
5.5.11. Property owner issues	67
5.5.12. Radio and television reception	70

5.5.13. Recreation	70
5.5.14. Safety	70
5.5.15. Stray voltage and dairy livestock	72
5.5.16. Water resources	74
5.5.17. Wetland resources	76
5.5.18. Woodlands	81
6. ENVIRONMENTAL ANALYSIS: NEW 345/161 KV BRIGGS ROAD SUBSTATION	84
6.1. Proposed Installation	84
6.1.1. Main equipment	84
6.1.2. Alternative sites	85
6.1.3. Transmission re-routes to enter substation	86
6.2. Natural Resources and Potential Impacts	88
6.2.1. Geography	88
6.2.2. Woodland	88
6.2.3. Wildlife and plant habitat changes	89
6.2.4. Endangered and threatened species and communities	89
6.2.5. Streams and wetlands	89
6.2.6. Archeological resources	89
6.3. Community Impacts	90
6.3.1. Agriculture	90
6.3.2. Land use compatibility	90
6.3.3. Zoning and planning	90
6.3.4. Proximity to residences	91
6.3.5. Visual and noise impacts	91
6.3.6. Property values	92
6.3.7. Electric and magnetic fields	92
6.4. Summary	92
6.5. Other Alternative Sites Considered by the Applicants	92
7. ENVIRONMENTAL ANALYSIS: Q1-HIGHWAY 35 ROUTE	94
7.1. Route Description	94
7.2. Geography	96
7.2.1. Geology	96
7.2.2. Topography	96
7.2.3. Soils	97
7.2.4. Land cover in general	98
7.3. Natural Resources and Impacts	98
7.3.1. Woodlands	98
7.3.2. Endangered resources	100
7.3.3. Rivers and streams	112
7.3.4. Wetlands and the Van Loon Wildlife Area	114
7.3.5. Archeological resources/historic properties	121
7.4. Community Impacts	121
7.4.1. Aesthetic and visual impacts	121
7.4.2. Agriculture	123

7.4.3. Airports and airstrips	125
7.4.4. Electric distribution line issues	125
7.4.5. Electric and magnetic fields	126
7.4.6. High-voltage impact fees	129
7.4.7. Public lands	130
7.4.8. Highway concerns—Great River Road	131
7.4.9. Land use compatibility	134
7.4.10. Residences	137
7.5. Staging and Access	138
7.5.1. Staging areas	138
7.5.2. Access paths	139
8. ENVIRONMENTAL ANALYSIS: Q1-GALESVILLE ROUTE	141
8.1. Route Description.....	141
8.2. Geography	143
8.2.1. Geology	143
8.2.2. Topography	144
8.2.3. Soils	144
8.2.4. Land cover in general	145
8.3. Natural Resources and Impacts.....	146
8.3.1. Woodlands	146
8.3.2. Endangered resources	148
8.3.3. Rivers and streams	152
8.3.4. Wetlands	154
8.3.5. Archeological resources/historic properties	157
8.4. Community Impacts	158
8.4.1. Aesthetic and visual impacts	158
8.4.2. Agriculture	160
8.4.3. Airports and airstrips	161
8.4.4. Electric distribution line issues	162
8.4.5. Electric and magnetic fields	163
8.4.6. High-voltage impact fees	167
8.4.7. Public lands	168
8.4.8. Highway concerns—Great River Road	168
8.4.9. Land use compatibility	170
8.4.10. Residences	173
8.5. Staging and Access	174
8.5.1. Staging areas	174
8.5.2. Access paths	175
9. ENVIRONMENTAL ANALYSIS: Q1-STH 88 CONNECTOR ALTERNATIVE	176
9.1. Route Descriptions.....	176
9.1.1. Reason for the alternatives	176
9.1.2. Route descriptions	176
9.1.3. ROW requirements	178
9.1.4. Structures	179

9.2. Geography	179
9.2.1. Geology	179
9.2.2. Topography.....	180
9.2.3. Soils	181
9.2.4. Landcover in general	181
9.3. Natural Resources and Impacts.....	182
9.3.1. Woodlands.....	182
9.3.2. Potential impact	182
9.3.3. Endangered resources	183
9.3.4. Streams	184
9.3.5. Wetlands.....	185
9.3.6. Archeological resources/historic properties.....	186
9.4. Community Impacts	186
9.4.1. Aesthetic and visual impacts	186
9.4.2. Agriculture.....	187
9.4.3. Airports and airstrips.....	189
9.4.4. Electric distribution line issues.....	189
9.4.5. Electric and magnetic fields.....	189
9.4.6. High-voltage impact fees	193
9.4.7. Highway concerns	194
9.4.8. Public lands	194
9.4.9. Land use compatibility	195
9.4.10. Residences	195
9.5. Potential Staging/Laydown Areas and Off-ROW Access Roads— Existing Conditions and Potential Impacts	196
9.5.1. Staging areas.....	196
9.5.2. Access paths	197
10. ENVIRONMENTAL ANALYSIS: ARCADIA ROUTE.....	198
10.1. Route Description.....	198
10.2. Geography	200
10.2.1. Geology	200
10.2.2. Topography	201
10.2.3. Soils	202
10.2.4. Land cover in general	203
10.3. Natural Resources and Impacts.....	203
10.3.1. Woodlands	203
10.3.2. Endangered and threatened species and communities.....	205
10.3.3. Rivers and streams	209
10.3.4. Wetlands	211
10.3.5. Archeological resources/historic properties	214
10.4. Community Impacts	214
10.4.1. Aesthetic and visual impacts.....	214
10.4.2. Agriculture	215
10.4.3. Airports and airstrips	217
10.4.4. Electric distribution line issues	217

10.4.5.	Electric and magnetic fields.....	219
10.4.6.	High-voltage impact fees	223
10.4.7.	Public lands	223
10.4.8.	Highway concerns	224
10.4.9.	Land use compatibility	224
10.4.10.	Residences	227
10.5.	Staging and Access	228
10.5.1.	Staging areas	228
10.5.2.	Access paths	229
11.	ETTRICK CONNECTOR ALTERNATIVE	230
11.1.	Route Description.....	230
11.2.	Geography	231
11.2.1.	Topography	231
11.2.2.	Soils	232
11.2.3.	Land cover in general	233
11.3.	Natural Resources and Impacts.....	233
11.3.1.	Woodlands.....	233
11.3.2.	Endangered resources	234
11.3.3.	Rivers and streams.....	235
11.3.4.	Wetlands.....	237
11.3.5.	Archeological resources	238
11.4.	Community Impacts	238
11.4.1.	Aesthetics and visual impacts	238
11.4.2.	Agriculture.....	240
11.4.3.	Airports and airstrips.....	240
11.4.4.	Electric distribution line issues.....	241
11.4.5.	Electric and magnetic fields.....	241
11.4.6.	High-voltage impact fees	243
11.4.7.	Public lands	244
11.4.8.	Highway concerns	244
11.4.9.	Land use compatibility	244
11.4.10.	Residences	245
11.5.	Staging and Access	245
11.5.1.	Staging areas	245
11.5.2.	Access paths	246
12.	SUMMARY AND COMPARISON OF IMPACTS AMONG ROUTES	247
12.1.	Derivation of Proposed Routes and Alternatives.....	247
12.1.1.	Three routes proposed by the applicants	247
12.1.2.	Routes resulting from WDOT suggestion.....	248
12.1.3.	Route resulting from WDNR suggestion	248
12.2.	Comparison of Natural Resource Impacts among Routes.....	249
12.2.1.	Potential impacts to rare species and communities	249
12.2.2.	Potential forest losses	252
12.2.3.	Potential Impacts to rivers and streams	252
12.2.4.	Potential wetland impacts.....	254

12.3. Comparison of Community Impacts.....	255
12.3.1. Recreational resources	255
12.3.2. High-voltage impact fees	255
12.3.3. Proximity of the routes to residences, schools, daycare centers, and businesses	256
12.3.4. Potential for impact on Great River Road	256
12.4. Scenarios for a DPC Q1 161 kV Rebuild Resulting from Commission Routing Decisions	257
12.5. Summary and Comparison of Selected Impacts for All Routes	258
12.6. Summary and Comparison of Route Costs	259
ACRONYMS	261
APPENDIX A – COMMON STRUCTURE DIAGRAMS	263
APPENDIX B – ELECTRIC AND MAGNETIC FIELDS	264
APPENDIX C – AGRICULTURAL IMPACT STATEMENT	265
APPENDIX D – EXECUTIVE SUMMARY OF THE MINNESOTA OFFICE OF ENERGY SECURITY ENVIRONMENTAL IMPACT STATEMENT.....	266
APPENDIX E – RURAL UTILITIES SERVICE DRAFT EIS	267

List of Tables

Table 1.1-1	Potential project ownership percentages, based on the Hampton-Rochester-La Crosse Project Development Agreement.....	5
Table 2.4-1	Power plants serving the La Crosse/Winona area.....	15
Table 2.5-1	Peak temperature and peak load.....	17
Table 2.5-2	Comparison of peak load projections.....	18
Table 3.3-1	La Crosse area reconductor alternative.....	25
Table 3.4-1	Cost and performance comparison of transmission line alternatives based on 2010 dollar planning level estimates.....	27
Table 4.5-1	Briggs Road Substation construction cost estimates.....	40
Table 4.5-2	Project cost estimates for utility-proposed transmission routes plus the proposed Briggs Road Substation	40
Table 4.5-3	Project cost estimates for STH 88 and Ettrick Route Alternatives based on suggestions from WisDOT and WDNR, plus the proposed Briggs Road Substation	42
Table 5.2-1	Examples of mitigation strategies	47
Table 5.2-2	Examples of possible disadvantages of corridor sharing.....	48
Table 5.5-1	Common exotic and invasive plant species found in Wisconsin	65
Table 6.2-1	Archeological resources identified on the West and East Briggs Road Substation Sites	89
Table 7.3-1	NHI natural community occurrences along Q1-Highway 35 Route	101
Table 7.3-2	Summary of area affected in acres, by general habitat type	101
Table 7.3-3	Summary of NHI rare species occurrences along the Q1-Highway 35 Route, by taxa	104
Table 7.3-4	Q1-Highway 35 Route wetland summary by segment*	114
Table 7.3-5	Original Q1 Route wetland summary by segment*	120
Table 7.4-1	High voltage impact fees expected to be paid to governmental units along the Proposed Q1-Highway 35 Route.....	130
Table 7.4-2	Residences within 300 feet of the Q1-Highway 35 Route	138
Table 8.3-1	NHI natural community occurrences along Q1-Galesville Route	148
Table 8.3-2	Summary of area affected in acres, by general habitat type	149
Table 8.3-3	Summary of NHI rare species occurrences along the Q1-Galesville Route, by taxa	150
Table 8.3-4	Q1-Galesville wetland summary by segment*	155
Table 8.4-1	High-voltage impact fees expected to be paid to governmental units along the Proposed Q1-Galesville Route	167
Table 8.4-2	Residences within 300 feet of the Q1-Galesville Route.....	173
Table 9.1-1	Q1-STH 88 Alternatives connector segments and route segments in combinations	177
Table 9.4-1	High-voltage impact fees expected to be paid to governmental units for STH 88 Option A/Q1-Highway 35 Route.....	193
Table10.3-1	NHI natural community occurrences summarized for the Arcadia Route	205
Table10.3-2	Summary of area affected in acres, by general habitat type	206
Table10.3-3	Summary of NHI rare species occurrences along the Arcadia Route, by taxa	207
Table10.3-4	Arcadia Route wetland summary by route segment*	211
Table10.4-1	High voltage impact fees expected to be paid to governmental units along the Proposed Arcadia Route	223
Table10.4-2	Residences within 300 feet of the Arcadia Route	227
Table11.3-1	Wetland Impacts along the Ettrick Connector route alternative in acres	235

PUBLIC SERVICE COMMISSION OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES

List of Figures

Figure 1.1-2.....Proposed Griggs Road Substation East and West site alternatives.....	4
Figure 2.5-1.....Peak load and temperature.....	17
Figure 4.2-1.....Typical Xcel/NSPW ROW clearing requirements	34
Figure 4.4-1General substation facilities arrangement at Briggs Road West Site Alternative	39
Figure 6.1-1Alternative sites proposed for Briggs Road Substation	85
Figure 6.1-2.....Re-routes of 161 kV lines and Briggs Road Substation if Q1-Highway 35 Route is approved	86
Figure 6.1-3.....Re-routes of 161 kV lines and Briggs Road Substation if Q1-Galesville or Arcadia Routes are approved.....	87
Figure 6.1-4.....Re-routes of 161 kV lines if the original Q1 Route across the Black River is approved.....	88
Figure 6.3-1Proposed Griggs Road Substation sites and nearby residences	91
Figure 7.1-1Q1-Highway 35 Route.....	95
Figure 7.3-1Original Q1 Route	111
Figure 7.4-1Mississippi Valley Conservancy Lands along the Q1 Routes and the STH 88 Connector alternatives.....	135
Figure 7.4-2.....New Amsterdam Grasslands of the Mississippi Valley Conservancy adjacent to Segment 9	137
Figure 8.1-1Q1-Galesville Route	142
Figure 9.1-1Q1-STH 88 Connector Alternative Option A	176
Figure 9.1-2Q1-STH 88 Connector Alternative Option B	178
Figure10.1-1Arcadia Route	199
Figure11.1-1Ettrick Connector Alternative Route.....	230

PUBLIC SERVICE COMMISSION OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES

Contributors and Reviewers

CONTRIBUTORS

Public Service Commission

Kenneth Detmer
Deborah Erwin
William Fannucchi
Jim Lepinski
Paul Rahn
Kenneth Rineer
Daniel Sage
Udaivir Singh Sirohi
Carol Stemrich
Julie Urban
Ali Wali
Marilyn Weiss

Department of Natural Resources

Shari Koslowsky
Cheryl Laatsch

REVIEWERS

Public Service Commission

Scot Cullen
William Fannucchi
Jim Lepinski
John Lorence
Diane Ramthun
Kenneth Rineer
Daniel Sage
Jana Thompson
Kathleen Zuelsdorff

Department of Natural Resources

Shari Koslowsky
Cheryl Laatsch
David Siebert

PUBLIC SERVICE COMMISSION OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES

Executive Summary

APPLICATION

The Public Service Commission of Wisconsin (PSCW or Commission) has before it an application for a Certificate of Public Convenience and Necessity (CPCN) for a new 345 kilovolt (kV) electric transmission line and substation, submitted as part of the major CapX2020 Transmission Expansion Initiative (CapX2020) by three Wisconsin electric utilities. The three utility applicants for the project are Northern States Power Company—Wisconsin (NSPW), Dairyland Power Cooperative (DPC), and WPPI Energy (WPPI). The 345 kV line would extend from the Wisconsin border in the Mississippi River west of Alma, Wisconsin, in Buffalo County, through Trempealeau County to a new 345/161 kV substation, known as the Briggs Road Substation, to be built on the southwest side of Holmen, Wisconsin, in La Crosse County.

CAPX2020

The three utilities are members of a larger group, the CapX2020 Utilities, a group of 11 electric utilities¹ that examined the regional transmission infrastructure in order to address a variety of emerging and related transmission concerns that have arisen in the multi-state area. The proposed project is part of a larger, multi-utility project called the Hampton-Rochester-La Crosse 345 kV Transmission Project. In their application, the utilities state that the purposes of the project are: (1) to serve increasing electric demand in the La Crosse, Wisconsin, and Winona and Rochester, Minnesota, areas; (2) to maintain the reliability of the regional electrical system; and (3) to support means for getting local electric generation output into the electric grid. More recently, the utilities have stated that another advantage of the new line is to enhance power transfers into Wisconsin from states west of the Mississippi River. The majority of the Hampton-Rochester-La Crosse project would be in Minnesota. The various parts of the CapX2020 project are subject to regulations administered in several states plus certain federal agencies. The portion of the proposed Hampton-Rochester-La Crosse project that is outside of Wisconsin extends from the Mississippi River westward into Minnesota to Rochester and northward and is subject to Minnesota state laws. The portion in Wisconsin, the proposed Alma-La Crosse Transmission Project, extends from the same place in the Mississippi River eastward through the city of Alma and southeast toward the city of La Crosse. It is subject to Wisconsin state laws.

ALMA-LA CROSSE 345 KV PROJECT

For the Alma-La Crosse 345 kV Transmission Project, the applicants propose to construct a 345 kV electric transmission line about 40 to 55 miles long, depending on the route. The proposed route alternatives mostly follow existing 161 or 69 kV transmission line corridors. The new line would, in most places, be a double-circuit, 345/161 kV line on single poles. The right-of-way (ROW) would be about 150 feet wide. Wider ROWs up to 280 feet would be necessary for specialty poles such as those for the Mississippi River crossing or those needed for supporting long spans between hilltops in the Wisconsin

¹The CapX2020 Utilities are Central Minnesota Municipal Power Agency, Dairyland Power Cooperative, Great River Energy, Minnesota Power, Minnkota Power Cooperative, Missouri River Energy Services, Otter Tail Power Company, Rochester Public Utilities, Southern Minnesota Municipal Power Agency, WPPI Energy, and Xcel Energy, parent company of NSPW.

coulee landscape. The eastern terminus of the project would be a new 345/161 kV substation, the Briggs Road Substation, southwest of the village of Holmen.

Three route alternatives for the proposed 345 kV transmission line are proposed by the applicants: the Q1-Highway 35 Route; the Q1-Galesville Route, and the Arcadia Route. Several other route possibilities have been identified based on suggestions from Wisconsin state agencies. The STH 88 Connector Alternatives to the Q1 Routes and the Ettrick Connector Alternative to the Arcadia Route are a result of concerns raised by the Wisconsin Department of Transportation (WisDOT) and the Wisconsin Department of Natural Resources (WDNR), respectively. The applicants' originally-proposed Q1 Route remains under consideration as well. All in all, nine route alternatives are being evaluated.

The overall cost of the project is expected to range from about \$195 million to about \$224 million, depending on the route selected by the Commission. The applicants state that final ownership percentages among the three utilities would be determined after all regulatory decisions are made if the project is approved. The final ownership percentages determine final capital expenditure commitments from the individual applicants.

If the project is approved, based on the expected timeframe for other milestones, an in-service date of June 2016 would be likely.

NEED FOR THE PROPOSED PROJECT

One of the stated reasons for this new line is to address the community load serving needs in the La Crosse/Winona area. In addition to the Winona area in Minnesota, the areas in Wisconsin served by this line are Buffalo, Trempealeau, and La Crosse Counties, including the communities of Alma, Buffalo City, Fountain City, Arcadia, Galesville, Trempealeau, Holmen, Onalaska, La Crosse, and the surrounding rural areas.

It is not clear that there will be sufficient population growth in the La Crosse/Winona area to justify the projected increase in demand for electricity presented in the CPCN application. Peak load growth in the La Crosse/Winona area from 2002 to 2010 was 6.2 percent or an average annual growth rate of 0.77 percent. Population growth during this same time period was 4.3 percent or an average annual growth rate of 0.54 percent. The population in the La Crosse/Winona area is projected to increase at an average annual rate of 0.49 percent from 2010 to 2030. However, the applicants have projected the average annual growth in peak load over the same time period to be 1.7 percent. This projected peak load growth rate is more than twice the historical peak load growth rate, even though the projected population growth rate is lower than the historical population growth rate.

Table ES-1 shows a comparison of the peak loads using the applicants' forecasted growth rate with the most likely growth rate MISO Scenario and the highest growth rate MISO Scenario. Given the growing consensus that economic recovery will be slow, the heavy support for the first scenario by MISO stakeholders and the population forecasts for the La Crosse/Winona area, the lower MISO forecast shown in Table ES-1 seems most likely.

Table ES-1 Comparison of peak load projections in MW

Year	Applicants' Rate of 1.70%	MISO Rate of 0.78%	MISO Rate of 1.28%
2015	514.98	469.29	481.05
2020	547.57	487.88	512.63
2025	583	507.21	546.29
2030	620	527.30	582.16

The applicants identified possible future overloads and low voltages on the transmission system under normal, first contingency, and multiple contingency conditions in the La Crosse/Winona (Project) area. They performed contingency analyses in accordance with North American Electric Reliability Corporation (NERC) standards and their planning criteria. These analyses examined the performance of the transmission system under contingency conditions, when a single element or a combination of multiple elements of the transmission system suddenly failed. The La Crosse/Winona area is mainly served by a network of 161 kV and 69 kV transmission lines. The four 161 kV transmission lines are Alma-Marshland-La Crosse Tap, Alma-Tremval-La Crosse, Genoa-Coulee, and Genoa-La Crosse Tap.²

The applicants state that the growing demand for electricity in the La Crosse/Winona area would exceed the capabilities of the existing electrical system to deliver power reliably under contingency conditions. At this time, that conclusion is still being questioned.

Existing transmission and generation

The transmission system's ability to serve the La Crosse/Winona area reliably depends on the operating status of the local major power plants shown in Table ES-2.

Table ES-2 Power plants serving the La Crosse/Winona area

Plant	Capacity (MW)	Fuel Type	Distance from La Crosse (miles)
John P. Madgett	395	Coal	40
Alma Units 1-5	208	Coal	40
Genoa Unit 3	377	Coal	20
French Island Units 1 and 2	26	Refuse	Within the City of La Crosse
French Island Unit 4	70	Oil	Within the City of La Crosse
French Island Unit 3	70	Oil	Currently not operating

The NERC Operating System Guideline requires that an area transmission system be capable of successful operation in the event of failure of two of its elements. The applicants identified an N-1 critical contingency that limited load serving capability to 460 MW with the operation of all generating units at Alma and Genoa. With additions of two 60 megavolt amperes reactive (MVAR) capacitor banks to the La Crosse area 161 kV system, the load serving capability increased by 10 MW to 470 MW. With operation of the 70 MW peaking French Island Peaking Unit 4 generation, the load serving capability could be increased to about 540 MW. Commission staff considers that reactivating the French Island Unit 3 generator could further increase the load serving capability to 610 MW.

The applicants identify an N-2 critical contingency that limited load serving capability up to 430 MW and indicate that additional electrical infrastructure is needed to provide load serving capability for customer loads greater than 430 MW. Commission staff considers that operation of French Island Unit 4 could increase the load serving capability to 500 MW and that reactivating French Island Unit 3 could increase it to 570 MW.

SYSTEM ALTERNATIVES

The applicants' analysis shows that if nothing is done, load-serving capability in the area will be limited to 610 MW in the event of a critical N-1 contingency and limited to 460 MW in the event of a critical N-2 contingency. Otherwise, the applicants state that transmission grid reliability would require the

²The La Crosse-Monroe County 161 kV line does not provide a meaningful source to the greater La Crosse area because it is the strongest source for Sparta and Tomah, given the relatively weak transmission source from the east.

demand/supply ratio to stay level until 2020 with a reduction of 98 MW of demand or an increase of 98 MW of generation in the La Crosse area. They conclude that neither additional generation nor demand-side management (DSM) would satisfy their need for local service reliability, generation support, and regional reliability. Energy efficiency and load management do not provide region-wide benefits, and additional local generation would not provide region-wide benefit without the addition of transmission. They also would not supply the additional transmission connections that a 345 kV line would offer with respect to improving the ability of the system to withstand contingencies. The applicants also state that neither DSM nor the addition of local generation can provide the bulk transmission capability across the Minnesota/Wisconsin border that could enable future power transfers into Wisconsin to support generation development elsewhere. In fact, current generation resources to meet the needs of the area appear adequate, and projected reserve margins and the need for economical energy typically drive investment decisions for generation. In addition, the installation of any large generation typically requires an increase in transmission capacity to move the power from the source.

Energy efficiency has been considered but, at this time, there is no regulatory authority to ensure energy user compliance with load reduction and energy efficiency goals. An effort would need to rely on voluntary compliance, and no mechanism has been identified that would ensure adequate participation over time. Because of the nature of human and economic activity, there would be no guarantee that a one-time measure in the area would have a lasting effect. Cost would also be an issue, or at least an unknown.

A wind project would have a capital cost of approximately \$2.2 million per MW of installed capacity. Unlike several other alternatives, there would be no fuel cost associated with a wind project but, based on even a 40 percent capacity factor, 245 MW of wind capacity would be needed to serve the electric demand and would cost approximately \$539 million. If wind power was to be imported from outside the La Crosse service area, that power would likely require additional transmission line facilities to be built. The voltage of the transmission lines might not need to be as high as the line proposed, but that would need to be evaluated.

Solar power has been considered but, assuming a 20 percent capacity factor, a system using the most efficient crystalline cells would need to be approximately 612.5 MW in size to provide 98 MW of capacity, and would require about 1.156 square miles to install.³ As with wind power, physical obstructions and local laws might increase the area needed for this capacity. Depending on where it was located, additional transmission line facilities might also be required.

If biomass power is sought, it appears that more than one biomass-fired generation plant would be needed. With a typical biomass supply and a new power plant site, 25 MW is an optimal size for a project in terms of capital costs and fuel supply costs. Smaller projects would be more expensive, relatively, and larger projects would likely require larger fuel acquisition radii. Three such biomass plants would not generate 98 MW, even if they could accomplish a 100 percent capacity factor. The optimum cost and size of a plant could cost about \$3,335 per kW for a 25 MW plant, including costs for environmental protection. At less than 25 MW, the capital cost per kW would increase and, at greater than 25 MW, the fuel supply cost would increase. The Commission recently approved a 50 MW, biomass-fired

³ The following numbers can be used to find the approximate system size that can be placed in a given space.

- Crystalline PV System: 8-11watts/square foot
- Thin Film PV System: 5 watts/square foot
- HE Crystalline System: 17-18 watts/square foot

<http://www.nrel.gov/docs/fy10osti/46078.pdf>. December 2009.

cogeneration plant at a cost of about \$255 million.⁴ This cost is greater than the anticipated cost of the Alma-La Crosse 345 kV Transmission Project, and it provides only 50 MW of capacity.

The capital cost of one 100-MW natural gas-fired plant would likely be close to \$100 million, about half the expected cost of the proposed transmission project. However, in addition to the capital cost, there would be the costs associated with fuel, maintenance and installation of larger natural gas supply lines and improved transmission connections if the existing lines near the new plants do not have the capacity. Thus, the installation cost appears relatively high, and potential environmental impacts would remain to be assessed. In addition, based on the capacity factors or run time of existing peakers at French Island, small natural gas-fired plants would seldom run, making them uneconomical. Without a need for replacement or additional generation, natural gas capacity would not be profitable, and any new local generation would not meet criteria of reasonable need for PSCW approval.

The applicants evaluated several transmission system options or alternatives to serve the needs of the La Crosse/Winona area. These included:

- A reconductor option
- A 161 kV Red Wing La Crosse transmission line option
- A single-circuit 161 kV North Rochester-La Crosse transmission line option
- A double-circuit 161 kV North Rochester-La Crosse transmission line option
- A single-circuit 230 kV North Rochester-La Crosse transmission line option

The above transmission alternatives are compared in Table ES-3. The costs included in the table are planning-level costs used primarily for comparison purposes.

Table ES-3 Cost and performance comparison of transmission line alternatives based on 2010 dollar planning level estimates

Alternatives	La Crosse/Winona Area Load Serving Capability (MW)	Project Cost (\$ million)	Transmission Losses Cost (\$ million)	Total Cost (\$ million)*
345 kV Proposed Project	750 MW	201	0	201
Reconductor Option	600 MW	182	36	218
Transmission Line Option: 161 kV Red Wing-La Crosse	750 MW	332	3	335
Transmission Line Option: Single-Circuit 161 kV North Rochester-La Crosse	550 MW	70	32	102
Transmission Line Option: Double-Circuit 161 kV North Rochester-La Crosse	600 MW	95	23	118
Transmission Line Option: Single-Circuit 230 kV North Rochester-La Crosse	550 MW	83	18	101

* For this comparison, Total Cost = Project Cost + Transmission Losses Cost

The existing DPC 161 kV line, called the Q1 line, is nearing the end of its useful life but is still needed. DPC has determined that it must be either rebuild or replace the line. DPC plans to reconstruct, by 2013, the sections of Q1 that are not replaced by the project in this docket. Different DPC Q1 rebuild scenarios

⁴ PSC REF #148090, Final Decision, Wisconsin Electric Power Company Rothschild Biomass Cogeneration Project.

would result from different Commission route decisions for this project. The rebuild could require a separate CPCN from the Commission depending on whether new ROW would be needed.

PROPOSED PROJECT AND ROUTES

For this project, the applicants proposed three routes to make the connection from the Mississippi River crossing at the city of Alma in Buffalo County to a new substation in the La Crosse service area near the village of Holmen in La Crosse County. The route alternatives considered in this EIS are described below. There are nine routes in all, including alternatives.

Two of the routes, the **Q1-Highway 35 Route** and **Q1-Galesville Route**, follow an existing 161 kV corridor southward as a 345/161 kV double-circuit line on metal, single-pole structures along Great River Road (GRR) to the mouth of Waumandee Creek between the villages of Cochrane and Fountain City. At that point the routes leave the Mississippi River and extend inland, still following the existing 161 kV corridor as a double-circuit line. East of the Trempealeau River, these two routes diverge and follow very different paths to avoid or minimize different resource impacts.

The **Q1-Highway 35 Route** continues along the existing 161 kV transmission corridor as a double-circuit line to where the corridor intersects with STH 35 east of the village of Trempealeau. From that point, the route leaves the 161 kV corridor, takes the 161 kV line with it, and parallels STH 35 east as a double-circuit line across the Black River bottomlands and the Van Loon State Wildlife Area to the STH 35/USH 53 interchange, where it then follows USH 53 southward to a proposed substation site along Briggs Road southwest of Holmen. This route was proposed by the applicants as an alternative to their original proposal that followed the existing Q1 transmission corridor all the way to the substation site. The existing Q1 corridor in this area passes through the Black River bottomlands and the Upper Mississippi River National Wildlife and Fish Refuge.

The **Q1-Galesville Route** avoids the Black River bottomlands and the Van Loon Wildlife Area by diverging from the existing 161 kV corridor around Delaney Road east of the Trempealeau River and running eastward as a single-circuit line, connecting with STH 54 south of Galesville and intersecting with a different, north-south, 161 kV transmission corridor east of USH 53. From that point, it follows the transmission corridor, USH 53, CTH HD, and Briggs Road as a double-circuit line to the proposed substation site.

WisDOT has strong concerns about a route along GRR (STH 35) and has suggested an alternative, an **STH 88 Connector Alternative**, that would run from the Mississippi River crossing at Alma east as a 345/161 double-circuit line to a point north of Waumandee Creek valley and then south along STH 88 as a single-circuit line to connect to the Q1-Highway 35 or Q1-Galesville Route from the north. From the mouth of Waumandee Creek eastward, either of the two Q1 Routes would be the same. The applicants provided two optional paths down the valley along STH 88, **STH 88 Connector Option A** and **STH 88 Connector Option B**.

During the pre-application process, the applicants had proposed the original **Q1 Route** following the existing DPC “Q1” 161 kV line between Alma and the North La Crosse Substation in Holmen. The portion of the original Q1 Route that crosses the Mississippi River Wildlife and Fish Refuge may not be approved by the USFWS because a portion of it would require additional easement that may not be allowed under current land uses authorized on refuge property. However, in case project circumstances change, comparable information is provided about this route so that the Commission can make informed decisions if it determines that it should be considered.

A third route, the **Arcadia Route**, is also proposed by the applicants. It avoids GRR and the Black River bottomlands and the Van Loon Wildlife Area almost entirely. It is an overland route that, from Alma, follows an existing east-west 161 kV transmission corridor over the river bluffs as a 345/161 kV double-circuit line to a point across the Trempealeau River northeast of the city of Arcadia. It then turns south following an existing north-south 69 kV transmission corridor generally as a 345/69 kV double-circuit line to STH 54 east of Centerville, and from there it heads east on STH 54 and south of the city of Galesville along the same path as the Q1-Galesville Route to the substation.

The applicants developed the **Ettrick ConnectorAlternative** for the Arcadia Route in response to WDNR's suggestion to provide the Commission with a second set of route segments to avoid the Black River bottomlands and the Van Loon State Wildlife Area (besides the segments common to the Arcadia and Q1-Galesville Routes). This alternative diverges from the Arcadia Route where the existing 69 kV corridor crosses Fox Coulee Lane. It follows an east-west 69 kV corridor as a 345/69 kV double-circuit line (with the 69 kV portion built to 161 kV standards) along Fox Coulee and Hovell Lane, and across a ridge. It continues to follow the 69 kV corridor eastward into the Beaver Creek valley to an intersection with an existing north-south 161 kV corridor west of the village of Ettrick. It follows that 161 kV corridor southward to the Black River and, from there, follows the same path as the Arcadia or Q1-Galesville Routes to the proposed substation site.

POTENTIAL ENVIRONMENTAL AND SOCIAL IMPACTS

On the western end of the project, every route alternative includes a Mississippi River crossing at Alma and the potential impacts associated with it in the Mississippi River National Wildlife and Fish Refuge. At the eastern terminus, every route alternative includes the proposed Briggs Road Substation and the potential impacts associated with that new large facility, which would replace several acres of agricultural land at one of two alternative sites.

In between these endpoints, the proposed and suggested route alternatives generally affect four basic impact areas, with some alternatives affecting more than one and some areas including more than one route alternative. Without ranking them, the four main areas of impact appear to be:

- The GRR area along the Mississippi River between Alma and the mouth of Waumandee Creek
- Woodlands, wetlands, and farms in the hill-and-valley country inland from the Mississippi River
- Concentrations of homes, particularly south of Galesville
- Black River bottomlands, including the Van Loon State Wildlife Area, an extraordinarily high-quality wetland riverine complex

WisDOT has expressed strong concerns about potential aesthetic impacts to GRR and potential violation of state scenic easements that it manages. WDNR has expressed strong concerns about potential impacts to the Van Loon wooded wetlands and rare species. Private landowners, homeowners, and farm operators have expressed concerns about potential impacts to the resources on their properties.

Table ES-4 summarizes some of the potential natural resource and social impacts for each of the nine route options and alternatives.

As shown in Table ES-4, the shortest of the route alternatives is the original Q1 Route, and the longest is the Arcadia Route with the Ettrick Connector. The route with the least need for new ROW is the original Q1 Route, while the route that would require the most new ROW is the Q1-Galesville Route with STH 88 Connector Option B. The Q1-Galesville and Arcadia alternatives are longer than the original Q1 Route or

Q1-Highway 35 alternatives. The Arcadia alternatives and the STH 88 Connector alternatives for the Q1 Routes would require more new ROW.

Table ES-4 Comparison of potential impacts among routes and alternatives

Route	Length (miles)	New ROW (acres)	Percent of ROW Length Shared	Agricultural Land Crossed (acres)	Number of Stream Crossings*	Wetland Area Affected (acres)	Wooded Wetland Crossed (acres)	Total Forest Area Cleared (acres)	Number of Residences within 300 Feet of the Centerline
Q1-Highway 35	43.0	404.4	94%	325.2	38	83.5	55.1	127.8	74
Q1-Highway 35 with STH 88 Connector A	49.7	509.2	90%	399.4	Unknown	109.0	69.1	176.7	79
Q1-Highway 35 with STH 88 Connector B	49.0	543.9	79%	417.9	Unknown	111.2	67.9	176.1	67
Q1-Galesville	48.4	497.0	79%	367.5	23	63.7	34.9	131.9	109
Q1-Galesville with STH 88 Connector A	55.0	601.8	78%	441.7	Unknown	60.7	38.1	180.8	114
Q1-Galesville with STH 88 Connector B	54.4	636.5	67%	460.2	Unknown	62.9	36.9	180.2	102
Q1 Original	41.3	377.1	96%	328.4	46	118.8	64.3	123.9	61
Arcadia	54.8	519.5	90%	445.3	42	95.6	38.8	161.1	102
Arcadia-Ettrick Connector	57.0	530.4	88%	468.0	63	142.9	56.9	175.4	57

* Stream data was not submitted in the CPCN Application for STH 88 Connector route segments.

Using Table ES-4, the routes can be compared in terms of the above-mentioned areas of impact.

- The Q1 Routes all follow the Q1 line along the Mississippi River and have the same effects on the Great River Road west of Waumandee Creek, while the others, including the Q1 Routes with STH 88 Connectors, do not.
- The original Q1 Route and the Q1-Highway 35 alternatives require the most wooded wetland clearing, while the Arcadia Route and Q1-Galesville alternatives require the least. Total woodland clearing would be greatest along the Q1-STH 88 and Arcadia-Ettrick Connector alternatives, while the original Q1 Route and utility-proposed Q1-Highway 35 and Q1-Galesville Routes would have the least total woodland cleared.⁵ The Arcadia Routes and the Q1-Galesville Route with an STH 88 Connector cross the most farmland, while the original Q1 Route and Q1-Highway 35 Route cross the least.
- The routes passing closest to the most homes would be the Q1-Galesville alternatives and the Arcadia Route.
- The original Q1 Route and the Q1-Highway 35 Route have direct impacts on the Black River (Van Loon) and its associated natural communities and rare species while the others would not.

⁵There is also the possibility of combining the original Q1 Route with an STH 88 Connector to avoid the Great River Road, but such a combination would likely have the maximum wooded wetland and total woodland impacts together.