


## Legalelectric, Inc.

Carol Overland Attorney at Law, MN #254617  
Energy Consultant—Transmission, Power Plants, Nuclear Waste  
overland@legalelectric.org

1110 West Avenue  
Red Wing, Minnesota 55066  
612.227.8638

P.O. Box 69  
Port Penn, Delaware 19731  
302.834.3466



September 25, 2015

Chuck Thompson, Manager  
Siting & Regulatory Affairs  
Dairyland Power Cooperative  
3200 East Avenue South  
La Crosse, WI 54602-0617

via email at [cat@dairynet.com](mailto:cat@dairynet.com)

Dennis Rankin  
Engineering and Environmental Analyst  
USDA RUS  
1400 Independence SW, Mailstop 1571  
Washington D.C., 20250-1571

via email at [dennis.rankin@wdc.usda.gov](mailto:dennis.rankin@wdc.usda.gov)

In Re: **SECOND NO CAPX 2020 COMMENT AND REQUEST FOR EXTENSION**  
Dairyland Power Cooperative Upgrade of Q-1D South, USDA RUS #1060

Dear Mr. Thompson and Mr. Rankin:

**ON BEHALF OF NO CAPX 2020, I AGAIN REQUEST THAT THE COMMENT PERIOD BE EXTENDED TO AT LEAST 30 DAYS FOLLOWING RELEASE AND PUBLICATION OF PROJECT INFORMATION AND ITS POTENTIAL IMPACTS.**

Once again, where is the additional information describing this project and its impacts available? I've not received any additional information from you on this project despite numerous requests. I specifically request the Application and all the Appendices, of which the Appendix A maps are obviously a part.

Regarding the Q-1D South project, on behalf of No CapX 2020, I offer the following comments:

### **Specifications and capacity of project**

Attached please find the MISO DPC: P7664 presentations and ACSS spec chart from the Xcel Energy SW MN 345 kV line Minnesota PUC Docket 01-1958. In these presentations, they consistently note that this project will use 795 ACSS, which show in this chart to have an ampacity rating in the 1600s and MVA in the 430s range. This rating is significantly higher than

the present line, and we have no information at this point of the limiting factor of capacity of this line. Based on this chart, the line will have a higher capacity, and will likely have higher electric fields and magnetic fields. Environmental review must consider electric and magnetic fields:

- The normal and emergency ratings for the differently spec'd segments of this project must be disclosed, expressed in ampacity and MVA.
- The range of electric fields and magnetic fields from a low capacity to the emergency rating must be disclosed and considered.
- The environmental document should disclose electric fields at various distances, ranging from the centerline to the easement edge to the point at which electric fields are reduced to 8 kV/meter (Minnesota standard), 5 kV/meter (IEEE guideline) and 4.2 kV/meter (ICNIRP, ACGIH, NRPB, EU guidelines).
- The environmental document should disclose magnetic fields at various distances, ranging from the centerline to the easement edge to the point at which fields are reduced to 4 mG and 2 mG. See MF chart attached, and independently verify calculations.
- The environmental document should disclose National Electric Safety Code safety requirements applicable to this project, particularly distances from homes and structures.
- The Applicant must disclose the normal and emergency rating, expressed in ampacity and MVA of the existing transmission line.
- Prior to de-energizing of the existing line, the Applicants must take baseline electric and magnetic field levels under "normal" operating conditions, and when the current line is loaded to its rated capacity.

The project will be very close to homes, based on the existing line routing and pole placement. Environmental review must consider proximity of the project to homes and businesses:

- The locations, by address, and distances for each home within 100 feet of the easement edge must be disclosed, including identification of homes within the easement, and for those homes within the easement, include the distance from the centerline.
- For each home within the easement, the distance from the centerline of the existing line must be disclosed.
- For each home within 100 feet of the edge of the easement, the date home was built and the local government responsible for permitting must be disclosed.

### **Rights of way and easements**

The project may require expanded easements or acquisition of additional land rights. For those homes and businesses sited with the existing line, there was actual or implied acceptance of the

existing line. The new line raises the capacity of the line and plans call for much higher towers. Environmental review for this project must consider impacts of a transmission line of a different character than the existing one. Environmental review must consider:

- Have landowners agreed to this change and been compensated for it? Provide documentation.
- For each location where centerline is within 100 feet of any residence or business, and where Applicant claims no additional easement is necessary, provide basis for such determination, and whether this distance is deemed safe by applicant and reviewers.
- For residences and businesses along the existing route, provide evidence of easements allowing rebuild. Note any and all easements that allow only for H-frame structures.
- For residences and business along the existing route, provide evidence of easements allowing for higher capacity conductors and taller structures.
- For each access road shown on “Appendix A” maps, provide documentation of easement allowing such use.
- What is the incremental impact on property valuation of this project with higher capacity and taller structures?
- What is the impact on marketability of properties affected by this transmission project?

#### **Justifications, need for the project, and rejections and approval by Wisconsin PSC**

Overloads of the 161 kV system was used as justification for construction and operation of the Badger Coulee project, and upgrade of the 161 kV system was also analyzed as an alternative to the Badger Coulee project and rejected.

To be NEPA compliant, the environmental review of this project must consider the need for this project, both in light of justification of Badger Coulee to solve problems in the 161 kV system, and in light of rejection of a 161 kV system upgrade as an alternative to Badger Coulee.

In the MISO MVP Project Portfolio, the 161 kV system was utilized as a justification for the Badger Coulee transmission project, where construction of the Badger Coulee “project will mitigate twelve bulk electric system (BES) NERC Category B thermal constraints and eight NERC Category C constraints. It will also relieve 30 non-BES NERC Category B and 36 NERC Category C constraints.” It is inconsistent to both build Badger Coulee and upgrade this project. The environmental review must consider impacts in light of this finding of mitigation:

- Where these constraints are eliminated by the Badger Coulee project, what is the justification for this project?
- The environmental review for this project must define and describe the need.

## 5.5 North LaCrosse to North Madison to Cardinal 345 kV Line




Figure 5.5: North LaCrosse to North Madison to Cardinal

Project(s): 3127

Transmission Owner(s): ATC, XEL

**Description:** This creates a 345 kV line from the North LaCrosse (Briggs Road) substation, to the North Madison substation, to the Cardinal substation, through southwestern Wisconsin. A 448 MVA, 345/161 kV transformer will be installed at Briggs Road, and approximately 20 miles of 138 kV line between the North Madison and Cardinal substations will be reconducted. The new 345 kV line will be approximately 157 miles long. The estimated cost is \$390 million<sup>14</sup>. The expected in service date is December 2018.

**Justification:** The 345 kV line from North LaCrosse to North Madison creates a tie between the 345kV network in western Wisconsin to the 345 kV network in southeastern Wisconsin. This creates an additional wind outlet path across the state; pushing power into southern Wisconsin, where it can go east into Milwaukee, or south to Illinois, providing access to less expensive wind power in two major load centers. With the Brookings project, the wind coming into North LaCrosse needs an outlet, and the line to North Madison is the best option studied. From a reliability perspective, the addition of the North LaCrosse to North Madison to Cardinal 345 kV path helps relieve constraints on the 345 kV system parallel to the project to the north and south of the new line. The 138 and 161 kV system in southwest Wisconsin and nearby in Iowa are also overloaded during certain contingent events, and the new line relieves those constraints. This project will mitigate twelve bulk electric system (BES) NERC Category B thermal constraints and eight NERC Category C constraints. It will also relieve 30 non-BES NERC Category B and 36 NERC Category C constraints.

### Alternatives Considered:

Rebuilding the overloaded 138 and 161 kV lines, along with adding transformers or upgrading the existing units to handle the increased loading, was the only other alternative considered. This was not a viable alternative, because the cost is greater than the proposed project. The proposed project also provides the most benefit to the transmission grid in the future.

In the Badger Coulee proceeding, MISO argued that Badger Coulee solved these overloads in testimony and in their brief. First, the testimony, that Badger Coulee relieves constraints on the 161 kV system:

1     A.     The Badger Coulee project helps relieve constraints on the 345 kV system parallel  
2           to the project to the north and south of the new line. The 138 kV and 161 kV  
3           systems in southwest Wisconsin are also overloaded during certain contingent  
4           events and the new line relieves these constraints. More specifically, the Badger  
5           Coulee project solves overloads near the 345 kV path from King to Werner West,  
6           and it also solves a number of overloads stretching down the southwest side of  
7           Wisconsin, from North La Crosse to Nelson Dewey.

Further testimony that Badger Coulee eliminates constraints on the 161 kV system:

16    **Q.     What are some key constraints mitigated by the Badger Coulee project?**

17    A.     The Badger Coulee project reduces loadings on approximately 60 highly loaded  
18           system elements, including lines and transformers, in and around Wisconsin,  
19           when the generation required to meet the renewable energy mandates of the  
20           MISO states is included in the model. The highest loaded Bulk Electric System  
21           (“BES”) elements that experienced violations under Category B conditions are  
1           listed below. A full list of these overloads may be found in Appendix E4 of  
2           MTEP 11 (attached as Exhibit 2 to this testimony).<sup>14</sup>

- 3           •     Werner – Rocky Run 345 kV line
- 4           •     North La Crosse – Mayfair 161 kV line
- 5           •     North La Crosse – La Crosse Tap 161 kV line
- 6           •     Seneca – Genoa 161 Kv line
- 7           •     Hydro Lane 161 / 115 kV transformer
- 8           •     Arpin 345 / 138 kV transformer
- 9           •     Adams 345 / 161 kV transformer

MISO Rauch Direct Testimony, p. 27-28, Badger Coulee WI PSC Docket 05-CE-142.

And in MISO's Initial Brief in the Badger Coulee docket, this same chart including the "North La Crosse – La Crosse Tap 161 kV line (Q-1D South):

Upon the completion of the extensive, multi-year planning process, MISO determined that the Project is necessary to meet transmission needs in the area.<sup>23</sup> As stated by MISO Witness Rauch, "the Badger Coulee project solves overloads near the 345 kV path from King to Werner West, and it also solves a number of overloads stretching down the southwest side of Wisconsin, from North La Crosse to Nelson Dewey."<sup>24</sup> Ms. Rauch testified.<sup>25</sup>

The highest loaded Bulk Electric System ("BES") elements that experienced violations under Category B conditions are \* \* \*

- Werner – Rocky Run 345 kV line
- North La Crosse – Mayfair 161 kV line
- North La Crosse – La Crosse Tap 161 kV line
- Seneca – Genoa 161 Kv line
- Hydro Lane 161 / 115 kV transformer
- Arpin 345 / 138 kV transformer
- Adams 345 / 161 kV transformer"

Because sworn testimony states that Badger Coulee addresses these problems, the environmental review for this project must address the need for this project in light of MISO statements that the Badger Coulee project solves overloads and contingency issues on the 161 kV system. If the problems are solved, why is it needed?

Conversely, rebuild of the 161 kV system was considered as an alternative to the Badger Coulee transmission project and rejected. Because Badger Coulee was selected as the preferred alternative to rebuild of the 161 kV system, the environmental review must consider the need for this project in light of rejection of rebuild of the 161 kV system as an alternative:

In addition, the MISO evaluated a system alternative comprised of rebuilding overloaded 138 and 161 kV lines, along with upgrading existing transformers and adding others. The alternative was not carried forward because the costs exceeded that of the Project and provide less benefit to the transmission grid.<sup>1</sup>

<sup>1</sup> MISO Multi Value Project Portfolio Results and Analyses (Jan. 10, 2012), p. 28

Badger Coulee Revised App. (redlined), p. 30. MISO MVP Portfolio had a similar analysis (§5.5 , supra p. 4 above):

#### **Alternatives considered:**

Rebuilding the overloaded 138 and 161 kV lines, along with adding transformers or upgrading the existing units to handle the increased loading, was the only other alternative considered. This was not a viable alternative, because the cost is greater than the proposed project. The proposed project also provides the most benefit to the transmission grid in the future.



If it's rejected by the WI PSC, MISO and Applicants as an alternative, the need must be demonstrated as viable and cost effective, particularly given MISO's cost concerns.

Because the Wisconsin PSC rejected rebuild and upgrade of the 161 kV system in the Badger Coulee docket, the environmental review for this project must address the need for this project in light of that rejection and explain why it should now be done anyway.

The Wisconsin PSC refused to address need information before it that would have an impact on the Q-1 line and its inclusion as part of CapX 2020 Hampton-La Crosse transmission line. This was part of Dairyland's Chuck Thompson's testimony in that docket in Wisconsin. See PUC Docket 05-CE-135.

Dairyland has announced that it is shutting down three coal-burning units at the Alma plant. However, these retirements have not been addressed regarding the impacts on Dairyland's Q-1 transmission line as part of the project. Thompson, Vol. 2, p. 168-170. The Q-1 is not the only transmission line to LaCrosse and Western Wisconsin – there are at least four transmission lines from Minnesota crossing the Mississippi to Wisconsin, including lines near Alma, Winona, Trempealeau and LaCrosse. USFWS 5/4/09 Letter to Hillstrom, NoCapX/CETF Item 21, ERF 161182. There is no information in the record supporting need for a rebuild of the Q-1, only that it is something that Dairyland wants. Based on the record in this proceeding, there is no basis for Commission approval of the Q-1 line.

No CapX 2020 Initial Brief, March 30, 2012, WI PSC Docket 05-CE-136; see also attached Direct Testimony of Chuck Thompson, Tr. Vol. 2, p. 167-178. The Q-1 rebuild was not included as part of the PSC's approval of the CapX 2020 Hampton – La Crosse line in Wisconsin.

### **USDA Rural Utilities Service financing**

USDA's RUS may finance this project. The environmental review should address:

- Cost – specific line item costs.
- Cumulative cost of all the Q-1 projects, from Alma to Genoa, including those funded by USDA RUS and otherwise.
- Percentage interest to be paid to Rural Utilities Service or other loan servicing entity on behalf of RUS.

- Return on investment – the percentage ROI should be disclosed. ROI for all USDA Dairyland projects should be included in the environmental review, and the cumulative ROI should be compared to Dairyland’s rate base and other revenue streams, and evaluated as a driver of these projects and as a percentage of Dairyland’s revenue.
- Project must be evaluated for need beyond that of a revenue source based on FERC approval of MISO tariffs for return on investment for transmission at over 12%. Utilities in the project area have requested, and received, substantial rate increases recently that are driven by capital projects including the CapX 2020 build-out and the MISO MVP 17 Project Portfolio. Economic considerations alone are not a sufficient basis for approval of any transmission project paid for by ratepayers and with impacts to residents, businesses, and landowners.
- The environmental review should disclose the authority authorizing that rate of return should be disclosed, and if FERC, the docket number should be disclosed, and if a MISO or other tariff, a link to the tariff.

### **Topics raised in “Public Notice” for project**

The “notice” suggested some topics at issue for comment, naming them, but going no further to describe the relationship between the project and these topics. The environmental review should address:

#### **Prime Farmland**

- Whether project takes productive farmland out of production.
- Impacts on ag operations, including irrigation or airplane flight paths for spraying.
- Construction impacts such as compaction, damage to drain tile and drainage systems.
- Access road impacts and whether applicant has right to build access roads under existing easements.
- Impacts on marketability and value of prime farmland.
- Potential for conflict of interest between USDA’s mission and Rural Utilities Service funding of transmission over prime farmland.

#### **100 year Floodplain**

- Impacts on floodplain, and also the opposite, floodplain impacts on the project.
- Anticipated impacts are release of leachate from the structure foundations, and stability of foundations in the floodplain.



- Soil and water conditions need to be addressed to assure it is possible and safe to build as planned (and not yet disclosed).
- Access to the structure site and the stringing activities could damage the area.

**Wetlands** (as with floodplain)

- Impacts on wetlands, and also the opposite, wetland impacts on the project.
- Anticipated impacts are release of leachate from the structure foundations, and stability of foundations in the wetlands.
- Soil and water conditions need to be addressed to assure it is possible and safe to build as planned (and not yet disclosed).
- Access to the structure site and the stringing activities could damage the area.
- Impacts on habitat for animals, and particularly consideration protected species in the wetlands. Address both project and construction impacts, and whether presence of protected species require restrictions on construction.
- Impacts that will be considered in review for any state permits. The line exists now, but is it permissible and constructable as proposed (and as yet undisclosed)?
- Impacts of construction activity, including both access road construction and use.
- Impacts of construction that necessitate a season or condition based activity restriction, i.e., can only build when ground is frozen.

**State law prohibits construction underneath transmission lines – what about new rebuilds over existing homes?**

This project goes over a route that is subject to a state law enacted after homes were built under and near a transmission line, and the law now prohibits that construction. The environmental review should consider impacts of this project on those homes under and near the line and whether in 2015 this construction and its impacts should be allowed.

Further, because of this law, the environmental review should consider whether this transmission line should be moved from its present location to an area where there would not be homes under the project.

**Permits required for this project**

The environmental review should list and consider the permits and approvals necessary for this project, and should address the factors that will be considered by federal, state, and local governments and agencies.

### **Eagle take permit**

The environmental review for this project should consider potential impacts on eagles due to its location in a major North American flyway and increased height. USFWS recommended that CapX 2020 transmission applicants get an eagle take permit. I believe this is also true of the Badger Coulee line. USFWS review should be solicited and its recommendations made public for comment.

### **No Build Alternative and Analysis**

The environmental review must consider the “No-Build Alternative” for compliance with NEPA.

### **Alternatives – System Alternatives and Route Alternatives**

The environmental review must consider alternatives. As to routing alternatives, I am not sufficiently familiar with the area to propose routing alternatives. Local residents should be offered opportunity to suggest alternatives for analysis by RUS.

The environmental review must consider alternatives. As to system alternatives:

- Evaluate removal of the link between Briggs Road as duplicative and unnecessary. For example, because CapX 2020 comes down to Briggs Road, and Badger Coulee runs north from Briggs Road, it may be possible to eliminate the Q-1 161 kV connection completely.
- Evaluate connection of the Genoa northward section of Q-1 to the large new substation south of I-90 and east of La Crosse.
- Evaluate impacts of shut down of Alma coal, Genoa coal, and Cassville coal on need for the connection between these plants and La Crosse.
- Evaluate impact continued operation of the La Crosse 3 generator on need for Q-1. This was a deciding factor in approval of CapX 2020, which claimed the La Crosse generator was not operational, and it was correctly noted that an operational Unit 3 would bring available generation to an acceptable level:

The applicants did not consider French Island Units 3 and 4 as available resources in the critical load limit analysis. Although NSPW has allocated \$1.9 million for the repair of the mothballed French Island Unit 3 in order to make it operational, this repair is neither scheduled nor planned with certainty. French Island Unit 4 has numerous operational problems which result in its reduced availability. If French Island Unit 3 is included, the critical load limit could increase to 500 MW calculated consistent with NERC standards.

PSC Final Order p. 22, Wisconsin PSC Docket 05-CE-136 (5/30/2012).

Shortly thereafter, Xcel Energy Resource Plans disclosed that in fact this plant would be returned to service. Xcel Energy Integrated Resource Plan, MPUC Docket 12-1240. The Q-1 line, and specifically Q-1D South, may not be needed.

Environmental Review should evaluate whether this line is needed in light of purpose of Q-1 as transmission for generation to La Crosse, and of available generation in La Crosse and shuttered generation on both the north and southern ends of the line.

### **Increased tower height**

Environmental review must consider:

- Impact of increased tower height on electric and magnetic fields.
- Impact of increased tower height on airport operation, and take off and landing clearances and zones.
- Impact of increased tower height on compliance with local airport overlay regulation.
- Impact of increased tower height on viewshed and aesthetics.

### **Segmentation**

The environmental review must address:

- Cumulative environmental impacts of all of the Q-1 upgrades, not just this one small segment.
- The cumulative environmental impacts for all Q-1 upgrades, whether financed by USDA RUS or otherwise, should be considered.
- Under NEPA, segmentation of projects is not appropriate, for example, in this case, Dairyland has separated out the project with the most extreme environmental impacts to close residents and directly affected landowners into a nine mile segment that may not receive the same environmental review that it would had it been included as part of the USDA RUS financed Marshland-Briggs Road segment.

### **Environmental Review should incorporate issues raised for Q-1 Marshland – Briggs Rd.**

Because these are parts of one longer project, traversing similar areas, and presuming project similarities, the environmental review should address:

- Issues reviewed in the USDA RUS EIS for Dairyland's Q-1 line from Marshland to Briggs Road substation.
- For environmental concerns not relevant to this project, that should be specifically noted.

### **RUS authority, mission, and criteria for grant of loans**

Environmental review, as published, should begin with disclosure, an explanation of, and citations for the RUS authority to loan funds for rebuild of facilities such as the Dairyland Q-1 line, a demonstration that this project loan falls within the mission of the RUS, and specific itemization of criteria for the RUS determination of whether to provide funds for this project. Each of these areas should be accompanied by citations to authority.

### **Request for Information**

Again, please forward information about this project at your earliest convenience, and post it online for the public to access. I will also post this information, if and when received, on my No CapX 2020 website.

On behalf of No CapX 2020, I have filed a FOIA request, but that is not likely to result in any information anytime soon.

### **Request for Extension**

**ON BEHALF OF NO CAPX 2020, I AGAIN REQUEST THAT THE COMMENT PERIOD BE EXTENDED TO AT LEAST 30 DAYS FOLLOWING RELEASE AND PUBLICATION OF PROJECT INFORMATION AND ITS POTENTIAL IMPACTS.**

Thank you for the opportunity to Comment on this project and for your attention to these matters.

Very truly yours,



Carol A. Overland  
Attorney at Law

Enclosures: Notice  
MISO meeting presentations (selected pages)  
Exhibit 35, Appendix 7 of NSP/Xcel Application MPUC Docket 01-1958  
Calculated Magnetic Fields – chart prepared by P.E. for CapX Brookings  
MISO Rauch Direct Testimony & Initial Brief (selected pages)  
Testimony of Thompson, CapX Hampton – La Crosse 05-CE-136 (selected)




Derendants,  
By virtue of and pursuant to  
a Judgment of Foreclosure entered  
in the above-entitled action on the  
twenty-fourth day of March, 2015, I  
will sell at public auction in the lobby  
of the La Crosse County Court-

Sale.  
Date at La Crosse, Wisconsin,  
this thirtieth day of March, 2015  
8/28,9/4,11 30394309 WNAXLP

### PUBLIC NOTICE

Dairyland Power Cooperative, 3200 East Avenue South, La Crosse, WI 54602-0817, is planning to rebuild approximately nine miles of 161 kilovolt transmission line in La Crosse County, the Q-1D South Project, near the Village of Holmen. It has been determined that the Project, as proposed, will be located in a prime farmlands, 100-year floodplain, and wetlands. The Project will occupy 100.8 square feet of prime farmland, 0.09 acres of 100-year floodplain, and 37.8 square feet of wetlands.



Dairyland Power Cooperative has considered a variety of alternatives, including no action, and believes that there is no practicable alternative that will avoid locating the Project in prime farmlands, 100-year floodplains, and wetlands. Additional information on the project can be obtained from Chuck Thompson at the address provided in this notice or by telephoning (608) 787-1432.

Comments on the environmental aspects of the project should be submitted in writing to Dairyland Power Cooperative within 30 days of the publication of this notice. Copies of all comments received will be forwarded to the Rural Utilities Service for consideration prior to approval of financing assistance or taking other Federal action related to the Project.

8/28 30394422 WNAXLP

From: Autumn Rose Bar  
To: Autumn Rose Holt-B  
Birth Certificate:  
Autumn Rose Bartelson  
IT IS ORDERED:  
This petition will be h  
Circuit Court of La Cro  
State of Wisconsin:  
Judge: Todd W. Bjerke  
Place: La Crosse Count  
Courthouse 333 Vine St  
La Crosse, WI 54601  
Date: 09/21/2015  
Time 10:45 a.m.  
BY THE COURT:  
/s/ Todd W. Bjerke  
Circuit Court Judge  
Dated: 08/11/2015  
8/14,21,28 30390164 V

### STATE OF WISC CIRCUIT COU LA CROSSE CO Notice to Cred (Informal Admini Case NO.: 15-P

In the matter of the es  
Glen M. Newkirk

PLEASE TAKE NOTIC

1. An application for  
ministration was filed.

2. The decedent, with  
05/22/1948 and d  
01/04/2015, was dor  
Crosse County, State  
with a mailing address  
Street, Onalaska, WI 54

3. All interested pe  
notice.

4. The deadline for  
against the deceder  
11/06/2015.

5. A claim may be  
Crosse County Co  
Vine Street, La Crosse  
Room 1201.

/s/ Jillian M. Just  
Probate Registrar

Dated: 08/03/2015  
Form completed by:

Lee J. Fehr  
Fehr Law Office

205 Green Street  
Onalaska, WI 54650

PH: 608-783-3647  
Bar No.: 1015079

8/14,21,28 3038997

books records tea kettle bicycle cards





A large, faint, light-gray graphic is positioned on the left side of the slide. It consists of a semi-circle at the top, from which several wedge-shaped segments radiate downwards, resembling a stylized sunburst or a fan. Below the semi-circle, there are several diamond-shaped segments arranged in a row.

# **American Transmission Company MTEP15 Project Information**

1st West Sub-regional Planning Meeting

December 3, 2014

A large, faint, light-gray graphic is positioned on the left side of the slide. It consists of a semi-circle at the top with several triangular segments radiating from a central point, resembling a stylized sun or a fan. Below this, there are several diamond-shaped segments arranged in a pattern that suggests a landscape or a network.


# **Dairyland Electric Cooperative MTEP15 Project Information Projects Targeting A in MTEP15**

1st West Sub-regional Planning Meeting

December 3, 2014

# DPC: P7664

- **Rebuild Briggs Road-La Crosse Tap 161 kV**
  - Rebuild the Briggs Road-La Crosse Tap 161 kV line on the existing ROW
  - Replace poles
  - Install 795 ACSS conductor
- **Estimated Cost \$12.1M**
- **Expected ISD 2016 June**
- **Preliminary Project Type**
  - Other Reliability
- **System Needs**
  - The line is 62 years old, experiencing increased maintenance costs due to it's age, and needs replacement.





A large, faint, light gray graphic is positioned on the left side of the slide. It consists of a semi-circle at the top, from which several triangular rays emanate downwards, resembling a stylized sun or a fan. Below the semi-circle, there are several diamond-shaped elements arranged in a pattern.

# **MISO Identified Potential Issues under Evaluation**

2<sup>nd</sup> West Sub-regional Planning Meeting  
May 19, 2015




A large, faint, light gray logo is visible in the background on the left side of the slide. It consists of a semi-circle at the top with several triangular segments radiating from a central point, and a larger, more complex geometric shape below it, resembling a stylized sun or a flower.

# **Dairyland Power Cooperative Review of reliability projects under consideration**

2<sup>nd</sup> West Sub-regional Planning Meeting  
May 19, 2015

# DPC: P7664

- **Rebuild Briggs Road-La Crosse Tap 161 kV**
  - Rebuild the Briggs Road-La Crosse Tap 161 kV line on the existing ROW
  - Replace poles
  - Install 795 ACSS conductor
- **Estimated Cost \$12.1M**
- **Expected ISD 2016 June**
- **Preliminary Project Type**
  - Other Reliability
- **System Needs**
  - The line is 62 years old, experiencing increased maintenance costs due to its age, and needs replacement.





A large, faint, light-gray logo is centered in the background. It consists of a semi-circle at the top with several triangular segments radiating from a central point, and a larger, more complex geometric shape below it, resembling a stylized sun or a compass rose.

# **American Transmission Company MTEP15 Project Review**

3rd West Sub-regional Planning Meeting  
July 27, 2015

A large, faint, light-gray graphic is positioned on the left side of the slide. It consists of a semi-circle at the top, from which several wedge-shaped segments radiate downwards, resembling a stylized sunburst or a fan. Below the semi-circle, there are several diamond-shaped segments arranged in a pattern that suggests a larger circular or spherical structure.

# **ATC Recommended Appendix A in MTEP15 Projects**

Updated since SPM2

A large, faint, light-gray graphic is positioned on the left side of the slide. It consists of a semi-circle at the top, from which several wedge-shaped segments radiate downwards, resembling a stylized sunburst or a fan. Below the semi-circle, there are several diamond-shaped segments arranged in a pattern that suggests a larger circular or spherical structure.

## **ATC Recommended Appendix A in MTEP15 Projects**

No Update since SPM2




A large, faint, light gray logo is visible in the background on the left side of the slide. It consists of a semi-circle at the top with several triangular segments radiating from a central point, and a larger, more complex geometric shape below it, resembling a stylized sun or a flower.

# **Dairyland Power Cooperative Review of reliability projects under consideration**

3<sup>rd</sup> West Sub-regional Planning Meeting  
June 27, 2015

# DPC: P7664

- **Rebuild Briggs Road-La Crosse Tap 161 kV**
  - Rebuild the Briggs Road-La Crosse Tap 161 kV line on the existing ROW
  - Replace poles
  - Install 795 ACSS conductor
- **Estimated Cost \$12.1M**
- **Expected ISD 2016 June**
- **Preliminary Project Type**
  - Other Reliability
- **System Needs**
  - The line is 62 years old, experiencing increased maintenance costs due to its age, and needs replacement.





## Computation of SAC Overhead Conductor Ampacities

(Steady State)

Per ANSI/IEEE Standard 738-1986

	Wind speed	ml/hr	ft/s		Temperature				
		1.38	2.00		C	F			
	Coefficient of emissivity		0.5	Ambient air temp	40	104	Latitude	45 degrees N	
	Coefficient of solar absorption		0.5	Conductor surface temp	200	392	Azimuth of line	90 degrees	
							Elev above msl	1000 ft	
	Air viscosity @ T ave		0.05463	lb/h ft					
	Air density		0.05403	lb/ft <sup>3</sup>					
	Air thermal conductivity		0.0101	W/ft C					
	Altitude of sun		68.1	degrees					
	Azimuth of sun		180	degrees					
	Heat rec'd by a surface		94.64	W/ft <sup>2</sup>					
	Elevation correction factor		1.0340						

Conductor			Resistance, Ohm/ml			Ohm/kft	Conductor heat transfer, W/ft					Ampacity kV: cond/ph:	MVA rating @ nominal voltage							kcm
kcm	strand	diam, in	50 deg C	100 deg C	200 deg C		Forced convection heat loss			Radiated heat loss	Solar heat gain		69	115	138	161	230	345	500	
							qc1	qc2	max				1	1	1	1	1	2	3	
4/0	6/1	0.583	0.5920	0.6979	0.9097	0.17229	48.46	39.77	46.46	15.72	2.30	590	70	117	141	164				4/0
268	6/7	0.633	0.5520	0.6507	0.8481	0.16063	49.28	42.67	49.28	17.67	2.58	633	78	128	151	177				268
336	18/1	0.684	0.3059	0.3606	0.4700	0.08902	51.24	44.70	51.24	19.09	2.79	871	104	174	208	243				336
336	26/7	0.721	0.3072	0.3623	0.4725	0.08949	52.62	46.14	52.62	20.13	2.94	883	106	176	211	248				336
477	28/7	0.858	0.2169	0.2557	0.3333	0.08313	57.44	51.21	57.44	23.95	3.50	1111	133	221	266	310				477
477	24/7	0.848	0.2168	0.2556	0.3332	0.08311	57.04	50.78	57.04	23.62	3.45	1106	132	220	264	308				477
556	26/7	0.927	0.1860	0.2192	0.2856	0.05409	59.73	53.65	59.73	25.88	3.78	1230	147	245	294	343				556
636	24/7	0.977	0.1631	0.1922	0.2504	0.04742	61.34	55.37	61.34	27.27	3.98	1336	160	266	319	373	532			636
795	28/7	1.108	0.1306	0.1538	0.2002	0.03792	65.38	59.71	65.38	30.93	4.52	1556	186	310	372	434	620	1860	4042	795
795	45/7	1.115	0.1313	0.1544	0.2006	0.03799	65.59	59.93	65.59	31.13	4.55	1556	186	310	372	434	620	1861	4047	795
795	30/19	1.140	0.1307	0.1540	0.2006	0.03799	66.33	60.74	66.33	31.82	4.65	1569	187	312	375	437	625	1875	4076	795
954	45/7	1.185	0.1099	0.1291	0.1675	0.03172	67.06	61.53	67.06	32.52	4.75	1729	207	344	413	482	689	2068	4492	954
954	54/7	1.196	0.1094	0.1287	0.1673	0.03169	67.96	62.51	67.96	33.39	4.88	1745	209	348	417	487	695	2085	4533	954
1192	54/19	1.338	0.0863	0.1013	0.1313	0.02487	71.95	66.88	71.95	37.35	5.46	2044	244	407	488	570	814	2442	5309	1192
1272	54/19	1.382	0.0851	0.0996	0.1286	0.02436	73.14	68.17	73.14	38.58	5.63	2087	249	416	499	582	831	2494	5422	1272
1590	54/19	1.545	0.0857	0.0787	0.0987	0.01869	77.41	72.89	77.41	43.13	6.30	1472	295	492	591	689	985	2954	6423	1590
2312	76/19	1.802	0.0505	0.0584	0.0742	0.01405	83.72	79.94	83.72	50.30	7.35	3002	359	598	718	837	1198	3588	7800	2312

## Notes:

Sun computations based on noon local sun time

Solar absorption based on "Clear atmosphere"

Azimuth of line: N-S = 0, E-W = 90

Xcel Energy

Delivery System Planning &amp; Engineering



# ADJUSTABLE TABLE

TABLE 5.2-6. Calculated Magnetic Fields (milligauss) for proposed double circuit 345 kV Transmission Line Designs  
(3.28 feet above ground)

STRUCTURE TYPE	SYSTEM CONDITION	CURRENT (AMPS)	DISTANCE TO PROPOSED CENTERLINES												
			-300'	-200'	-100'	-75'	-50'	-25'	0'	25'	50'	75'	100'	200'	300'
1 CIRCUIT DELTA CFG	PEAK	1568.95	4.69	9.92	33.40	51.70	85.34	139.36	189.52	176.86	106.50	60.56	37.20	9.81	4.28
	AVERAGE	301.58	0.90	1.91	6.41	9.94	16.42	26.78	36.42	33.99	20.48	11.64	7.16	1.89	0.82
1 CIRCUIT VERT CFG	PEAK	1568.95	5.11	11.71	42.31	65.97	107.98	163.14	151.84	95.33	58.60	38.09	26.27	8.80	4.22
	AVERAGE	301.58	0.99	2.25	8.13	12.69	20.75	31.36	29.18	18.32	11.26	7.33	5.04	1.68	0.80
2 CIRCUIT W/ 1 CKT ACTIVE	PEAK	1568.95	4.22	8.80	26.33	38.21	58.78	95.62	152.26	163.43	108.04	65.97	42.25	11.71	5.11
	AVERAGE	301.58	0.82	1.70	5.06	7.35	11.30	18.38	29.26	31.42	20.77	12.67	8.11	2.25	0.99
2 CIRCUIT W/ 2 CKTS ACTIVE	PEAK	1568.95	1.13	3.45	19.73	36.13	71.08	136.09	178.47	137.05	71.91	36.67	20.15	3.51	1.13
	AVERAGE	301.58	0.21	0.67	3.80	6.95	13.67	26.17	34.30	26.34	13.82	7.06	3.87	0.67	0.23

ENTER MVA BELOW TO  
ADJUST CURRENT IN THE TABLE

437.00 MVA PEAK

161.00 kV

1.73 3 Phase

1568.95 Amps PEAK CALC'D

84.00 MVA AVERAGE

161.00 kV

1.73 3 Phase

301.58 Amps AVERAGE CALC'D






The new 345 kV path through Iowa mitigates constraints seen on the Lime Creek – Emery – Floyd – Bremer – Black Hawk 161 kV line. The 345/161 kV transformers at Lime Creek and Emery are effectively acting as step-up transformers for wind and lowering congestion on the lower voltages. The additional 345 kV path into Hazleton significantly increases the transfer capability of the Mitchell County – Hazleton 345 kV line. Working in tandem with project 3205, this project reliably moves mandated renewable energy from western and northern Iowa along with existing wind at the Winnebago, Wisdom and Lime Creek/Emery areas to major 345 kV transmission hubs.

#### Alternatives Considered:

An Iowa alternative of Lakefield Junction to Mitchell County and Sheldon to Burt to Webster to Black Hawk to Hazleton 345 kV was analyzed but was not effective in collecting Lime Creek/Emery area wind or lowering congestion on the Mitchell County to Hazleton 345 kV line. It had similar cost to the combined Iowa projects 3205 and 3213.

## 5.5 North LaCrosse to North Madison to Cardinal 345 kV Line



**Figure 5.5: North LaCrosse to North Madison to Cardinal**

**Project(s):** 3127

**Transmission Owner(s):** ATC, XEL

**Description:** This creates a 345 kV line from the North LaCrosse (Briggs Road) substation, to the North Madison substation, to the Cardinal substation, through southwestern Wisconsin. A 448 MVA, 345/161 kV transformer will be installed at Briggs Road, and approximately 20 miles of 138 kV line between the North Madison and Cardinal substations will be reconducted. The new 345 kV line will be approximately 157 miles long. The estimated cost is \$390 million<sup>14</sup>. The expected in service date is December 2018.

<sup>14</sup> In 2011 dollars

**Justification:** The 345 kV line from North LaCrosse to North Madison creates a tie between the 345kV network in western Wisconsin to the 345 kV network in southeastern Wisconsin. This creates an additional wind outlet path across the state; pushing power into southern Wisconsin, where it can go east into Milwaukee, or south to Illinois, providing access to less expensive wind power in two major load centers. With the Brookings project, the wind coming into North LaCrosse needs an outlet, and the line to North Madison is the best option studied. From a reliability perspective, the addition of the North LaCrosse to North Madison to Cardinal 345 kV path helps relieve constraints on the 345 kV system parallel to the project to the north and south of the new line. The 138 and 161 kV system in southwest Wisconsin and nearby in Iowa are also overloaded during certain contingent events, and the new line relieves those constraints. This project will mitigate twelve bulk electric system (BES) NERC Category B thermal constraints and eight NERC Category C constraints. It will also relieve 30 non-BES NERC Category B and 36 NERC Category C constraints.

#### Alternatives Considered:

Rebuilding the overloaded 138 and 161 kV lines, along with adding transformers or upgrading the existing units to handle the increased loading, was the only other alternative considered. This was not a viable alternative, because the cost is greater than the proposed project. The proposed project also provides the most benefit to the transmission grid in the future.

## 5.6 Dubuque to Spring Green to Cardinal 345 kV Line




Figure 5.6: Dubuque to Spring Green to Cardinal

**Project(s):** 3127

**Transmission Owner(s):** ATC, ITCM

**Description:** A 345 kV line is created from the Dubuque substation in Iowa, to the Spring Green substation to the Cardinal substation through southwestern Wisconsin. A new Dubuque County 345 kV switching station will be created, and the Spring Green substation will be upgraded to



1 A. The Badger Coulee project helps relieve constraints on the 345 kV system parallel  
2 to the project to the north and south of the new line. The 138 kV and 161 kV  
3 systems in southwest Wisconsin are also overloaded during certain contingent  
4 events and the new line relieves these constraints. More specifically, the Badger  
5 Coulee project solves overloads near the 345 kV path from King to Werner West,  
6 and it also solves a number of overloads stretching down the southwest side of  
7 Wisconsin, from North La Crosse to Nelson Dewey.

8 **Q. Does MISO have additional steady state concerns related to electric**  
9 **reliability in areas outside Wisconsin that the Badger Coulee project will also**  
10 **address?**

11 A. Yes. Without the Badger Coulee project, the west to east flows overload  
12 components of the 161 kV network stretching down from Minnesota into Iowa.  
13 More specifically, the project alleviated thermal constraints near the Adams  
14 substation in Minnesota, and it also helped to resolve constraints on the 161 kV  
15 network between Emery and Blackhawk in Iowa.

16 **Q. What are some key constraints mitigated by the Badger Coulee project?**

17 A. The Badger Coulee project reduces loadings on approximately 60 highly loaded  
18 system elements, including lines and transformers, in and around Wisconsin,  
19 when the generation required to meet the renewable energy mandates of the  
20 MISO states is included in the model. The highest loaded Bulk Electric System  
21 (“BES”) elements that experienced violations under Category B conditions are

1 listed below. A full list of these overloads may be found in Appendix E4 of  
2 MTEP 11 (attached as Exhibit 2 to this testimony).<sup>14</sup>

- 3 • Werner – Rocky Run 345 kV line
- 4 • North La Crosse – Mayfair 161 kV line
- 5 • North La Crosse – La Crosse Tap 161 kV line
- 6 • Seneca – Genoa 161 Kv line
- 7 • Hydro Lane 161 / 115 kV transformer
- 8 • Arpin 345 / 138 kV transformer
- 9 • Adams 345 / 161 kV transformer

10 **Q. What contingencies resulted in the steady state issues relieved by the Badger**  
11 **Coulee project?**

12 A. Approximately 55 Category B and 60 Category C contingencies resulted in issues  
13 that are relieved by the incorporation of the Badger Coulee project into the  
14 transmission system. Key Category B contingencies included the loss of the line  
15 from Eau Claire to Arpin or Arpin to Rocky Run. Violations were also observed  
16 for single element contingencies on the path from La Crosse to Nelson Dewey,  
17 along the western side of Wisconsin.

18 **Q. Were there other reliability benefits that resulted from the MVP portfolio in**  
19 **the aggregate?**

20 A. Yes. Each project in the portfolio mitigated specific overloads across the MISO  
21 footprint. In addition, the portfolio as a whole mitigated more than 30 conditions  
22 that could cause system instability, as documented in Appendix E4 of the MTEP  
23 11 report. The MVP portfolio also increased transfer capability before voltage

---

<sup>14</sup>A copy of Appendix E4 of the MTEP 11 report is attached to this testimony and also  
publically available on the MISO website, at the link below:  
<https://www.misoenergy.org/Library/Pages/ManagedFileSet.aspx?SetId=694>



1 EXAMINER NEWMARK: Okay. Redirect?

2 MS. AGRIMONTI: No, Your Honor.

3 EXAMINER NEWMARK: You're excused.

4 Thanks.

5 (Witness excused.)

6 MS. AGRIMONTI: Mr. Thompson.

7 EXAMINER NEWMARK: Just keep them coming.

8 MS. AGRIMONTI: At some point I will beg  
9 for a five-minute break.

10 EXAMINER NEWMARK: You can try.

11 CHARLES THOMPSON, APPLICANTS WITNESS, DULY SWORN

12 DIRECT EXAMINATION

13 BY MS. AGRIMONTI:

14 Q Mr. Thompson, would you please state your name,  
15 position and responsibilities.

16 A My name is Chuck Thompson. I work for Dairyland  
17 Power Cooperative. I am responsible for getting  
18 regulatory permits in four states where we operate  
19 for transmission lines, substations, communication  
20 towers.

21 Q And did you prepare direct testimony and an exhibit  
22 for this proceeding?

23 A Yes, I did.

24 Q And do you have copies of those in front of you?

25 A I do.



1 Q And are they true and correct copies of what you  
2 filed here?

3 A They are.

4 MS. AGRIMONTI: Mr. Stevenson is -- Mr. --  
5 one of the Mr. Thompsons is available for cross.

6 EXAMINER NEWMARK: Cross-exam. Go ahead.

7 CROSS-EXAMINATION

8 BY MS. OVERLAND:

9 Q And is it correct that -- I want to make sure I have  
10 all the exhibits. Do you only have the Exhibit 1  
11 which is the Dairyland Power Q1 rebuild technical  
12 memorandum exhibit?

13 A That's correct.

14 Q That's it. And there's no 2, 3, 4, 5, 10 --

15 A No.

16 Q -- 20? One second. I want to clarify. Is it  
17 correct that if the Q1 rebuild is not completed, that  
18 Dairyland would not be a part of this project?

19 A No, that's not correct. We initially got involved in  
20 the beginning of the project back in 2005 and 2006.  
21 Dairyland originally had started the planning study  
22 back then. And so we have been a member of the  
23 project since it started.

24 Q Is it correct that three of the units at the Alma  
25 plant will be shutting down?

1 A That's correct. The three smallest units.

2 Q Okay. And as it stands now, the project as proposed,  
3 there is no substation -- it does not connect at the  
4 Alma area, correct? It just goes through?

5 A That's correct.

6 Q So if the three -- if three of the units may be  
7 shutting down, what is the need for the Alma rebuild?

8 A The Alma rebuild, the Q1 line goes from Alma to  
9 Genoa, it was built back in 1950. We divided it up  
10 in three segments based on trying to rebuild that  
11 project. The line from North La Crosse with the  
12 Briggs Road substation to Alma, that line serves the  
13 City of Winona. There is a substation called  
14 Marshland, it is a primary source for that. It also  
15 serves Riverland Electric. They have customers off  
16 of that substation also.

17 Q But the Q1 line extends from Alma through Marshland  
18 down to La Crosse, correct?

19 A Correct.

20 Q And if there isn't the power coming out of Alma, the  
21 plant, where is the power coming from that will be on  
22 that line?

23 A The Alma plant actually has five -- well, take that  
24 back, there is six power plants at Alma. Three of  
25 them that are being proposed to be retired are 20

1 megawatt units each, they were built back in the late  
2 '40s, so there's three other power plants at the Alma  
3 site.

4 Q So 60 megawatts will be taken offline?

5 A That's correct.

6 Q And how many megawatts are left?

7 A Let me do some math here. I believe approximately  
8 580 megawatts.

9 Q And so the line as it exists now is currently  
10 handling the 580 plus the 60, correct?

11 A There are five 161 lines out of the Alma site. So  
12 it's a combination of all five lines.

13 Q So the Q1 is only one of five?

14 A The Q1 is only one of five.

15 Q So it's handling a lot less than that. Does it  
16 matter how those are configured as far as what power  
17 is assigned to what lines?

18 A I don't know.

19 Q Well, okay. But if the Q1 line is handling the power  
20 generate -- its share of the power generated at Alma,  
21 if the -- if we lose 60 megawatts, won't there be  
22 less power coming out of Alma?

23 MS. AGRIMONTI: Your Honor, I'm going to  
24 object at this point. Mr. Thompson's testimony does  
25 not relate to engineering considerations.

1 EXAMINER NEWMARK: Sustained.

2 BY MS. OVERLAND:

3 Q In your technical memorandum attached as Exhibit 1,  
4 and you had earlier talked about the line being  
5 divided into three sections, and the 3.1, 3.2, 3.3  
6 sections of the technical memorandum, would that be  
7 the same as the three sections you were describing?  
8 You had used the term Marshland, but I don't see  
9 that.

10 A Which page are you on?

11 Q Okay. If you look -- I'm just looking at the table  
12 of contents now of your technical memorandum where  
13 Section 3, Q1 rebuild options, we have 3.1, 3.2, 3.3.  
14 And you had mentioned that it's divided into three  
15 segments, but here they're, like, slightly different.  
16 And you had mentioned Marshland. So here we have  
17 Alma to Milton, Milton to Trempealeau, Trempealeau to  
18 Holmen.

19 A If you go to page 5 in our introduction, second  
20 paragraph down, it talks about the three segments  
21 that make up the total of 70 miles.

22 Q Page 5. Oh, page -- you mean page 5 of 102?

23 A Right, correct.

24 Q Okay. So it --

25 A The three segments that you're referring to, 3.1,

1           3.2, 3.3, those are the segments for the north 40  
2           miles from Alma to La Crosse.

3       Q     The north 40 only?

4       A     Yeah.

5                       MS. OVERLAND:   Okay.   I have no further  
6           questions.

7                       EXAMINER NEWMARK:   Okay.   Other cross?

8                               CROSS-EXAMINATION

9       BY MR. THIEL:

10      Q     The Department of Transportation, Jim Thiel.   Good  
11           afternoon.   The Q1 line that's referred to that  
12           Dairyland Power Company has an easement for, where  
13           exactly does the Q1 line run?

14      A     Could you repeat that again, please.

15      Q     Yeah, what is the -- the three geographical endpoints  
16           of the Q1 line?

17      A     The Q1 starts at the Alma substation; it proceeds  
18           south to a substation called Marshland where it  
19           interconnects; from there it goes to La Crosse; and  
20           it interconnects with a couple of NSP lines in  
21           La Crosse; and then continues on down to Genoa,  
22           Wisconsin.

23      Q     Okay.   But for purposes of this proceeding, we're  
24           just talking about Alma to La Crosse; is that  
25           correct?

1 A Correct.

2 Q And are you aware of the size of the easement for  
3 your existing line?

4 A Sure. Yes. The existing lines, they were purchased  
5 back in 1950, I believe the majority of those  
6 easements are blanket easements. And -- but we have  
7 been maintaining approximately an 80-foot  
8 right-of-way.

9 Q When you say a blanket easement, what do you mean by  
10 that?

11 A Those were easements that were generally purchased  
12 which took over a larger area than just the  
13 right-of-way, but those were typically types of  
14 easements that were gotten back in the early days.

15 Q So your testimony is that your right-of-way is not 80  
16 feet, it's more than that; is that correct?

17 A That's going a little bit beyond what I can get into.  
18 I'm not a right-of-way expert.

19 Q When you talk about rebuilding the Q1 line from Alma  
20 down to La Crosse, when you say it needs rebuilding,  
21 do you have a precise cost estimate for rebuilding it  
22 exactly as it is now as a 161 kV line?

23 A We have done some generic numbers for that.

24 Q In the absence of this project, would you rebuild the  
25 161 kV line in the same place it is now?

1 A Yes, we would.

2 Q And would you put the towers in the same place as  
3 they are now?

4 A That would probably be something we'd negotiate with  
5 the landowners. We would stay on the existing  
6 rights-of-way. Where the actual location of the  
7 poles would be, it may -- it may change.

8 Q Would you -- generally do you know whether you would  
9 replace them with the H-type poles?

10 A We can do either. We can do the existing H frame,  
11 they could be wood or steel, or you could go to a  
12 single structure, a single pole. So you could build  
13 it either way.

14 Q Are you aware that some of the easements are  
15 restricted to H-frame poles?

16 A I am not.

17 Q Have you looked at all of the easements along the  
18 line?

19 A Some of the folks in our right-of-way department  
20 have, yes.

21 Q You have no direct personal knowledge of what they  
22 state?

23 A No, I don't.

24 Q Approximately when would you proceed to reconstruct  
25 the 161 kV line in the absence of this initiative by

1 CapX?

2 A Well, we would need to wait until the Commission  
3 order comes out to know which route they've selected.  
4 Anticipating that they have chosen possibly the  
5 Arcadia route, we would begin work on doing the  
6 engineering, rights-of-way contacts and that type of  
7 thing. We would probably have to wait until the CapX  
8 line is constructed before we could take that line of  
9 service to rebuild it. So we're probably looking at  
10 starting construction in late 2015.

11 Q And I take it that would require a separate  
12 application to the Commission?

13 A Under Wisconsin law, if Dairyland stays on the  
14 existing rights-of-way, we do not need to get a CPCN.

15 Q And when you say on the existing right-of-way, does  
16 that mean the 80-foot right-of-way?

17 A Correct.

18 Q And is your application for funding to the RUS for  
19 the -- just the Wisconsin portion of the 345 kV  
20 project or is it broader than that?

21 A The Dairyland at this point has not applied to RUS  
22 for funding. The 345 project itself would be a  
23 separate what they call a work plan. We'd have to  
24 file a separate work plan for that project, and that  
25 would take in the whole projects in -- for the cost,



1 both the Minnesota and Wisconsin part.

2 Q So you do not have an application pending before RUS  
3 for funding?

4 A No. Under RUS rules, you have to put a project in a  
5 work plan, they have to approve that work plan.  
6 We've included in -- generally we submit two- to  
7 three-year work plans with RUS. This project has  
8 been included in that. The only funding we have put  
9 into that document is for the permitting phase of it.  
10 The next part of it is that they actually have to  
11 approve the Federal EIS. Unless the environmental  
12 documents are approved, it's at that point they  
13 decide whether they will or will not give you  
14 funding. So the application comes in after the  
15 project is probably built.

16 Q So it's a reimbursement of your share of the cost of  
17 the -- I guess I don't understand. What exactly is  
18 under consideration by RUS?

19 A The -- Dairyland has indicated that we're -- we  
20 planned on 11 percent ownership of the 345 kV  
21 project. The funding for that 11 percent we would  
22 put in an application to RUS to cover those costs.

23 Q Okay. So there is nothing for strictly improving the  
24 161 kV line on the 80-foot right-of-way?

25 A That would be a separate document. Separate loan

1 request.

2 MR. THIEL: Thank you. I have no further  
3 questions.

4 EXAMINER NEWMARK: Okay. Other cross?  
5 No? Redirect?

6 MS. AGRIMONTI: Yes, Your Honor.

7 REDIRECT EXAMINATION

8 BY MS. AGRIMONTI:

9 Q I just wanted to clarify something with Mr. Thompson.  
10 You testified about the existing right-of-way for the  
11 Q1 and that's the existing 80 feet that TPC maintains  
12 for the Q1; is that right?

13 A That's correct.

14 Q And then you also testified that you are not in a  
15 position to be able to opine about whether the  
16 easements might allow TPC to maintain a right-of-way  
17 greater than that 80 feet; is that also correct?

18 A That's correct.

19 MS. AGRIMONTI: Thank you. That's all I  
20 have.

21 EXAMINER NEWMARK: Okay. You're excused.  
22 (Witness excused.)

23 MS. AGRIMONTI: This is when I start  
24 begging.

25 EXAMINER NEWMARK: Okay. We'll take ten

1 minutes. We'll start at quarter to.

2 (Recess taken from 2:35 to 2:45 p.m.)

3 EXAMINER NEWMARK: Let's get on the  
4 record. Okay. Well, the applicants have offered  
5 written surrebuttal and exhibits for the next two  
6 witnesses, Stevenson and Hillstrom. And I guess the  
7 question is really how are we going to handle these?  
8 I've already decided for sake of time we can -- you  
9 know, if they go in, they go in as read. We have  
10 the paper version. We don't have to read it into  
11 the record.

12 However, I guess I'd like to hear from the  
13 parties about this. Because there is substantial  
14 information in here. So I mean, one thing I can  
15 offer is to give people more time, we could take  
16 these witnesses tomorrow. But I don't know if  
17 that's really going to solve our timing problems  
18 because of the order of witnesses we need to have.  
19 If it would help to have more time right now to  
20 review these, I could take -- we can go off the  
21 record for this.

22 (Discussion off the record.)

23 JEFFREY R. WEBB, MISO WITNESS, DULY SWORN

24 DIRECT EXAMINATION

25 BY MR. DAY: